



Proposed Unit No.	Easting Coordinates	Northing Coordinates	Unit Location	Unit Description	Service Connection Type	Primary Isolator	Secondary Isolator	Private Cable Network Termination Type
LC01	387823.208	403047.423	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC02	387803.244	403072.767	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC03	387783.865	403089.895	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC04	387813.883	403102.000	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC05	387849.341	403130.131	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC06	387857.639	403154.663	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC07	387888.455	403164.472	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC08	387918.506	403142.545	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC09	387824.169	403129.428	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC10	387804.682	403160.690	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC11	387776.868	403164.925	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC12	387764.791	403136.902	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC13	387789.080	403191.844	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC14	387804.496	403208.361	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A
LC15	387826.848	403201.258	Refer to 'SHD2164-SHD-HLG-HINC-DR-EO-Lighting Layout-R1' S38 street lighting layout drawing	Proposed galvanised tubular steel lighting column of 6.0 metre nominal height with a planted base as supplied by Mallatite to Manchester City Council street lighting specification with post top mounted at 0° tilt, Philips Luma Gen2 Micro, BGP702 DW50 4000 4.00klm 23w neutral white LED luminaire and Philips Citytouch Central Management System (CMS) node (35/18 lux)	Proposed IDNO supply with secondary isolation	IDNO approved double pole isolator	Lucy Zodion 32A double pole isolator and BS 88 type 2 fuse to luminaire	N/A