

NOTES

- ALL LUMINAIRES WITHIN APARTMENTS SHALL BE COMPLETE WITH DIMMABLE DRIVERS.
- ALL LIGHTING CIRCUITS WITHIN APARTMENTS SHALL BE COMPLETE WITH DIMMER SWITCHES.
- LUMINAIRE MANUFACTURER TO ENSURE THAT ALL DIMMER SWITCHES ARE COMPATIBLE WITH LED LAMPS.

LEGEND

- A ○ F TYPE DOWNLIGHT IP65 760LM 8W 4000K DIMMABLE DRIVER
- B ○ 1500LM 15W 4000K STANDARD DRIVER
- BE ○ 1500LM 15W 4000K EMERGENCY DRIVER
- B1 ○ 2000LM 22W 4000K STANDARD DRIVER
- B1E ○ 2000LM 22W 4000K EMERGENCY DRIVER
- ⊙ BULKHEAD IP65 317mm 2100LM 24W 4000K STANDARD DRIVER
- ⊙ BULKHEAD IP65 317mm 2100LM 24W 4000K EMERGENCY DRIVER
- ⊙ SINGLE IP65 1540mm 3400LM 24W 4000K STANDARD DRIVER
- ⊙ SINGLE IP65 1540mm 3400LM 24W 4000K 3HR EMERGENCY PACK
- F ○ PENDANT LIGHT FITTING (LOW ENERGY)
- EXIT ILLUMINATED EMERGENCY EXIT SIGN WITH ARROW
- ⏏ SINGLE GANG LIGHT SWITCH 'n' DENOTES GANG
- ⏏ 2 WAY LIGHT SWITCH 'w' DENOTES GANG
- ⏏ KEYSWITCH & CONTACTOR TO CONTROL LANDLORDS AREA CLEANERS SOCKET RING MAIN
- ⏏ VANITY UNIT LIGHTING SUPPLIED FROM BATHROOM LIGHTING CIRCUIT
- ⏏ CEILING MOUNTED PIR DETECTOR
- ⏏ MICROWAVE SWITCH FOR CORRIDOR LIGHTING

FOR CONTINUATION SEE DRAWING No M2215-63-E-01-02

C1	CONSTRUCTION ISSUE	NOV 24	DRD	SD
T2	REVISED DUE TO ADDITION OF 2ND. DUPLEX APARTMENTS	NOV 23	DRD	SD
T1	TENDER ISSUE	AUG 21	DRD	SD
P2	AMENDED IN ACCORDANCE WITH REVISED ARCHITECTS LAYOUT	JUN 21	DRD	SD
P1	PRELIMINARY ISSUE	FEB 21	DRD	SD
REV	REVISION	DATE	DRAWN	CHK

CLIENT

MPH ANCOATS LIMITED

PROJECT

RESIDENTIAL DEVELOPMENT
OSBORNE YARD
OLDHAM ROAD

DRAWING TITLE

FIRST FLOOR
LIGHTING AND EMERGENCY LIGHTING
Sheet 1 of 2

DRDESIGN LLP
ENGINEERING - DESIGN - CONSULTANTS
5th FLOOR, BARNFIELD COURT,
BUILDING 2, EXCHANGE QUAY,
MANCHESTER, M1 2EP
Tel: 0161-457-2430 Fax: 0161-457-2001
email: enquiries@dr-design.co.uk
web: www.dr-design.co.uk

DATE	FEB 2021	SCALE	1:50
DRAWN	DRD	ORIGINAL DRAWING SIZE A0	
CHECKED	SD	DRAWING NUMBER	M2215-63-E-01-01
		REV	C1