

2022 Mason Navarro Pledge




600 Masonry Retaining Wall
(No Fence)

General


1.1 This drawing is to be read in conjunction with all Architect's, Engineer's and Services Engineer's drawings and specifications.
1.2 Do not scale from any of the structural drawings. All dimensions to be verified on site and any discrepancies should be highlighted.
1.3 The contractor is responsible for the stability of the building and adjoining structures during construction and shall design, install, adapt and maintain all necessary propping and temporary works. A method statement for the temporary works must be submitted to the contractor
administrator for comment before work begins.
1.4 All materials to comply with the relevant British Standard.




Typical Inspection Chamber Backdrop Detail
(Scale 1:25)



Gully Detail
450mm x 900mm for Road Gully, 375mm x 750mm for Car Park Gully
(Scale 1:25)



Trapped Yard Gully
(Scale 1:25)



Note: All drainage channels shall be installed strictly in accordance with manufacturers instructions

ACO Drain Detail
(Scale 1:10)

FC01 Final Constructiono 23.07.25 RJ

REV COMMENTS DATE CHK

STATUS

FINAL CONSTRUCTION

mnp
mason navarro pledge
Consulting Civil and Structural Engineers
LONDON · MANCHESTER · HITCHIN
0203 9265613 0161 8701197 01462 632012
Email: office@mnp.co.uk
www.mnp.co.uk

CLIENT

TTSP

PROJECT

KS DC Manchester

DRAWING TITLE

Site Wide Typical Drainage Details Sheet 2

SCALE @ A1	DRAWN BY	DATE
1:25	AGD	July 2023

MNP No.	STATUS CODE	REV
223169		**FC01**

Ref No.
170188-MNP-ZZ-XX-DR-C-2801