

RADIATOR SCHEDULE

SCHEDULE REF			0406325-HLE-EN-XX-SH-M-706007 - Radiators											
PROJECT	Computer Science & ITS Project - Eddie Newcombe												No.	04/06325
SYSTEM	LTHW												RAD 01-06	
REF	LOCATION	MODEL / TYPE	ORIENTATION HORIZONTAL / VERTICAL	DESIGN HEATING DUTY (kW)	SELECTION HEATING OUTPUT (W) (see notes 2 and 3)	FLOW RATE (kg/s)	PRESSURE DROP (Pa/m)	ROOM AIR TEMP. (°C)	MOUNTING HEIGHT (m)	DIMENSIONS HEIGHT (mm) WIDTH (mm) DEPTH (mm)			OPERATING WEIGHT (kg)	COMMENTS
RAD 1	B.003 - Break Out	wall-mounted	Horizontal	2.20	TBC	0.05	65	21	0.150	600	2200	100	TBC	
RAD 2	B.003A - Meeting Room	wall-mounted	Horizontal	1.20	TBC	0.03	26	21	0.150	600	1200	100	TBC	
RAD 3	B.003B - Meeting Room	wall-mounted	Horizontal	1.20	TBC	0.03	26	21	0.150	600	1200	100	TBC	
RAD 4	B.003 - Break Out	wall-mounted	Horizontal	2.20	TBC	0.05	65	21	0.150	600	2200	100	TBC	
RAD 5	B.006 - Kitchen	wall-mounted	Horizontal	1.00	TBC	0.02	13	21	0.150	600	1000	100	TBC	
RAD 6	B.006 - Kitchen	wall-mounted	Horizontal	2.20	TBC	0.05	65	21	0.150	600	2200	100	TBC	
NOTES:														
1. RADIATOR SELECTIONS ARE BASED ON THE FOLLOWING MANUFACTURER:														