Outlook

Plan ref 140789

From [redacted]
Date Thu 12/09/2024 16:38
To Jennifer Atkinson [redacted]

Hi Jennifer,

Please can the following condition be attached to the above. The submitted note, along with the original acoustic report is sufficient to address part a of the condition.

NSE4(b)

Residential sound insulation AND overheating

a) Before the development commences a scheme for acoustically insulating the proposed residential accommodation against noise from the nearby road network shall be submitted to and approved in writing by the City Council as local planning authority. There may be other actual or potential sources of noise which require consideration on or near the site, including any local commercial/industrial premises.

The potential for overheating shall also be assessed and the noise insulation scheme shall take this into account. The approved noise insulation and ventilation scheme shall be completed before any of the dwelling units are occupied.

Noise survey data shall include measurements taken during a rush-hour period and night time to determine the appropriate sound insulation measures necessary. The following noise criteria shall be required to be achieved when providing adequate ventilation as defined by Approved Document F of the Building Regulations (whole dwelling ventilation):

Bedrooms (night time - 23.00 - 07.00) 30 dB LAeq (individual noise events shall not exceed 45 dB LAmax,F by more than 10 times)

Living Rooms (daytime - 07.00 - 23.00) 35 dB LAeq

Gardens and terraces (daytime) 55 dB LAeq

Higher internal noise levels than those specified above may be allowed when higher rates of ventilation are required in relation to the overheating condition.

b) Prior to first occupation of the residential units, a verification report shall be required to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic consultant's report. The report shall also undertake post completion testing to confirm that the internal noise criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the internal noise criteria.

Reason: To secure a reduction in noise from traffic or other sources in order to protect future residents from noise disturbance and to reduce the potential for overheating.

Kind regards

[redacted]
Environmental Protection Officer
Environmental Protection
Environmental Health
The Neighbourhoods Directorate
Manchester City Council

email: [redacted]
website: www.manchester.gov.uk
Tel: [redacted]
Internal: [redacted]

We are now on Twitter, for latest news and updates follow us @EnvHealthMcr

****
This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed. If you have received this email in error, please notify the sender, or dpo@manchester.gov.uk, and then permanently delete the email, attachments and all copies.
The full text of the Council's email disclaimer is available at: www.manchester.gov.uk/emaildisclaimer.
Your personal data is very important to us. Please refer to our privacy notice at: www.manchester.gov.uk/privacy for further information.

This footnote also confirms that this email message has been swept for the presence of computer viruses.
****