Hi Steve,

In relation to the discharge of Condition 9, Azymuth understand that there is no externally mounted ancillary plant that serves the building except from the smoke extract system which would only be operational during an emergency or testing. As there is no noise generating plant there shall be no additional noise impacts at nearby noise sensitive locations in line with BS 4142.

Kind Regards,

Ollie Platts

BSc (Hons) | Diploma in Acoustics | AMIOA

Acoustic Consultant

Azymuth Acoustics UK

Professional Acoustic Services

Viridor House, No.3 Bolholt Terrace, Bury, Greater Manchester, BL8 1PP

Tel: +44 (0)161-762 1055/ +44 (0)330-304 0162

E-mail: Ollie@acousticsuk.com **| Web:** www.acousticsuk.com **| Twitter:** @azymuthAUK

Energy Assessments (Part L & EPC), Low Energy and Sustainable Buildings (Code & BREEAM), Passive House Design, Air Leakage Testing, Infra Red Thermography, Renewable Energy Studies, Low Carbon Consultants, Part F Ventilation Compliance, Part G Water Compliance, Part E Acoustic Consultancy & Testing

Company Registration: 10714713 | VAT Registration: 272129806