



File name: I:\UK WSP GROUP\CONVENTIONAL DATA\PROJECTS\2024\EXTERNAL WORKS BUILD UPS\DWG\STAGE 34\DRAWINGS\Z0-WSP-G700-SE-XX-001 - EXTERNAL WORKS BUILD UPS.DWG, printed on 04 November 2022 15:02:05, by Bannister@wsp.co.uk




REF P1: PODIUM PERMEABLE PAVEMENT CONSTRUCTION

LAYER	CLAUSE	MATERIAL	THICKNESS	SPECIAL REQUIREMENTS
SURFACE COURSE	1107	BLOCK PAVING UNIT	80mm	TO LANDSCAPE ARCHITECTS DESIGN
LAYING COURSE	-	CRUSHED IGNEOUS ROCK	50mm	BS EN 7533, $d_{90} \leq 5mm$; $d_{60} > 2mm$
SUB-BASE	803	GRANULAR TYPE 3	VARIES TO SUIT EXTERNAL FFL	COMPACTION TO COMPLY WITH DMRB. REFER TO REFORM DRAWINGS: Z0-REF-G710-PI-Grd-0894-0008 to 0010
DRAINAGE LAYER	-	GEO-CELLULAR CRATES	50mm	DETAILS/SPECIFICATION TO BE AGREED
SLAB	-	CONCRETE SLAB	VARIES	SEE STRUCTURAL ENGINEERS DRAWINGS FOR DETAILS




REF P2: REAR EXTERNALS PERMEABLE PAVEMENT CONSTRUCTION

LAYER	CLAUSE	MATERIAL	THICKNESS	SPECIAL REQUIREMENTS
SURFACE COURSE	1107	BLOCK PAVING UNIT	80mm	TO LANDSCAPE ARCHITECTS DESIGN
LAYING COURSE	-	CRUSHED IGNEOUS ROCK	50mm	BS EN 7533, $d_{90} \leq 5mm$; $d_{60} > 2mm$
SUB-BASE	803	GRANULAR TYPE 3	320mm	COMPACTION TO COMPLY WITH DMRB
FORMATION LEVEL/CAPPING	-	CAPPING LAYER (6F2) OR EXISTING GROUND	TO SUIT FFL	-




REF P3: BLOCK PAVING FOR EMERGENCY FIRE TENDER ACCESS

LAYER	CLAUSE	MATERIAL	THICKNESS	SPECIAL REQUIREMENTS
SURFACE COURSE	1107	BLOCK PAVING UNIT	80mm	TBC BY LANDSCAPE ARCHITECT
LAYING COURSE	-	PROPRIETARY BEDDING MORTAR	50mm	-
BASE COURSE	906	AC32 DENSE BASE 100/150	150mm	PD 6691 TABLE B.11
SUB-BASE	803	GRANULAR TYPE 1	200mm	COMPACTION TO COMPLY WITH DMRB
FORMATION LEVEL	-	SUBGRADE	-	-



REF P4: FLAG PAVING TO MCC SPECIFICATION

LAYER	CLAUSE	MATERIAL	THICKNESS	SPECIAL REQUIREMENTS
SURFACE COURSE	1104	HIGH QUALITY FLAG PAVING	65-80mm	TBC BY LANDSCAPE ARCHITECT
LAYING COURSE	-	HIGH STRENGTH PROPRIETARY BEDDING MORTAR	30mm	MINIMUM STRENGTH 35N/mm ²
BASE COURSE	2602	UNREINFORCED C32/40 CONCRETE	180mm	COMPACTION TO COMPLY WITH DMRB
SUB-BASE	803	TYPE 1 GRANULAR MATERIAL	225mm	COMPACTION TO COMPLY WITH DMRB
FORMATION LEVEL	-	SUBGRADE	-	-



REF P5: FLAG PAVING TO MCC SPECIFICATION ON PODIUM SLAB

LAYER	CLAUSE	MATERIAL	THICKNESS	SPECIAL REQUIREMENTS
SURFACE COURSE	1104	HIGH QUALITY FLAG PAVING	65-80mm	TBC BY LANDSCAPE ARCHITECT
LAYING COURSE	-	HIGH STRENGTH PROPRIETARY BEDDING MORTAR	30mm	MINIMUM STRENGTH 35N/mm ²
BASE COURSE	2602	UNREINFORCED C32/40 CONCRETE	180mm	COMPACTION TO COMPLY WITH DMRB
SUB-BASE	803	TYPE 1 GRANULAR MATERIAL	TO SUIT FFL	COMPACTION TO COMPLY WITH DMRB
SLAB	-	CONCRETE SLAB	VARIES	SEE STRUCTURAL ENGINEERS DRAWINGS FOR DETAILS

TABLE 1: CAPPING LAYER AND SUB-BASE THICKNESS

SUB-GRADE (CBR)	CAPPING + SUB-BASE (MM)	SUB-BASE ONLY (MM)
<2%	SUB GRADE IMPROVEMENT REQUIRED	
2%	600 + 150	-
2.5%	400 + 150	-
3%	350 + 150	300
4%	300 + 150	275
5%	250 + 150	225
8%	225 + 150	200
10%	175 + 150	175
15%+	-	150

1. CAPPING/SUB-BASE DEPTH DEPENDS UPON EQUILIBRIUM CBR TESTING OF SUB-GRADE (THE CONTRACTOR IS RESPONSIBLE FOR UNDERTAKING THESE TESTS AND ANY SUBSEQUENT IN-SITU TESTS TO DEMONSTRATE VALIDITY OF EQUILIBRIUM TESTING). CAPPING/SUB-BASE DEPTHS TO BE IN ACCORDANCE WITH TABLE 1

2. THE CONTRACTOR IS RESPONSIBLE FOR ENSURING THAT THE SUB-GRADE IS NOT EXPOSED TO INCLEMENT WEATHER. SUB-GRADE ONLY DESIGN SHALL ONLY BE USED WHERE THERE IS ADEQUATE DRAINAGE AND FAVORABLE WEATHER AT THE TIME OF CONSTRUCTION

3. WARRANTY FOR PROPRIETARY SURFACE COURSES IS TO BE PROVIDED BY THE MANUFACTURER & NOT WSP.

4. TACK & BOND COATS TO BE PROVIDED WHERE REQUIRED IN ACCORDANCE WITH SHW CLAUSE 920 AND ANY MANUFACTURER'S REQUIREMENTS.

5. SEALING CRIT TO BE USED FOR TEMPORARY BASE COURSE RUNNING SURFACES ONLY. NOT TO BE USED ON SURFACE COURSE.

6. CBR TESTING TO BE TAKEN AT SUB FORMATION LEVEL.

DO NOT SCALE

NOTES:

- ALL DIMENSIONS ARE IN MILLIMETRES UNLESS OTHERWISE STATED
- ALL CLAUSE NUMBERS REFER TO VOLUME 1, SPECIFICATION FOR HIGHWAY WORKS OF THE MANUAL CONTRACT FOR HIGHWAY WORKS.
- THIS DRAWING SHOULD BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT SCHEME DRAWINGS.
- REFER TO WSP DRAWING Z0-WSP-G700-PL-XX-001 FOR LOCATIONS AND EXTENTS OF EACH BUILD UP.

UNTIL TECHNICAL APPROVAL HAS BEEN OBTAINED FROM THE RELEVANT LOCAL AUTHORITIES OR STATUTORY BODIES, IT SHOULD BE UNDERSTOOD THAT ALL DRAWINGS ARE ISSUED AS PRELIMINARY AND NOT FOR CONSTRUCTION. SHOULD THE CONTRACTOR AND / OR EMPLOYER COMMENCE WORK PRIOR TO APPROVAL BEING GIVEN, IT IS ENTIRELY AT THEIR OWN RISK

P03	04/11/2022	JEB	GEOTEXTILE MEMBRANE REFERENCES ADDED	SM	SM
P02	31/10/2022	JEB	UPDATED FOR STAGE 4 CLOSE OUT	SM	SM
P01	19/08/2022	JEB	STAGE 4 ISSUE	SM	SM
REV	DATE	BY	DESCRIPTION	CHK	APP

DRAWING STATUS: STAGE 4

wsp

8 First Street, Manchester, M15 4GU, UK
T+ 44 (0) 161 200 5000
wsp.com

CLIENT: RENAKER

ARCHITECT: SIMPSON HAUGH

SITE/PROJECT: PORT STREET, MANCHESTER

TITLE: EXTERNAL WORKS BUILD UPS

SCALE @ A1: 1:10MM	CHECKED: SM	APPROVED: SM
PROJECT NO: 70084548	DESIGNED: JEB	DRAWN: JEB
		DATE: November 22

DRAWING No: Z0-WSP-G700-SE-XX-001	REV: P03
-----------------------------------	----------

© WSP UK Ltd