



Document Number
143404-FAI-B1-B1-DR-D-02021

Revision C03

Issued for Construction

Ms Fatima Asim - United Living
Aug 16, 2024, 11:31 AM GMT+1:00

Manhole Number	Cover Level	Connections	Pipe			Manhole Size	Types		
Coordinates	Depth To Soffit		Code	Inverts	Diams		Manhole	Cover	
FMH30	45.330 0.662		1	—	44.568	100	450	PPIC	*450x450 FACTA CLASS B
E. 384782.119 N. 398414.911			0	—	44.568	100			
FMH31	45.330 0.696		1	—	44.584	100	450	PPIC	*450x450 FACTA CLASS B
E. 384779.741 N. 398413.533			2	—	44.534	100			
FMH32	45.330 0.795		1	—	44.485	100	450	PPIC	*450x450 FACTA CLASS B
E. 384772.881 N. 398409.558			2	—	44.435	100			
FMH33	45.330 0.857		1	—	44.423	100	450	PPIC	*450x450 FACTA CLASS B
E. 384775.253 N. 398405.167			0	—	44.373	100			
FMH34 PUMPING STATION	45.330 0.930		1	—	44.300	100	TBC	PROPRIETARY PACKAGED PUMPING STATION PUMP RATE: 5.5L/s HEAD: 4.1m REQUIRED STORAGE: 3.2m3	TBC D400
E. 384770.558 N. 398401.720			2	—	44.300	100			
			3	—	44.300	100			
			0	—	TBC	RISING MAIN			

***INTERNAL MANHOLE COVERS**

- ALL INTERNAL MANHOLE COVERS MUST BE TRIPLE SEALED.
- TYPE & SPECIFICATION OF MANHOLE COVERS TO BE AGREED WITH ARCHITECT PRIOR TO ORDERING / INSTALLATION.
- MANHOLE COVERS MUST BE INSTALLED PARALLEL WITH ADJACENT WALL LINES.
- MANHOLE COVERS MUST BE INFILLED WITH CONCRETE OF AN ADEQUATE STRENGTH TO ACHIEVE FULL LOADING, PLEASE REFER TO CHOSEN MANUFACTURERS INSTRUCTIONS.
- ALL INTERNAL MANHOLE COVERS MUST NOT BE TRAFFICKED BY CONSTRUCTION TRAFFIC.

Do not scale from this drawing.

SAFETY HEALTH AND ENVIRONMENTAL INFORMATION

IN ADDITION TO THE HAZARD/RISKS NORMALLY ASSOCIATED WITH THE TYPES OF WORK DETAILED ON THIS DRAWING, NOTE THE FOLLOWING RISKS AND INFORMATION.

RISKS LISTED HERE ARE NOT EXHAUSTIVE. REFER TO DESIGN ASSESSMENT FORM NO.

CONSTRUCTION

- RESTRICTED SITE/CONFINED SPACES
- GROUND WATER/INUNDATION

DEMOLITION

FOR INFORMATION RELATING TO USE, CLEANING AND MAINTENANCE SEE THE HEALTH AND SAFETY FILE

IT IS ASSUMED THAT ALL WORKS WILL BE CARRIED OUT BY A COMPETENT CONTRACTOR WORKING, WHERE APPROPRIATE, TO AN APPROVED METHOD STATEMENT.

C03 15/07/24 FMH30, FMH31, FMH32 & FMH33 LOCATED TO AVOID SLAB THICKENING, INVERTS AMENDED ACCORDINGLY. DAS JRT JRT

C02 07/05/24 FMH34 PUMPING STATION PUMP RATE AMENDED. DAS JRT JRT

Rev. Date Description Drawn. Chkd. Appd.

FAIRHURST

51a St. Pauls Street
LEEDS
LS1 2TE

Tel: 0113 243 4671
Fax: 0844 381 4412

Client:



Project Title:

**1 NQ & CLEMENTS BUILDING
TARIFF STREET
MANCHESTER**

Drawing Title:

**BLOCK 1NQ
BASEMENT
INTERNAL FOUL WATER
MANHOLE SCHEDULES**

Scale at A3:

NTS

Status:

Construction

Drawn:

DS

Checked:

JRT

Approved:

JRT

Date:

06/03/24

Date:

06/03/24

Date:

06/03/24

Drawing No.:

143404-FAI-B1-B1-DR-D-02021-C03