



To	Head of Planning	FAO: Katie Raw
From	Head of Compliance, Enforcement and Community Safety	
Contact Officer:	Karen Williamson	Our Ref: PR202506-1653222

Date: 24 June 2025

Telephone: 31347

Consultation on Planning Application

Application No: **143088/FO/2025**

Description: Change of use of ground floor to form Class E (Commercial, Business and Service use) together with installation of shopfront; and, part single/part two storey rear extension, installation of rear dormer and enlarged front dormer in association with the use of the first floor and accommodation in the roof space as 1no. residential dwelling (Class C3 use)

Location: 59 Barlow Road Manchester M19 3DB

I write in response to your memorandum regarding the above application and to inform you that I have considered the application and recommend that the following conditions are attached to any approval.

Commercial

HOURS1

Premises opening hours

The premises shall not be open outside the following hours unless otherwise agreed in writing by the City Council as local planning authority:-

To be submitted.

Reason - To safeguard the amenities of the occupiers of nearby residential accommodation.

HOURS2

Deliveries to commercial premises

Deliveries, servicing and collections, including waste collections shall not take place outside the following hours: 07:30 to 20:00, Monday to Saturday, no deliveries/waste collections on Sundays/Bank Holidays.

Reason - To safeguard the amenities of the occupiers of nearby residential accommodation.

NSE1

a) The premises shall be acoustically insulated and treated to limit the break out of noise in accordance with a noise study of the premises and a scheme of acoustic treatment that has been submitted to and approved in writing by the City Council as local planning authority. The scheme shall be implemented in full before the use commences or as otherwise agreed in writing by the City Council as local planning authority.

b) Prior to occupation of the development a verification report shall be required to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic consultant's report. The report shall also undertake post completion testing to confirm that acceptable criteria have been met. Any instances of non-conformity with the recommendations in the verification report shall be detailed along with any measures required to be undertaken prior to occupation of the development to ensure compliance with the internal noise criteria.

Reason - To safeguard the amenities of the occupiers of the building and occupiers of nearby properties.

Residential

NSE4(b)

Residential sound insulation AND overheating

a) Before the development commences a scheme for acoustically insulating the proposed residential accommodation against noise from Barlow Road shall be submitted to and approved in writing by the City Council as local planning authority. There may be other actual or potential sources of noise which require consideration on or near the site, including any local commercial/industrial premises.

The potential for overheating shall also be assessed and the noise insulation scheme shall take this into account. The approved noise insulation and ventilation scheme shall be completed before any of the dwelling units are occupied.

Noise survey data shall include measurements taken during a rush-hour period and night time to determine the appropriate sound insulation measures necessary. The following noise criteria shall be required to be achieved when providing adequate ventilation as defined by Approved Document F of the Building Regulations (whole dwelling ventilation):

Bedrooms (night time - 23.00 - 07.00)	30 dB L_{Aeq} (individual noise events shall not exceed 45 dB $L_{Amax,F}$ by more than 10 times)
Living Rooms (daytime - 07.00 - 23.00)	35 dB L_{Aeq}
Gardens and terraces (daytime)	55 dB L_{Aeq}

Higher internal noise levels than those specified above may be allowed when higher rates of ventilation are required in relation to the overheating condition.

b) Prior to first occupation of the residential units, a verification report shall be required to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic consultant's report. The report shall also undertake post completion testing to confirm that the internal noise criteria have been met. Any instances of non-conformity with the recommendations in the verification report shall be detailed along with any measures required to be undertaken prior to first occupation of the residential units to ensure compliance with the internal noise criteria.

Reason: To secure a reduction in noise from traffic or other sources in order to protect future residents from noise disturbance and to reduce the potential for overheating.

Both commercial and residential

CONSTRUCTION HOURS

Construction works shall be confined to the following hours unless otherwise agreed in writing by the City Council as local planning authority:

- Monday - Friday: 7.30am - 6pm
- Saturday: 8.30am - 2pm
- Sunday / Bank holidays: No work

Reason - To safeguard the amenities of nearby residents pursuant to policies SP1, EN19 and DM1 of the Manchester Core Strategy.

NSE6

External plant/equipment/servicing

a) Externally mounted ancillary plant, equipment and servicing shall be selected and/or acoustically treated in accordance with a scheme designed so as to achieve a rating level of 5dB (L_{Aeq}) below the typical background (L_{A90}) level at the nearest noise sensitive location. Prior to commencement of the use hereby approved the scheme shall be submitted to and approved in writing by the City Council as local planning authority in order to secure a reduction in the level of noise emanating from the site. The scheme shall be implemented in full before the use commences or as otherwise agreed in writing by the City Council as local planning authority.

b) Prior to the operation of the scheme a verification report shall be submitted to and approved in writing by the City Council as local planning authority to validate that the work undertaken throughout the development conforms to the recommendations and

requirements in the approved acoustic report. The report shall also undertake post completion testing to confirm that the noise criteria have been met. Any instances of non-conformity with the recommendations in the verification report shall be detailed along with any measures required to be undertaken prior to operation of the scheme to ensure compliance with the agreed noise criteria.

Reason - To minimise the impact of the development and to prevent a general increase in pre-existing background noise levels around the site.

REF*

a) Before the development commences a scheme for the storage and disposal of refuse shall be submitted to and approved in writing by the City Council as local planning authority.

New developments shall have refuse storage space for segregated waste collection and recycling. Internal and external storage areas are required.

b) The details of the approved scheme shall be implemented as part of the development and shall remain in situ whilst the use or development is in operation.

Reason - In the interests of amenity and public health.

*The proforma/ Waste Management Strategy must include the following information:

- Estimated volumes and types of waste produced by the development;
- Details of internal and external stores for both waste and recycling, including any plans and designs;
- Location of the proposed collection point and details of the route the collection vehicle will take;
- Details of how waste will be transferred between stores and to the collection location; and
- Details of number and capacity of bins proposed and collection frequency.
- Other details as per 'Waste Proforma v1.0' - refer to guidance at: http://www.manchester.gov.uk/downloads/download/6048/waste_management_strategy

The waste pro forma provided is not acceptable. The residential and commercial bins need to be separate with a scheme to ensure that the commercial business is not able to use the residential bins. Furthermore, the residential needs a bin for each waste stream. The commercial business needs to show how they will recycle.

CLAND* Watching brief

In the event that ground contamination, groundwater contamination and/or ground gas are encountered on the site at any time before the development is occupied during the watching brief, then development shall cease and/or the development shall not be occupied until a report detailing what measures, if any, are required to remediate the land (the Remediation Strategy), is submitted to and approved in writing by the City Council as local planning authority and the development shall be carried out in accordance with the agreed Remediation Strategy and validated. If no contamination is found, then a post-completion report shall be submitted to evidence this prior to occupation of the development.

Reason – To ensure that the presence of or the potential for any contaminated land and/or groundwater is detected and appropriate remedial action is taken in the interests of public safety. Pursuant to [INSERT] of the Unitary Development Plan for the City of Manchester.

Information for Developers guidance documents can be downloaded using the following link:

http://www.manchester.gov.uk/info/500207/planning_and_regeneration/1962/additional_planning_guidance/3

Should you wish to discuss this matter further please contact Karen Williamson.

Samantha Stabler

Head of Compliance, Enforcement and Community Safety