

Below Ground Drainage Test & Inspection

Form Reference	F1.2211509
Owned By	Calum Henry (MPB Structures Limited ~)
Date	09/06/2023 10:37:53
Status	Opened
Project Name	253 - First Street, Manchester - Block D
Project Reference	253
Project Address	
Location	253 - First Street, Manchester - Block D

Form Location	253 - First Street, Manchester - Block D
Location	Block D Foul and Storm Drainage.

Comments	Created By	Date
Please refer to mark-up drawing attached for locations and details of testing carried out.	Calum Henry (MPB Structures Limited ~)	09/06/2023 10:40:37
Any item which had been clouded (issues to be rectified) will be repaired and a complete QA sign-off for Block A, B and D will be submitted.	Calum Henry (MPB Structures Limited ~)	09/06/2023 10:46:30

Document Name	Type	Created By	Date
Site Wide Foul Testing Mark-up.pdf	Pdf	Calum Henry (MPB Structures Limited ~)	09/06/2023 10:46:47
Site Wide Storm Testing Mark-up.pdf	Pdf	Calum Henry (MPB Structures Limited ~)	09/06/2023 10:46:59

Have the works been inspected?	Yes
--------------------------------	-----

Comments	Created By	Date
Works inspected at time of installation, post installation via CCTV camera and at time of final water testing.	Calum Henry (MPB Structures Limited ~)	09/06/2023 10:38:47

Have the adequate temporary works been used?	N/A
Is the pipe the correct diameter?	Yes
Have the pipes been laid with the correct bed and surround?	Yes

Comments	Created By	Date
Works inspected at time of installation by Downing Engineering Site Team.	Calum Henry (MPB Structures Limited ~)	09/06/2023 10:39:18

Has an air test being carried out?	Yes
------------------------------------	-----

Comments	Created By	Date
Air testing carried out at time of installation. QA document is for final water testing sign-off.	Calum Henry (MPB Structures Limited ~)	09/06/2023 10:39:49

Have Building Control Inspected?	Yes
----------------------------------	-----

Comments	Created By	Date
As indicated on mark-up drawing.	Calum Henry (MPB Structures Limited ~)	09/06/2023 10:40:03

Additional photos be included	
Contractor Sign off	

Calum Henry (MPB Structures Limited ~)
09/06/2023 10:47:17

DCL Approval	
DCL Sign off	John Bagley