Structures Group

Sunlight House, P2

WJ493

Sunlight House, Quay Street, Manchester

M3 3HP GB

SA07- Micro Strip Sample Record

Project Number	WJ493
Project Name	Sunlight House, P2
Principal Contractor	MYCO Contracts Ltd
Date	Jul 01, 2025

SAMPLE DETAILS

Before

Description & Location (Floor, Elevation, Reference)

Basement stairs on Atkinson/little Quay st elevation

After

Media Spec & Supplier Paint Rid from Stone Health

Equipment set Up (Location of compressor, Location of pot, location of compressor)

Paint Rid, paint kettle , water bottle/ spray , empty bucket and wet and dry clothes

Description of Process (Pot spec, Compressor Spec, Pressure, Nozzle distance from wall, Number of pass)

Applied with paint brush in thick layers and left for approx 30 mins per coat of paint then removed delicately with scraper making sure no scratches happen to the glaze. This process depends how many layers there is in a particular area. Final coat is to delicately remove paint from the grout lines.
All areas then rinsed down with soapy water then a dry microfibres cloth to finish. All excess paint to be disposed of in rubble bags and put into designated waste skips on site.