



Architecture

Lewis & Hickey Ltd
1 St. Bernard's Row
Edinburgh, EH4 1HW
0131 343 6222
edinburgh@lewis-hickey.com

Edinburgh | Guildford | London | Manchester | Nottingham

KEY

- NO WORKS
- DOWNTAKINGS / REMOVALS
- REINSTATEMENTS
- DIRECTIONAL SIGNAGE**
LED RECESSED EMERGENCY ESCAPE SIGN
LUMINAIRE WITH DIRECTIONAL ARROW POINTING
LEFT OR RIGHT
- LED RECESSED EMERGENCY ESCAPE SIGN
LUMINAIRE WITH DIRECTIONAL ARROW POINTING
DOWNWARDS
- SELF CONTAINED/MAINTAINED EXIT SIGN
ILLUMINATED INTERNALLY / EXTERNALLY
WITH EMERGENCY LIGHT
- FIRE EXTINGUISHERS**
MOUNTED ON PAINTED SOFTWOOD BACK PANELS
- HYDROSPRAY WATER
- CARBON DIOXIDE
- FIRE BLANKET
- FOAM
- DOOR SIGNAGE**
EMERGENCY EXIT ONLY, DOOR ARMED
to inside of fire exit doors
- FIRE EXIT KEEP CLEAR
to outside of Fire Exits
- FIRE DOOR KEEP SHUT
blue discs both sides of fire door
- FIRE SYMBOLS, MISC**
- FD30S 30min FIRE RESISTING DOOR
- FD60S 60min FIRE RESISTING DOOR
- FIRE ESCAPE ROUTE
- 60 MIN FIRE RATED SEPARATION

REFER TO M&E CONSULTANTS DRAWINGS TO CONFIRM LOCATION OF
EMERGENCY LIGHTS, SMOKE/HEAT DETECTION, SOUNDERS AND FIRE
PANEL/INTERFACE.

M&E CONSULTANT TO PROVIDE FIRE DAMPERS TO ALL FIRE RESISTING
WALL SERVICE PENETRATIONS.

TRAVEL DISTANCES:

OS1 to point of divergence PoD1 = 5.8m
PoD to FE1 = 1.3m
PoD to FE2 = 29m
PoD to FE3 = 13.8m

A 27.03.25 MATERIAL SPECIFICATION ADDED, REPLACEMENT FIRE DOOR ADDED RH 27.03.25
TO SCOPE, ADDRESS UPDATED.

rev	date	description	drawn	checked



address
25 ST ANN STREET
MANCHESTER
M2 7PW

ref no. - sortcode 160002

description
MEZZANINE FLOOR PLAN
PROPOSED
SEPARATION WORKS

status

IPMS1	-	sqm	-
-------	---	-----	---

IPMS2	-	sqm	-
-------	---	-----	---

scale	1:50	paper size	A1	brand	
-------	------	------------	----	-------	--

scale	1:100	paper size	A3	brand	
-------	-------	------------	----	-------	--

dn	ZR	date	18/07/24	chk	RH	date	02.09.24
----	----	------	----------	-----	----	------	----------

nw drawing number	E7480-GA-MZ	rev.	A
-------------------	-------------	------	---

