MMA LIGHTING CONSULTANCY
Exterior Lighting Design Specialists

Private Developer

Proposed Connection Schedule

16 May 2025

MMA19394 - Langdale Mews - Private Lighting - Equipment Schedule - R0

Proposed Unit No.	Easting Coordinates	Northing Coordinates	Service Connection Type	Location	Unit Description	Isolator Type	Termination Type
P01	44.12	421.26	Private supply to be confirmed by others	MMA19394/001	Proposed galvanised tubular steel lighting column of 5m nominal height with a post top mounted DW Windsor Kirium Pro Mini 1.93klm 3000k (KIRIUM PRO MINI 8LED 3k C2 Rear Shield 650mA UMSUG 42 0016 0000 100) LED lantern complete with integral rear shield and Electronic DALi enabled driver and Lucy Zodion ZCELL LED 20 lux (1:1 ratio).	Supply connection to be confirmed by others	Supply connection to be confirmed by others
P02	56.92	401.48	Private supply to be confirmed by others	MMA19394/001	Proposed galvanised tubular steel lighting column of 5m nominal height with a post top mounted DW Windsor Kirium Pro Mini 1.93klm 3000k (KIRIUM PRO MINI 8LED 3k C2 Rear Shield 650mA UMSUG 42 0016 0000 100) LED lantern complete with integral rear shield and Electronic DALi enabled driver and Lucy Zodion ZCELL LED 20 lux (1:1 ratio).	Supply connection to be confirmed by others	Supply connection to be confirmed by others
P03	49.69	383.64	Private supply to be confirmed by others	MMA19394/001	Proposed galvanised tubular steel lighting column of 5m nominal height with a post top mounted DW Windsor Kirium Pro Mini 1.93klm 3000k (KIRIUM PRO MINI 8LED 3k C2 Rear Shield 650mA UMSUG 42 0016 0000 100) LED lantern complete with integral rear shield and Electronic DALi enabled driver and Lucy Zodion ZCELL LED 20 lux (1:1 ratio).	Supply connection to be confirmed by others	Supply connection to be confirmed by others

NOTE: NUMBERS SHOWN ON THE SCHEDULE AND DESIGN DRAWING ARE FOR IDENTIFICATION PURPOSES ONLY - ACTUAL COLUMN NUMBERS TO BE SPECIFIED BY LOCAL AUTHORITY LIGHTING DEPARTMENT OR OVERSEEING ORGANISATION.