

Application details:	Application number: 142453/FO/2025 Proposal: Erection of a six storey building to form 82 residential dwellings (Use Class C3a) with associated landscpaing, car parking and boundary treatment Location: Land At The West Side Of The Junction Of Grey Mare Lane And Ashton New Road, Manchester
-----------------------------	--

LLFA Comments 20/05/2025

The following Information has been considered:

Planning Portal uploads:	17/03/2025
Further submission emails:	-
Pre-Application Advice:	-

Any LLFA Comments to LPA

Condition 1: Prior to the commencement of the development hereby approved, a surface water drainage scheme in accordance with Non-Statutory Technical Standards for Sustainable Drainage Systems (March 2015) or any subsequent replacement national standards, shall be submitted for approval in writing by the City Council, as Local Planning Authority. This shall include:

- Progression through the drainage hierarchy must be evidence based and supported by site investigation including assessments of ground conditions and infiltration testing in accordance with BRE365. Proposals of attenuation should achieve half drain time within 24 hours.
- Where surface water is connected to the public sewer, agreement in principle from United Utilities is required that there is adequate spare capacity in the existing system taking future development requirements into account. An email of acceptance of proposed flows and/or new connection will suffice.
- Maximised integration of green SuDS components (utilising infiltration or attenuation) if practicable.
- Construction details of flow control and SuDS elements.
- A plan indicating easements. SuDS features (including attenuation tanks) should be appropriately positioned, including a 2.5m easement from the existing highway and a 5m easement from any dwellings, guaranteeing accessibility for future maintenance and contingency for asset failure. This practice is in accordance with SuDS Manual (C753).

The development shall be constructed and completed in accordance with the approved details prior to the first occupation/use of the development.

Reason: To promote sustainable development, secure proper drainage and to manage the risk of flooding and pollution. This condition is imposed in light of national policies within the NPPF and NPPG and local policies EN08 and EN14.

Condition 2: Prior to the first occupation/use of the development hereby approved details of the implementation, maintenance and management of the surface water drainage scheme, as approved by **Condition X**, shall be submitted for approval in writing by the City Council, as Local Planning Authority. Those details shall include:

- Verification report providing photographic evidence of constructed flow control and SuDS components as per design drawings approved as part of **Condition X**.
- Provide As Built construction drawings OR confirm that they align with the original design construction drawings.
- Management and maintenance plan for the lifetime of the development which shall include the arrangements for adoption by any public body or statutory undertaker, or any other arrangements to secure the operation of the sustainable drainage scheme throughout its lifetime.

The scheme shall be implemented and thereafter managed and maintained in accordance with the approved details.

Reason: To manage flooding and pollution and to ensure that a managing body is in place for the sustainable drainage system and there is funding and maintenance mechanism for the lifetime of the development.