

GENERAL NOTES

- 1.0 THE DRAWING SHALL BE READ IN CONJUNCTION WITH THE SPECIFICATION & ALL OTHER RELEVANT DOCUMENTS & DRAWINGS PROVIDED BY MEP DESIGN.
- 2.0 THE DRAWING INDICATES THE DESIGN INTENT FOR THE WORKS.
- 3.0 COORDINATION WORKING DRAWINGS, INSTALLATION DRAWINGS & BUILDERS WORK DRAWINGS SHALL BE PREPARED BY THE CONTRACTOR.
- 4.0 DIMENSIONS SHALL NOT BE SCALED FROM THE DRAWING & THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL DIMENSIONS & LEVELS ON SITE FOR THE ACTUAL SITTING OUT OF THE WORKS.

DOMESTIC SERVICES NOTES

- 1.0 DRAIN COCKS TO BE INSTALLED AT ALL LOW POINTS.
- 2.0 INSTALLATION & TESTING OF THE DOMESTIC WATER INSTALLATION SHALL BE IN ACCORDANCE WITH BS 8558:2015, APPROVED DOCUMENT G & THE WATER REGULATION GUIDE 1999.
- 3.0 THE INSTALLATION SHALL COMPLY WITH THE RECOMMENDATIONS IN HSC ACOP L8 & CISE TM13 ON THE CONTROL OF LEGIONELLA BACTERIA IN WATER SYSTEMS.
- 4.0 ALL PIPEWORK SHALL BE INSULATED IN ACCORDANCE WITH BS 5970.
- 5.0 ALL PIPEWORK & FITTINGS TO BE INSTALLED AS PER MANUFACTURERS WRITTEN INSTRUCTIONS.
- 6.0 ALL PIPEWORK TO BE SUPPORTED (CLIPPED) IN ACCORDANCE WITH THE MANUFACTURERS WRITTEN INSTRUCTIONS.
- 7.0 ALL SIZING SHALL BE IN ACCORDANCE WITH BS 8558:2015 & BS EN 806-3 2006.

GENERAL LEGEND

---	PIPEWORK RUN IN DUCT BELOW GROUND.
-.-.-	PIPEWORK RUN IN CEILING VOID.
-.-.-	PIPEWORK RUN AT HIGH LEVEL.
---	PIPEWORK RUN AT LOW LEVEL.
M.C.W.S.	MAINS COLD WATER SERVICE.
H.W.S. F	HOT WATER SERVICE FLOW.
H.W.S. R	HOT WATER SERVICE RETURN.
L/L	ITEM MOUNTED AT LOW LEVEL.
H/L	ITEM MOUNTED AT HIGH LEVEL.
W/T	ITEM MOUNTED AT WORKTOP LEVEL.
R.T.A.	RISE TO ABOVE.
R.F.B.	RISE FROM BELOW.
D.F.A.	DROP FROM ABOVE.
D.T.B.	DROP TO BELOW.
	MIXING VALVE.
IV	ISOLATION VALVE.
DOC	DRAIN OFF COCK.
WHB	WASH HAND BASIN.
TMV	THERMOSTATIC MIXING VALVE.
	HEATRAE SADIA MEGAFL0 COMMERCIAL FLEXISTOR DIRECT, ELECTRIC CYLINDER.
EX	DENOTES EXISTING TO BE RETAINED.

T01	ISSUED FOR TENDER	JUNE 25
P02	REVISED COMMENT ISSUE	MAY 25
P01	ISSUED FOR COMMENT	MAY 25
Revision	Description	Date

**MEP
DESIGN**

Bridgeway House, Mellor Road, Cheadle Hulme, Cheadle SK8 5AU
www.mepdesign.co.uk

Client
PRIORY MANCHESTER LTD.

Project
82 KING STREET, MANCHESTER

Title
**PUBLIC HEALTH SERVICES
GROUND FLOOR
DOMESTIC WATER SERVICES**

Scale	1 : 50 @A1			Drawn		W.H.	
Project No.	Zone	Originator	Uniclass	Type	Level	Code	Rev
4_035	X	- MEP	G501	PL	00	001	T01