

Application details:	Application number: 141661/FO/2024 Proposal: Erection of 8no dwelling houses (4no blocks of semi-detached), with associated infrastructure works, car parking and hard and soft landscaping. Location: Grassland To The North/East Of Amberley Drive, Manchester.
-----------------------------	--

LLFA Comments 04/06/2025

The following Information has been considered:

Planning Portal uploads:	03/12/2024- 01/04/2025
Further submission emails:	From: David Lawless <david.lawless@manchester.gov.uk> Sent: 30 April 2025 11:36 To: Flood Risk Management <floodriskmanagement@manchester.gov.uk> Subject: Fw: 141661/FO/2024 - Grassland To The North/East Of Amberley Drive Manchester - updated reports.
Pre-Application Advice:	NA

Any LLFA Comments to LPA
United Utilities public sewer onsite. The LPA should consult UU on an approvable master plan before determining the planning application.

Condition: Prior to the commencement of the development hereby approved, a surface water drainage scheme for the development site, based on sustainable drainage principles, shall be submitted for approval in writing by the City Council, as Local Planning Authority. This shall include:

- For surface water connections, evidence of agreement in principle from the relevant authority/service provider is required to ensure there is adequate spare capacity in the existing system taking future development requirements into account. An email of acceptance of proposed new connection will suffice.
- Finalised surface water drainage layout including all components, levels, connectivity and proposed overland flow routes for extreme events.
- Hydraulic calculations of the proposed drainage system, including all design parameters. Results must demonstrate no surcharge for the 1 in 2, no flooding in the 1 in 30 and no flooding of buildings for the 1 in 100 + 45% Climate Change.
- A plan indicating easements. SuDS features (including attenuation tanks) should be appropriately positioned, including a 2.5m easement from the existing highway and a 5m easement from any

dwellings, guaranteeing accessibility for future maintenance and contingency for asset failure. This practice is in accordance with SuDS Manual (C753).

- Construction details of flow control and SuDS components.
- Details of how the scheme shall be maintained and managed after completion.

The development shall be constructed and completed in accordance with the approved details prior to the first occupation/use of the development.

Reason: To promote sustainable development, secure proper drainage and to manage the risk of flooding and pollution. This condition is imposed in light of national policies within the NPPF and NPPG and local policies EN08 and EN14

Informative:

To apply for the land drainage consent, please use the following link,

link: <https://manchester.civicapayforms.co.uk/Sales/LaunchInternet.aspx?saleform=drainage>.