

#### GENERAL NOTES

- 1.0 THE DRAWING SHALL BE READ IN CONJUNCTION WITH THE SPECIFICATION & ALL OTHER RELEVANT DOCUMENTS & DRAWINGS PROVIDED BY MEP DESIGN.
  - 2.0 THE DRAWING INDICATES THE DESIGN INTENT FOR THE WORKS.
  - 3.0 COORDINATION WORKING DRAWINGS, INSTALLATION DRAWINGS & BUILDERS WORK DRAWINGS SHALL BE PREPARED BY THE CONTRACTOR.
  - 4.0 DIMENSIONS SHALL NOT BE SCALED FROM THE DRAWING & THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL DIMENSIONS & LEVELS ON SITE FOR THE ACTUAL SITTING OUT OF THE WORKS.
  - 5.0 RAINWATER AS PER ARCHITECTS DRAWINGS.
- #### ABOVE GROUND DRAINAGE NOTES
- 1.0 THE SANITARY PIPEWORK INSTALLATION SHALL COMPLY WITH THE REQUIREMENT OF THE BUILDING REGULATION APPROVED DOCUMENT H & THE RECOMMENDATIONS OUTLINED IN BS 12056-2.
  - 2.0 ACCESS POINT TO BE PROVIDED AT THE BASE OF ALL VERTICAL SOIL STACKS & AT EVERY FLOOR ABOVE ALL BRANCHES & AT CHANGES IN DIRECTION. ACCESS POINTS TO BE AT 1.0m A.F.F.L.
  - 3.0 ALL HORIZONTAL SOIL & WASTE PIPEWORK TO BE LAID TO A FALL OF 1-40 MINIMUM 1-80 UNLESS OTHERWISE STATED.
  - 4.0 ALL PIPES PASSING THROUGH FLOOR SLABS ARE TO BE SEALED AGAINST WATER PENETRATION WITH POLYSULPHIDE FLEXIBLE SEALANT BY BUILDER.
  - 5.0 ALL TRAPS TO BE ANTI-SYPHON TYPE. EACH WHB TO HAVE 32Ø CONNECTION, SINK & SHOWER TO HAVE 40Ø CONNECTION, WC TO HAVE 110Ø CONNECTION.
  - 6.0 INTUMESCENT FIRE COLLARS ARE TO BE FITTED WHERE PIPEWORK PASSES THROUGH FIRE COMPARTMENTS ON ALL PIPES 50Ø & ABOVE.
  - 7.0 ALL AAV'S TO BE FULLY ACCESSIBLE.
  - 8.0 ALL WHB & SINK TO BE C/W 75mm DEEP SEAL TRAPS. ALL BATHS TO BE C/W 'P' TRAP.

#### GENERAL LEGEND

- FOUL DRAINAGE PIPEWORK RUN IN FLOOR VOID.
  - FOUL DRAINAGE PIPEWORK RUN IN CEILING VOID.
  - FOUL DRAINAGE PIPEWORK RUN AT HIGH LEVEL.
  - FOUL DRAINAGE PIPEWORK RUN AT LOW LEVEL.
  - CONDENSATE PIPEWORK IN CEILING VOID.
- L/L ITEM MOUNTED AT LOW LEVEL.  
H/L ITEM MOUNTED AT HIGH LEVEL.  
C/V ITEM MOUNTED IN CEILING VOID.  
R/V ITEM MOUNTED IN ROOF VOID.  
F/V ITEM MOUNTED IN FLOOR VOID.  
W/T ITEM MOUNTED AT WORKTOP LEVEL.  
R.T.A. RISE TO ABOVE.  
R.F.B. RISE FROM BELOW.  
D.F.A. DROP FROM ABOVE.  
D.T.B. DROP TO BELOW.  
RE DENOTES RODDING EYE.  
EX DENOTES EXISTING ITEM TO BE RETAINED.
- AH 450x450 ACCESS HATCH.  
FG FLOOR GUILLEY.  
FAN COIL UNIT.  
WALL MOUNTED HEAT PUMP UNIT.  
MECHANICAL VENTILATION HEAT RECOVERY UNIT.

|          |                       |         |
|----------|-----------------------|---------|
| T01      | ISSUED FOR TENDER     | JUNE 25 |
| P02      | REVISED COMMENT ISSUE | MAY 25  |
| P01      | ISSUED FOR COMMENT    | MAY 25  |
| Revision | Description           | Date    |

**MEP  
DESIGN**

Bridgeway House, Mellor Road, Cheadle Hulme, Cheadle SK8 5AU  
www.mepdesign.co.uk

Client  
**PRIORY MANCHESTER LTD.**

Project  
**82 KING STREET, MANCHESTER**

Title  
**PUBLIC HEALTH SERVICES  
GROUND FLOOR  
ABOVE GROUND DRAINAGE**

|             |            |            |          |       |       |       |       |  |
|-------------|------------|------------|----------|-------|-------|-------|-------|--|
| Scale       | 1 : 50 @A1 |            |          | Drawn |       | W.H.  |       |  |
| Project No. | Zone       | Originator | Uniclass | Type  | Level | Code  | Rev   |  |
| 4_035       | - X -      | MEP        | - G581 - | PL    | - 00  | - 001 | - T01 |  |