

Application details:	Application number: 142670/FO/2025 Proposal: Erection of foodstore (Use Class E) with associated car parking and landscaping. Location: 440 Hollinwood Avenue, Manchester, M40 0AE.
-----------------------------	--

LLFA Comments 05/06/2025**The following Information has been considered:**

Planning Portal uploads:	10/04/2025 - 30/04/2025
Further submission emails:	NA
Pre-Application Advice:	NA

Condition: Prior to the commencement of the development hereby approved, a surface water drainage scheme for the development site, based on sustainable drainage principles, shall be submitted for approval in writing by the City Council, as Local Planning Authority. This shall include:

- Progression through the drainage hierarchy must be evidence based and supported by site investigation including assessments of ground conditions and infiltration testing in accordance with BRE365. Proposals of attenuation should achieve half drain time within 24 hours.
- For surface water connections, evidence of agreement in principle from the relevant authority/service provider is required to ensure there is adequate spare capacity in the existing system taking future development requirements into account. An email of acceptance of proposed new connection will suffice.
- Finalised surface water drainage layout including all components, levels, connectivity and proposed overland flow routes for extreme events.
- Hydraulic calculations of the proposed drainage system, including all design parameters. Results must demonstrate no surcharge for the 1 in 2, no flooding in the 1 in 30 and no flooding of buildings for the 1 in 100 + 45% Climate Change.
- Where flows less than 5 l/s are proposed, a blockage risk assessment must be undertaken. If the risk cannot be adequately managed, a higher minimum discharge rate should be considered / agreed with relevant authority.
- A plan indicating easements. SuDS features (including attenuation tanks) should be appropriately positioned, including a 2.5m easement from the existing highway and a 5m easement from any dwellings, guaranteeing accessibility for future maintenance and contingency for asset failure. This practice is in accordance with SuDS Manual (C753).

The development shall be constructed and completed in accordance with the approved details prior to the first occupation/use of the development.

Reason: To promote sustainable development, secure proper drainage and to manage the risk of flooding and pollution. This condition is imposed in light of national policies within the NPPF and NPPG and local policies EN08 and EN14.