

GENERAL NOTES

- 1.0 THE DRAWING SHALL BE READ IN CONJUNCTION WITH THE SPECIFICATION & ALL OTHER RELEVANT DOCUMENTS & DRAWINGS PROVIDED BY MEP DESIGN.
- 2.0 THE DRAWING INDICATES THE DESIGN INTENT FOR THE WORKS.
- 3.0 COORDINATION WORKING DRAWINGS, INSTALLATION DRAWINGS & BUILDERS WORK DRAWINGS SHALL BE PREPARED BY THE CONTRACTOR.
- 4.0 DIMENSIONS SHALL NOT BE SCALED FROM THE DRAWING & THE CONTRACTOR SHALL BE RESPONSIBLE FOR OBTAINING ALL DIMENSIONS & LEVELS ON SITE FOR THE ACTUAL SITTING OUT OF THE WORKS.

SMALL POWER & DATA LEGEND

- SINGLE UNSWITCHED SOCKET OUTLET.
- SINGLE SWITCHED SOCKET OUTLET.
- SINGLE SWITCHED CLEANERS SOCKET OUTLET.
- DOUBLE SWITCHED SOCKET OUTLET. 'USB' DENOTES C/W DOUBLE USB OUTLETS.
- SINGLE RJ45 DATA OUTLET.
- DOUBLE RJ45 DATA OUTLET.
- SINGLE DATA OUTLET IN CEILING VOID FOR WIFI WIRELESS ACCESS POINT.
- SINGLE DATA OUTLET IN CEILING VOID FOR CCTV CAMERA.
- SWITCHED FUSED CONNECTION UNIT.
- UNSWITCHED FUSED CONNECTION UNIT.
- FLEX OUTLET FRONT PLATE.
- ROTARY LOCKABLE ISOLATOR SIZED AS SHOWN.
- BS60309 COMMANDO SOCKET OUTLET SIZED AS SHOWN.

GENERAL LEGEND

- L/L ITEM MOUNTED AT LOW LEVEL.
- H/L ITEM MOUNTED AT HIGH LEVEL.
- C/V ITEM MOUNTED IN CEILING VOID.
- R/V ITEM MOUNTED IN ROOF VOID.
- F/V ITEM MOUNTED IN FLOOR VOID.
- W/T ITEM MOUNTED AT WORKTOP LEVEL.
- WP DENOTES WEATHERPROOF IP65 TYPE SUITABLE FOR EXTERNAL USE.
- EX DENOTES EXISTING TO BE RETAINED.
- R DENOTES EXISTING TO BE RELOCATED.
- R.T.A. RISE TO ABOVE.
- R.F.B. RISE FROM BELOW.
- D.F.A. DROP FROM ABOVE.
- D.T.B. DROP TO BELOW.

ABBREVIATIONS LEGEND

- CCTV - CCTV CAMERA MOUNTED IN CEILING VOID.
- D - DISABLED ALARM MOUNTED IN CEILING VOID.
- DA - DOOR ACCESS CONTROL IN CEILING VOID.
- EF - EXTRACT FAN IN CEILING VOID.
- F - FRIDGE AT LOW LEVEL.
- FCU - MECHANICAL FAN COIL UNIT CEILING VOID.
- HD - HAND DRYER MOUNTED AT HIGH LEVEL WITH FLEX OUTLET PLATE BEHIND HAND DRYER FOR FINAL CONNECTION.
- HP - HEAT PUMP UNIT IN CEILING VOID.
- HPU - HEAT RECOVERY UNIT IN CEILING VOID.
- IFP - INTERFACE PANEL IN DADO TRUNNING.
- IL - INDUCTION LOOP IN CEILING VOID.

T01	ISSUED FOR TENDER	JUNE 25
P02	REVISED COMMENT ISSUE	MAY 25
P01	ISSUED FOR COMMENT	MAY 25
Revision	Description	Date

**MEP
DESIGN**

Bridgeway House, Mellor Road, Cheadle Hulme, Cheshire SK8 5AU
www.mepdesign.co.uk

Client
PRIORY MANCHESTER LTD.

Project
82 KING STREET, MANCHESTER

Title
**ELECTRICAL SERVICES
GROUND FLOOR
SMALL POWER, DATA & CONTAINMENT**

Scale	1 : 50 @A1	Drawn	W.H.
Project No.	Zone	Originator	Uniclass
24_035	X	MEP	G531 - PL - 00 - 001 - T01

