

Hi Ian

The lighting design is produced in compliance with BS-EN12464-2 and 13201.

The obtrusive light calcs have been produced for the nearest properties to the site, they are all compliant.

The results are shown in the table on the left hand side of the drawing.

If you look at the lines below the lighting schedule all the lines that begin with 'Nearby Residential Buildings' shows the results re obtrusive light, this is info that the planners need.

There is also some additional information on the BREEAM table.

If you need more information please let me know.

Kind Regards

Janine Sehne | Regional Sales Manager (Northern Region)
Mobile: 07974 454612
Email: jsehne@kingfisherlighting.com
Website: www.kingfisherlighting.com
Brochures: [Download the latest guides here](#)

