

ouw relocation schedule v1.10

Subject: OUW Relocation Schedule V1.10
Project: Rylands Building, Manchester
Reference: Rylands Building – OUW
Author: EAJC
Reviewer: NGRC

Item	Level	Element	Grid Location	Relocation Reason	Photograph	New Grid Location	Photograph
2	-2	Basement Wall/ Foundation	K/12	Basement walls/ piers inaccessible due to being located behind sprinkler room wall.		H/12	
5	-2	Column/ Beams/ Slab/ Foundation	F/10	Column location currently inaccessible within existing stair core.		G/10	

Item	Level	Element	Grid Location	Relocation Reason	Photograph	New Grid Location	Photograph
8	-2		O/12	Column location currently inaccessible as contained within decommissioned ventilation fan room.		Q/12	
16	-1	Basement Wall/Column	A/8	Unable to access pier location due to current floor layout.		A/9	

Item	Level	Element	Grid Location	Relocation Reason	Photograph	New Grid Location	Photograph
16	-1	Basement Wall/ Column	S1/15	Unable to access pier location due to current floor layout.		T1/15	
17	-1	Basement Wall/ Column/ Slab/ Foundations	S/14	Column now known to pass down to sub basement level.		R/14	

Item	Level	Element	Grid Location	Relocation Reason	Photograph	New Grid Location	Photograph
40	5	Column/ Beams/ Slab	D/14	Relocated at floor above due to inaccessibility. Location at fifth relocated to maintain continuous column stack OUW.	See Item 58.	G/14	
55	6	Column	Q/14	Electrical cabinet located at proposed OUW location.		R/14	

Item	Level	Element	Grid Location	Relocation Reason	Photograph	New Grid Location	Photograph
58	6	Column/ Beams/ Slab	D/13	Proposed OUW location inaccessible due to current floor layout.		G/13	

e_{nd}

Ref: EAJC / Rylands Building – OUW / Rylands Building, Manchester / 25 February 2021