

[illegible]

[illegible]

Link Engineering		Page 4
Lombard House 145 Great Charles Street Birmingham, B3 3LP		
Date 24/04/2025 15:42 File LM3107 - Source Control....	Designed by Link Engineering Checked by	
Innovyze	Source Control 2019.1	

Model Details

Storage is Online Cover Level (m) 100.000

Cellular Storage Structure

Invert Level (m) 99.000 Safety Factor 2.0
Infiltration Coefficient Base (m/hr) 0.00000 Porosity 0.95
Infiltration Coefficient Side (m/hr) 0.00000

Depth (m)	Area (m ²)	Inf. Area (m ²)	Depth (m)	Area (m ²)	Inf. Area (m ²)
0.000	4.0	0.0	0.401	0.0	0.0
0.400	4.0	0.0			

Orifice Outflow Control

Diameter (m) 0.050 Discharge Coefficient 0.600 Invert Level (m) 99.000

©1982-2019 Innovyze