

Item	System Reference	Code	Suffix	DWG	L1	L2/ID	W	H	Vol	PD	Wt	No.		Performance, dB							
					mm	mm	mm	mm	m ³ /s	Pa	kg	Off.		63	125	250	500	1k	2k	4k	8k
1	ATT/01- EF/01- EXTRACT	PL	G	A13G	900	200			0.1	5	10	1	IL	1	3	7	19	28	23	20	15
2	ATT/02- EF/01- DISCHARGE	PL	G	A13G	900	200			0.1	5	10	1	IL	1	3	7	19	28	23	20	15
3	ATT/03- HRU/01- EXHAUST	SL	GJ	A02G	900		500	400	0.525	30	36	1	IL	6	11	18	26	35	30	25	16
4	ATT/04- HRU/01- INTAKE	SL	GJ	A02G	900		500	400	0.525	30	36	1	IL	6	11	18	26	35	30	25	16
5	ATT/05- HRU/03- SUPPLY	SL	GJ	A02G	900		500	400	0.525	30	36	1	IL	6	11	18	26	35	30	25	16
6	ATT/06- HRU/04- EXTRACT	SL	GJ	A02G	900		500	400	0.525	30	36	1	IL	6	11	18	26	35	30	25	16
7	CTA- TOILET- GROUND FLOOR	SL	GJ	A02G	900		350	200	0.151	15	20	1	IL	2	5	11	24	46	42	36	22
8	CTA- TOILET- FIRST FLOOR	SL	GJ	A02G	900		350	200	0.122	15	20	1	IL	2	5	11	24	46	42	36	22
9	CTA- TOILET- SECOND FLOOR	SL	GJ	A02G	900		350	200	0.093	15	20	1	IL	2	5	11	24	46	42	36	22
10	CTA- STAFF ROOM	PL	G	A13G	600	150			0.033	5	6	1	IL	1	2	6	16	23	19	17	12

NOTES

LABEL WITH ITEM NO. & SYSTEM REF.

IL = INSERTION LOSS (dB)

G - SELF FINISH PRE-GALVANISED STEEL CONSTRUCTION.

J - SPLITTERS ARRANGED HORIZONTALLY.

AS REV P01 WATERMAN SCHEDULE ISSUED.