



ROCKER PIPES	
NOMINAL DIAMETER (mm)	EFFECTIVE LENGTH (m)
150-600	0.600
601-750	1.000
OVER 750	1.250

ROCKER PIPES TO BE INSTALLED TO ALL MANHOLES AS PER
DESIGN AND CONSTRUCTION GUIDANCE REQUIREMENTS,
'SECTION E6.6 - RIGID PIPES AND JOINTS ADJACENT TO
STRUCTURES' AND 'TABLE 'E13'

- | | | | |
|-----|--|----------------------------|-----------------------------|
| 1. | SETTING OUT SHALL BE UNDERTAKEN USING ONLY THE INFORMATION GIVEN. DISTANCES SHOULD NOT BE SCALED FROM THIS DRAWING. | | |
| 2. | ALL SEWERS SHALL BE CONSTRUCTED IN ACCORDANCE WITH THE DESIGN AND CONSTRUCTION GUIDANCE AND WHERE APPLICABLE UNITED UTILITIES DETAILS | | |
| 3. | THE MINIMUM GRAVITY PIPE DIAMETER UNDER ADOPTABLE HIGHWAYS SHALL BE 150mm | | |
| 4. | IT IS THE RESPONSIBILITY OF THE CONTRACTOR TO VERIFY ALL INFORMATION GIVEN WITH REGARDS TO EXISTING SERVICES AND DRAINAGE CONNECTIONS ETC. PRIOR TO COMMENCING THE WORKS. THE RATES SHALL INCLUDE FOR HAND DIG ABOVE SERVICES TO BE REMOVED. THE CONTRACTOR SHALL ADHERE TO THE COM REGULATIONS AT ALL TIMES | | |
| 5. | THE OUTSIDES OF ALL SEWERS SHALL BE A MINIMUM OF 1.0m FROM KERB LINES AND THE OUTSIDE OF MANHOLES SHALL BE A MINIMUM OF 0.5m FROM KERB LINES | | |
| 6. | EXISTING FLOWS IN WATERCOURSES, SEWERS AND LAND DRAINS SHALL BE MAINTAINED AT ALL TIMES | | |
| 7. | ONLY TRAINED PERSONNEL SHALL BE PERMITTED TO ENTER CONFINED SPACES | | |
| 8. | ALL MATERIALS TO BEAR THE RELEVANT B.S. KITEMARK AND COMPLY FULLY WITH THE SPECIFICATIONS. ALL CONCRETE & CONCRETE PRODUCTS MUST USE SULPHATE RESISTANT CEMENT UNLESS THE SITE INVESTIGATION REPORT PROVES THAT SULPHATE ATTACK FROM SOILS AND GROUNDWATER WILL NOT OCCUR TO WITHSTAND A CLASS | | |
| 9. | ALL OPENING NOTICES ETC. AS REQUIRED UNDER HIGHWAYS ACTS ETC. ARE TO BE OBTAINED PRIOR TO COMMENCEMENT OF WORKS. ALL WORKS ARE TO BE INSPECTED BY L.A., NHBC OR THE NETWORK OPERATOR AS APPLICABLE. | | |
| 10. | WHERE 'ULTRA BIR' UPVC PIPES (OR SIMILAR APPROVED) ARE USED IN ADAPTABLE DRAINAGE THEY SHALL STILL BE HANDLED AND LAID IN ACCORDANCE WITH THE SPECIFICATION AND GUIDANCE ISSUED BY THE HIGH-PERFORMANCE PIPE ASSOCIATION. | | |
| 11. | A CLASS B SACK BED AND SURROUND MUST BE USED FOR SUCH PIPES. TRENCH BACKFILL IN HIGHWAYS TO WITHIN 1m OF HIGHWAY SHALL, AS DIRECTED BY THE HIGHWAY AUTHORITY BE A SUITABLE GRANULAR MATERIAL ALL IN ACCORDANCE WITH SEWERS FOR ADOPTION CD. 4.3.4. | | |
| 12. | SLAB LEVELS SHALL NOT BE VARIED WITHOUT REFERENCE TO THE ENGINEER FOR GUIDANCE | | |
| 13. | DOMESTIC DRAINAGE SHALL BE TO BUILDING REGULATIONS APPROVED DOCUMENT H. 110mm UP V.P.C. PIPES LAID TO THE FOLLOWING MINIMUM FALLS UNLESS OTHERWISE SHOWN. | | |
| | HEAD RUN
ELSEWHERE | FOUL
1 IN 40
1 IN 60 | S.W.
1 IN 60
1 IN 100 |
| 14. | ALL GULLY CONNECTIONS TO BE 150mm VTRIFIED CLAY UNLESS NOTED OTHERWISE | | |
| 15. | MINIMUM COVER TO DRAINAGE SOFFIT LEVEL: | | |
| | LANDSCAPING
0.600m | TRAFFICKED AREAS
0.900m | HIGHWAYS
1.200m |
| | <ul style="list-style-type: none"> CLASS 'S' BEDDING AND SURROUND TO BE USED WHERE MINIMUM COVER IS ACHIEVED. WHERE MINIMUM COVER IS NOT ACHIEVED CLASS 'Z' BEDDING AND SURROUND (CONCRETE ENCASEMENT) IS TO BE USED. | | |
| 16. | ALL PIPES TO BE 1000 UNLESS NOTED | | |
| 17. | DRAINAGE CHANNELS ARE TO CONNECT DIRECTLY INTO ATTENUATION TANK | | |
| 18. | ALL INSPECTION CHAMBER SIZES TO BE 4500 | | |

SCP
an RSK company

Date:	08.04.2024	Drawn By:	LC
Scale:	1:20 @ A1	Checked:	LR
Status:	DESIGN	Approved:	NMc

Drawing No.	Rev.
SCP-230871-S106-0500-041	B