

44758 - AP Watches Manchester - Outdoor Condensers & Associated Equipment Schedule							
Ref	Serving System	Manufacturer	Model	SOUND PRESSURE LEVEL (dBA) - Heating/Cooling	DIMENSIONS (mm)	ELECTRICAL SUPPLY	PHASE
					- Width x Depth x Height		
CU 01	FCU-01/02	Daikin	RXYSQ6TV9	70	900x320x1345	230V	Single
CU 02	FCU-04/05	Daikin	RXYSQ6TV9	70	900x320x1345	230V	Single
CU 03	FCU-03/10	Daikin	RXYSQ6TV9	70	900x320x1345	230V	Single
CU 04	FCU-07/08/09/11/12	Daikin	RXYSQ4TV9	68	900x320x1345	230V	Single
CU 05	FCU-06	Daikin	RZAG35A	62	870x373x734	230V	Single
Notes:							
1. Outdoor unit to be located externally on the roof to replace the existing units .							
2. Access for maintenance shall be as per manufacturers recommendations.							
3. Final handing of each FCU to be confirmed with Daikin prior to order.							

