

S106 Part 2 'Request for permission to work on a public sewer (MEDIM / HIGH RISK)'



Water for the North West

United Utilities Reference Number:

06647305

Contractor details

Contractor/company name	CIVILS AND CONSTRUCTION SOLUTIONS LTD
Contractor email address	PHIL@CIVILSLTD.CO.UK
Works Supervisor	PHIL BARNES

Principal Contractor details (if applicable):

Company name	XENON 303 LTD		
Name of contact for project	SHUJA REHMAN		
Email address	shuja@clearcutaccounting.co.uk		
Date of proposed works	22/11/2024	Type of connection approved	New Manhole

Site details: The site / property which is proposed for connection to the public sewer

Site address (including postcode)	492-494 CLAREMONT ROAD MANCHESTER M14 5WA
--------------------------------------	---

APPROVED

Your application for permission to work on the public sewer has been approved.
THIS PERMIT SHOULD BE AVAILABLE ON SITE FOR INSPECTION

This notice constitutes your permit make a connection to the public sewer network as detailed on your application, 'Request for permission to work on a public sewer'. You are now authorised to make the connection to the public sewer based on the agreed method and on the date given.

Please provide 5 days' notice to the Development Support Technician named below to arrange an inspection of the works.

The excavation should not be backfilled until the United Utilities appointed person has inspected the works.

United Utilities reserve the right to request a connection to the public sewer be laid open for inspection.

United Utilities will also be entitled to recover all costs associated for any excavation, remedial works and repeat visits if these requirements are not met.

**You must log on and off the sewer network at the beginning and end of each shift when working on the public sewer by calling
07826 539459**

and quoting the United Utilities reference number at the top of this decision notice.

Any gas alarms, residual risks or sewer incidents should also be reported on this number.

Comments

Approval granted for a 225mm combined connection via the construction of a new manhole on the combined sewer located within Stenbury Road.

*The new manhole must be constructed in line with United Utilities standard details.

Developer Services Inspector	Marcus Jones
Contact number	07823553970

Date	20/11/2024
------	------------