



THIS DRAWING IS A TECHNICAL DRAWING AND SHOULD NOT BE USED FOR ANY OTHER PURPOSE WITHOUT THE WRITTEN PERMISSION OF THE DESIGNER.

THIS DRAWING IS FOR INFORMATION ONLY DO NOT SCALE

CDM REGULATIONS			
NUMBER	DATE	DATE	DATE
	ISSUED	REVISED	APPROVED

- LEGEND:
- RE II - ROOFING EYE
 - HIGH LEVEL PIPE
 - LOW LEVEL PIPE
 - BELOW GROUND PIPE
 - CONDENSATE PIPEWORK
 - SVP SOIL VENT PIPE
 - SOIL VENT PIPE
 - STUB STACK
 - SOIL VENT PIPE (PROPOSED)
 - SOIL VENT PIPE (EXISTING)
 - FLOOR DULLY

- DRAINAGE NOTES:
- DRAWING TO BE READ IN CONJUNCTION WITH SPECIFICATIONS
 - REPORT ANY DISCREPANCIES TO THE DRAWING ORIGINATOR IMMEDIATELY
 - ALL DIMS ARE IN MM UNLESS STATED OTHERWISE
 - SANITATION PIPEWORK MUST COMPLY WITH BUILDING REGULATIONS PART H
 - DRAINAGE SERVICES SHALL COMPLY WITH BS EN 12056 (SYSTEM III)
 - ALL HORIZONTAL WASTE PIPES TO HAVE 1:40 GRADIENT WHERE FEASIBLE
 - PIPEWORK MUST BE SUPPORTED IN LINE WITH MANUFACTURERS RECOMMENDATIONS
 - ALL PIPEWORK TO BE SOLVENT WELDED PUSH FIT TO FINAL APPLIANCE ONLY FOR EASY MAINTENANCE
 - INSTALLATION TO ALLOW FOR EXPANSION WITH SLIP JOINTS TO SUIT
 - ACCESS/ROOFING POINTS SHALL BE FITTED AT EACH FLOOR LEVEL AT THE END OF HORIZONTAL BRANCHES, ALL CHANGES IN DIRECTION & EVERY 12M ON STRAIGHT SECTIONS
 - WC MANIFOLDS SHALL HAVE VENTED UPSTAND ROOFING POINTS ABOVE LEVEL OF CISTERN
 - ALL NEW VENT PIPE TERMINATIONS TO ATMOSPHERE SHALL BE AGREED WITH THE ARCHITECT
 - ALL ROOF PENETRATIONS SHALL BE WEATHERED IN ACCORDANCE WITH THE ROOF SPECIALISTS REQUIREMENTS
 - ALL BASINS/SINKS CONNECTING TO A RUN WHICH DOES NOT CONNECT TO A VENT PIPE MUST USE AIRSTOP/SHOUL TRAPS
 - PLASTIC PIPES PENETRATING A FIRE COMPARTMENT (REFER TO FIRE STRATEGY DRAWINGS), 50MM AND ABOVE SHALL BE FITTED WITH A SUITABLY INSTALLED FIRE COLLAR
 - ALL BENDS TO BE LONG RADIUS SWEEP BENDS, IDEALLY USING 135° ENDS TO FORM A BEND. USE OF 90° ELBOWS ARE NOT ACCEPTABLE
 - ALL DRAINAGE PIPEWORK PASSING THROUGH ROSE SENSITIVE SPACES SHALL BE ACOUSTICALLY LAGGED
 - ALL EXPOSED DRAINAGE PIPES TO BE WHITE IN COLOUR
 - HEPFO WATERLESS TRAPS SHALL BE INSTALLED ON CONDENSATE PIPE CONNECTIONS
 - ALL FLOOR DULLYS SHALL BE PROVIDED AS PART OF THE UNDERGROUND DRAINAGE PACKAGE. LOCATIONS SHOWN FOR INFORMATION ONLY
 - KITCHENETTE AREA TERMINATION POINTS TO BE AGREED WITH CONTRACTOR

CD1	08.11.24	ISSUE FOR CONSTRUCTION	DB	SH
REV	DATE	AMENDMENTS	BY	CHK

FOR COMMENT & APPROVAL

Commercial Services Design Ltd
Unit 5
Woodside Court
Clayton Wood Rise
Leeds LS10 8HF
Tel: 0113 3223190
Web: www.csdesign.co.uk



CLIENT
G&H BUILDING SERVICES

PROJECT
**SUNLIGHT HOUSE
LITTLE QUAY STREET
MANCHESTER M3 3HP**

TITLE
**ELECTRICAL SERVICES
LIGHTING LAYOUT
LEVEL 04**

SCALE: 1:100

DATE: MAY 24

ENGINEER: DB

ISSUED: JUNE 24

APPROVED: BW

1298-CSD-XX-04-DR-E-6305

C01