



NOTES

1. ALL TRAY WORK IS DEEMED TO BE 25mm RETURN MEDIUM DUTY GALVANISED STEEL TYPE UNLESS OTHERWISE DETAILED.

2. ALL WIRE BASKET IS DEEMED TO BE 54mm RETURN ZINK STEEL TYPE UNLESS OTHERWISE DETAILED.

CONTAINMENT LAYOUT TO BE REVIEWED AND POSSIBLY REVISED FOLLOWING RECEIPT OF FIRE ALARM, SECURITY, P/Vs, ACCESS CONTROL DESIGN INFORMATION AND DRAWINGS BY THE SPECIALIST.

NOTES

1. THE TABLE ABOVE DETAILS THE POWER SEPARATION FROM DATA & VOICE CARRYING CABLES IN REFERENCE WITH ISO 11801 & EN 50174 & ECA (EMC) GUIDELINES
2. HORIZONTAL CABLING RUNS OF MORE THAN 35m NO SEPARATION IS REQUIRED FOR THE FINAL 15m

 DADO DROP

THIS DRAWING IS FOR INFORMATION ONLY DO NOT SCALE			
COM REGULATIONS			
HAZARDS	SAFETY NOTES	DATE REVISED	BY ASSESSMENT DATE
NOTES 1. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH THE M&E SPECIFICATION AND TO ALL RELEVANT ARCHITECTS AND ENGINEERS DRAWINGS. 2. PRIMARY CONTAMINANT RISKS INDICATED ON THIS DRAWING, THE CONTRACTOR SHALL INCLUDE FOR ALL SECONDARY CONTAMINANT RISKS TO BE COVERED COMPLETE END TO END CONTAMINANT SYSTEM INCLUDING BUT NOT LIMITED TO RISKS FROM PRIMARY CONTAMINANT TO POINTS OF USE. 3. ALL CABLE TRAY SHALL BE HEAVY DUTY 50mm depth (UNLESS SPECIFICALLY STATED ON THE LAYOUT). 4. ALL CABLE BASKET SHALL BE 40mm DEEP UNLESS SPECIFICALLY STATED ON THE LAYOUT. 5. CONTAINMENT RISKS TO DADO RISKS SHALL BE INSTALLED AS BELOW UNLESS A SPECIFIC SIZE IS PROVIDED ON THE LAYOUT. 5.1. GENERAL LIGHTING & POWER - 50mm BASKET (RISK 2) 5.2. DATA - 50mm BASKET (RISK 2) 6. FOR SERVICES RUNNING WITHIN THE CEILING BULKHEAD, SEE DRAWING - ILM-CDMA-04-002-0001. 7. FINAL CONTAMINANT RISKS AND ROUTES TO BE CONFIRMED FOLLOWING CONFIRMATION OF MECHANICAL HEATING COOLING LOAD, FIRE ALARM, ACCESS CONTROL, AND CCTV DESIGN INFORMATION.			

C01	08.11.24	ISSUED FOR CONSTRUCTION	01	08
REV	DATE	AMENDMENTS	BY	CHK

**CONSTRUCTION
ISSUE**

Commercial Services Design Ltd
Unit 5
Woodside Court
Clayton Wood Rise
Leeds
LS18 6RF
Tel: 0113 3223190
Web: www.csdesign.uk.com



CLIENT	
G&H BUILDING SERVICES	
PROJECT	
SUNLIGHT HOUSE LITTLE QUAY STREET MANCHESTER M3 3HP	
TITLE	
ELECTRICAL SERVICES CONTAINMENT LAYOUT LEVEL 04	
SCALE @ A0: 1/100	CSD REF: CSD 1298
DRAWN: MW	ENGINEER: OI
STARTED: NOVEMBER 24	ISSUED: NOVEMBER 24
CHECKED: DB	APPROVED: BW
DRAWING NO.	REV.
1298-CSD-XX-04-DR-E-6105	C01

This document is the property of Commercial Services Design Ltd. Copyright is reserved by them and is loaned on the condition that it is not used after the date of its return and without consent of Commercial Services Design Ltd. Printed on Recycled Paper.