



This document and its contents are the property of the Purchaser/Employee and Crookes Walker Consulting. They may not be copied or reproduced in any way, in part or whole, without prior written consent of Crookes Walker Consulting. This drawing shall be used in conjunction with the CWC Mechanical and / or Electrical Specification. DO NOT SCALE FROM THIS DRAWING

DESIGNERS RISK ASSESSMENT
REFER TO APPENDIX 1 OF M&E SPECIFICATION FOR DESIGNERS RISK ASSESSMENT SCHEDULE


DESIGNERS RISK ASSESSMENT SCHEDULE

3 No 200DIA HOLES TO BE INSTALLED TO ACCOMMODATE LV CABLES AND LTHW F&R PIPEWORK



- Minimum cover depth to suit traffic, loads
- Geotextile surround and clean out facility
 - Plastic geotextile units
 - 20mm or 40mm granular backfill
 - Inlet pipe
 - Catchment to remove oil and sediment
 - Sand bedding layer
 - Infiltration from sides and base
- NOTE: CHANNELS PROVIDED ACCESS TO INSULATION TUNNELS FOR INSPECTION & MAINTENANCE IF REQUIRED

REINFORCED CONCRETE PLINTH, OPEN WELD MESH FENCING AROUND ASHPs. PLINTH TO BE DESIGNED BY STRUCTURAL ENGINEER




PROPOSED BASE DETAILS

TYPICAL ASHP ABSORBOTIVE FENCING

NTS


TYPICAL CRATE DRAINAGE SOAKWAY DETAIL

NTS



BUILDERSWORK HOLE DETAIL

1:20



PROPOSED ELEVATION B

1:50

Rev	Date	Description	Eng/CHK
T3	20/12/24	UPDATED DUE TO COMMENTS	JS GR
T2	19/12/24	UPDATED DUE TO COMMENTS	JS GR
T1	25/11/24	TENDER ISSUE	JS GR

CWC
Crookes Walker Consulting
Sallya 9a, Bisc, 17 Marble Street
Manchester M2 3AW
Tel: 0161 604 9999
The Plaza, Old Hall Street,
Tel: 0151 600 5400
Email: sallya@cwcon.co.uk
Website: www.cwcon.co.uk

EQUANS

Project
EQUANS MCC BLACKELY CEMETERY OFFICE AND YARD

Drawing Title
PROPOSED EXTERNAL MECHANICAL SERVICES

Status
TENDER

Project No.
3390

Scale / Paper Size
BW 1:100 @ A1


Drawing No.
3390-CWC-XX-ZZ-DR-M-5001

Rev
T3



- Minimum cover depth to suit traffic, loads
- Geotextile surround and clean out facility
 - Plastic geotextile units
 - 20mm or 40mm granular backfill
 - Inlet pipe
 - Catchment to remove oil and sediment
 - Sand bedding layer
 - Infiltration from sides and base
- NOTE: CHANNELS PROVIDED ACCESS TO INSULATION TUNNELS FOR INSPECTION & MAINTENANCE IF REQUIRED

REINFORCED CONCRETE PLINTH, OPEN WELD MESH FENCING AROUND ASHPs. PLINTH TO BE DESIGNED BY STRUCTURAL ENGINEER




PROPOSED BASE DETAILS

TYPICAL ASHP ABSORBOTIVE FENCING

NTS


TYPICAL CRATE DRAINAGE SOAKWAY DETAIL

NTS



BUILDERSWORK HOLE DETAIL

1:20



PROPOSED ELEVATION B

1:50

Rev	Date	Description	Eng/CHK
T3	20/12/24	UPDATED DUE TO COMMENTS	JS GR
T2	19/12/24	UPDATED DUE TO COMMENTS	JS GR
T1	25/11/24	TENDER ISSUE	JS GR

CWC
Crookes Walker Consulting
Sallya 9a, Bisc, 17 Marble Street
Manchester M2 3AW
Tel: 0161 604 9999
The Plaza, Old Hall Street,
Tel: 0151 600 5400
Email: sallya@cwcon.co.uk
Website: www.cwcon.co.uk

EQUANS

Project
EQUANS MCC BLACKELY CEMETERY OFFICE AND YARD

Drawing Title
PROPOSED EXTERNAL MECHANICAL SERVICES

Status
TENDER

Project No.
3390

Scale / Paper Size
BW 1:100 @ A1


Drawing No.
3390-CWC-XX-ZZ-DR-M-5001

Rev
T3



- Minimum cover depth to suit traffic, loads
- Geotextile surround and clean out facility
 - Plastic geotextile units
 - 20mm or 40mm granular backfill
 - Inlet pipe
 - Catchment to remove oil and sediment
 - Sand bedding layer
 - Infiltration from sides and base
- NOTE: CHANNELS PROVIDED ACCESS TO INSULATION TUNNELS FOR INSPECTION & MAINTENANCE IF REQUIRED

REINFORCED CONCRETE PLINTH, OPEN WELD MESH FENCING AROUND ASHPs. PLINTH TO BE DESIGNED BY STRUCTURAL ENGINEER




PROPOSED BASE DETAILS

TYPICAL ASHP ABSORBOTIVE FENCING

NTS


TYPICAL CRATE DRAINAGE SOAKWAY DETAIL

NTS



BUILDERSWORK HOLE DETAIL

1:20



PROPOSED ELEVATION B

1:50

Rev	Date	Description	Eng/CHK
T3	20/12/24	UPDATED DUE TO COMMENTS	JS GR
T2	19/12/24	UPDATED DUE TO COMMENTS	JS GR
T1	25/11/24	TENDER ISSUE	JS GR

CWC
Crookes Walker Consulting
Sallya 9a, Bisc, 17 Marble Street
Manchester M2 3AW
Tel: 0161 604 9999
The Plaza, Old Hall Street,
Tel: 0151 600 5400
Email: sallya@cwcon.co.uk
Website: www.cwcon.co.uk

EQUANS

Project
EQUANS MCC BLACKELY CEMETERY OFFICE AND YARD

Drawing Title
PROPOSED EXTERNAL MECHANICAL SERVICES

Status
TENDER

Project No.
3390

Scale / Paper Size
BW 1:100 @ A1


Drawing No.
3390-CWC-XX-ZZ-DR-M-5001

Rev
T3



- Minimum cover depth to suit traffic, loads
- Geotextile surround and clean out facility
 - Plastic geotextile units
 - 20mm or 40mm granular backfill
 - Inlet pipe
 - Catchment to remove oil and sediment
 - Sand bedding layer
 - Infiltration from sides and base
- NOTE: CHANNELS PROVIDED ACCESS TO INSULATION TUNNELS FOR INSPECTION & MAINTENANCE IF REQUIRED

REINFORCED CONCRETE PLINTH, OPEN WELD MESH FENCING AROUND ASHPs. PLINTH TO BE DESIGNED BY STRUCTURAL ENGINEER




PROPOSED BASE DETAILS

TYPICAL ASHP ABSORBOTIVE FENCING

NTS


TYPICAL CRATE DRAINAGE SOAKWAY DETAIL

NTS



BUILDERSWORK HOLE DETAIL

1:20



PROPOSED ELEVATION B

1:50

Rev	Date	Description	Eng/CHK
T3	20/12/24	UPDATED DUE TO COMMENTS	JS GR
T2	19/12/24	UPDATED DUE TO COMMENTS	JS GR
T1	25/11/24	TENDER ISSUE	JS GR

CWC
Crookes Walker Consulting
Sallya 9a, Bisc, 17 Marble Street
Manchester M2 3AW
Tel: 0161 604 9999
The Plaza, Old Hall Street,
Tel: 0151 600 5400
Email: sallya@cwcon.co.uk
Website: www.cwcon.co.uk

EQUANS

Project
EQUANS MCC BLACKELY CEMETERY OFFICE AND YARD

Drawing Title
PROPOSED EXTERNAL MECHANICAL SERVICES

Status
TENDER

Project No.
3390

Scale / Paper Size
BW 1:100 @ A1

Drawing No.
3390-CWC-XX-ZZ-DR-M-5001

Rev
T3