

Extract Grille Schedule								
	Project :	Picadilly Warehouse Bloom Street Manchester	Project No : 51050		Schedule Ref :		24006-HAK-BS-XX-SH-M-57001	
	Building:		Issue Date : 27/11/2024		Purpose of Issue :		Tender	
	H&K Office:				Revision:		P02	
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments
Lower Ground Floor								
EG2	Apt LG01 - Services Cupboard	Gilberts	GX	Air Extract Valve	200	40	14	
EG3	Apt LG01 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	70	19	
EG2	Apt LG01 - Bathroom	Gilberts	GX	Air Extract Valve	200	40	14	
EG1	Apt LG02 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt LG02 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt LG02 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt LG03 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt LG03 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt LG03 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt LG04 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt LG04 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt LG04 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt LG05 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt LG05 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt LG05 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	

Extract Grille Schedule									
	Project :	Picadilly Warehouse			Project No :	51050	Schedule Ref :	24006-HAK-BS-XX-SH-M-57001	
	Building:				Bloom Street	Issue Date :	27/11/2024	Purpose of Issue :	Tender
	H&K Office:				Manchester			Revision:	P02
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments	
Upper Ground Floor									
EG5	WC / Cleaners	Gilberts	GECA	Eggcrate Grille	200 x 200	50		Installed in Wall	
EG2	Apt UG01 - Services Cupboard	Gilberts	GX	Air Extract Valve	200	40	14		
EG3	Apt UG01 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	70	19	Air distribution plate to be dismantled, unit used for extract.	
EG2	Apt UG01 - Bathroom	Gilberts	GX	Air Extract Valve	200	40	14		
EG1	Apt UG02 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12		
EG1	Apt UG02 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17		
EG1	Apt UG02 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12		
EG1	Apt UG03 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12		
EG1	Apt UG03 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17		
EG1	Apt UG03 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12		
EG1	Apt UG04 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12		
EG1	Apt UG04 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17		
EG1	Apt UG04 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12		
EG1	Apt UG05 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12		
EG1	Apt UG05 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17		
EG1	Apt UG05 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12		

Extract Grille Schedule								
	Project :	Picadilly Warehouse	Project No :		51050	Schedule Ref :		24006-HAK-BS-XX-SH-M-57001
	Building:		Bloom Street	Issue Date :		27/11/2024	Purpose of Issue :	
	H&K Office:		Manchester			Revision:		P02
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments
First Floor								
EG2	Apt 101 - Services Cupboard	Gilberts	GX	Air Extract Valve	200	40	14	
EG3	Apt 101 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	70	19	Air distribution plate to be dismantled, unit used for extract.
EG2	Apt 101 - Bathroom	Gilberts	GX	Air Extract Valve	200	40	14	
EG1	Apt 102 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG4	Apt 102 - Kitchen / Living	Gilberts	GX	Air Extract Valve	150	25	20	
EG1	Apt 102 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 103 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG4	Apt 103 - Kitchen / Living	Gilberts	GX	Air Extract Valve	150	25	20	
EG1	Apt 103 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 104 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 104 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 104 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 105 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 105 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 105 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 106 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 106 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 106 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	

Extract Grille Schedule									
	Project :	Picadilly Warehouse		Project No :	51050		Schedule Ref :	24006-HAK-BS-XX-SH-M-57001	
	Building:			Bloom Street			Issue Date :		
	H&K Office:			Manchester			Revision:	P02	
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments	
EG1	Apt 107 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12		
EG1	Apt 107 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17		
EG1	Apt 107 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12		

Extract Grille Schedule								
	Project :	Picadilly Warehouse	Project No :		51050	Schedule Ref :		24006-HAK-BS-XX-SH-M-57001
	Building:		Bloom Street	Issue Date :		27/11/2024	Purpose of Issue :	
	H&K Office:		Manchester			Revision:	P02	
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments
Second Floor								
EG2	Apt 201 - Services Cupboard	Gilberts	GX	Air Extract Valve	200	40	14	
EG3	Apt 201 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	70	19	Air distribution plate to be dismantled, unit used for extract.
EG2	Apt 201 - Bathroom	Gilberts	GX	Air Extract Valve	200	40	14	
EG1	Apt 202 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG4	Apt 202 - Kitchen / Living	Gilberts	GX	Air Extract Valve	150	25	20	
EG1	Apt 202 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 203 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG4	Apt 203 - Kitchen / Living	Gilberts	GX	Air Extract Valve	150	25	20	
EG1	Apt 203 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 204 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 204 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 204 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 205 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 205 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 205 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 206 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 206 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 206 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	

Extract Grille Schedule									
	Project :	Picadilly Warehouse		Project No :	51050		Schedule Ref :	24006-HAK-BS-XX-SH-M-57001	
	Building:			Bloom Street			Issue Date :		
	H&K Office:			Manchester			Revision:	P02	
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments	
EG1	Apt 207 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12		
EG1	Apt 207 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17		
EG1	Apt 207 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12		

Extract Grille Schedule								
	Project :	Picadilly Warehouse	Project No :		51050	Schedule Ref :		24006-HAK-BS-XX-SH-M-57001
	Building:		Bloom Street	Issue Date :		27/11/2024	Purpose of Issue :	
	H&K Office:		Manchester			Revision:		P02
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments
Third Floor								
EG2	Apt 301 - Services Cupboard	Gilberts	GX	Air Extract Valve	200	40	14	
EG3	Apt 301 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	70	19	Air distribution plate to be dismantled, unit used for extract.
EG2	Apt 301 - Bathroom	Gilberts	GX	Air Extract Valve	200	40	14	
EG1	Apt 302 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 302 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 302 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 303 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 303 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 303 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 304 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 304 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 304 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 305 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 305 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 305 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 306 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 306 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 306 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	

Extract Grille Schedule								
		Project :	Picadilly Warehouse	Project No :		51050	Schedule Ref :	24006-HAK-BS-XX-SH-M-57001
		Building:		Issue Date :			Purpose of Issue :	
		H&K Office:					Revision:	
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments
EG1	Apt 307 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 307 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 307 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 308 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 308 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 308 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	

Extract Grille Schedule								
	Project :	Picadilly Warehouse	Project No :		51050	Schedule Ref :		24006-HAK-BS-XX-SH-M-57001
	Building:		Bloom Street	Issue Date :		27/11/2024	Purpose of Issue :	
	H&K Office:		Manchester			Revision:		P02
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments
Fourth Floor								
EG2	Apt 401 - Services Cupboard	Gilberts	GX	Air Extract Valve	200	40	14	
EG3	Apt 401 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	70	19	Air distribution plate to be dismantled, unit used for extract.
EG2	Apt 401 - Bathroom	Gilberts	GX	Air Extract Valve	200	40	14	
EG1	Apt 402 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 402 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 402 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 403 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 403 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 403 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 404 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 404 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 404 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 405 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 405 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 405 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 406 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 406 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 406 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	

Extract Grille Schedule													
		Project :	Picadilly Warehouse	Project No :		51050	Schedule Ref :		24006-HAK-BS-XX-SH-M-57001				
		Building:		Bloom Street			Issue Date :			27/11/2024	Purpose of Issue :		Tender
		H&K Office:		Manchester			Revision:				P02		
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments					
EG1	Apt 407 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12						
EG1	Apt 407 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17						
EG1	Apt 407 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12						
EG1	Apt 408 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12						
EG1	Apt 408 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17						
EG1	Apt 408 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12						

Extract Grille Schedule								
	Project :	Picadilly Warehouse	Project No :		51050	Schedule Ref :		24006-HAK-BS-XX-SH-M-57001
	Building:		Bloom Street	Issue Date :		27/11/2024	Purpose of Issue :	
	H&K Office:		Manchester			Revision:		P02
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments
Fifth Floor								
EG2	Apt 401 - Services Cupboard	Gilberts	GX	Air Extract Valve	200	40	14	
EG3	Apt 401 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	70	19	Air distribution plate to be dismantled, unit used for extract.
EG2	Apt 401 - Bathroom	Gilberts	GX	Air Extract Valve	200	40	14	
EG1	Apt 502 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 502 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 502 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 503 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 503 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 503 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 504 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 504 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 504 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 505 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 505 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 505 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 506 - Services Cupboard	Gilberts	GXD	Air Extract Valve	125	10	12	
EG1	Apt 506 - Kitchen / Living	Gilberts	GXD	Air Extract Valve	125	15	17	
EG1	Apt 506 - Bathroom	Gilberts	GXD	Air Extract Valve	125	10	12	

Extract Grille Schedule								
	Project :	Picadilly Warehouse		Project No :	51050	Schedule Ref :		24006-HAK-BS-XX-SH-M-57001
	Building:			Issue Date :		Purpose of Issue :		
	H&K Office:			Manchester			Revision:	
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments

Notes:

- 1. All colour finishes must be agreed with the client and architect prior to order. For tender purposes, the contractor shall allow for each grille to be provided in a non standard finish.
- 2. Contractor to allow for any ductwork transitions to terminal unit connections.