



HEATING NOTES

1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT PROJECT DRAWINGS AND DOCUMENTATION BEFORE COMMENCING WORK.
2. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH THE M&E SERVICES SPECIFICATION. ANY DISCREPANCIES BETWEEN THE DRAWINGS AND THE SPECIFICATION SHALL BE BROUGHT TO THE ATTENTION OF THE ENGINEER.
3. DO NOT SCALE FROM THIS DRAWING.
4. THERE SHALL BE NO CHANGES TO THE PROPOSALS WITHOUT THE AGREEMENT OF THE ENGINEER.
5. THIS DRAWING SHOULD BE READ IN COLOUR.
6. THE CONTRACTOR SHALL PROVIDE OPERATION AND MAINTENANCE MANUALS, AS FITTED DRAWINGS AND BUILDING LOG BOOK IN ACCORDANCE WITH CIBSE TM31.
7. CONTRACTOR TO CONDUCT A SITE VISIT PRIOR TO THE SUBMISSION OF A TENDER RETURN TO FAMILIARISE THEMSELVES OF THE SITE AND THE EXTENT OF WORKS REQUIRED - NO CLAIMS SHALL BE MADE FOR ADDITIONAL COSTS AS A RESULT OF THIS NOT HAVING TAKEN PLACE.
8. THIS DRAWINGS SHALL BE READ IN CONJUNCTION WITH BOTH THE ARCHITECTURAL DRAWINGS IN PARTICULAR THE HERITAGE DRAWINGS SHOWING THE POSITION OF RETAINED CAST IRON RADIATORS.
9. THE RADIATORS INDICATED ON THIS DRAWING AND REFERENCES THEREIN ARE SPECIFIC TO THIS DRAWING ONLY AND SHOULD NOT BE USED IN CONJUNCTION WITH ANY OTHER DRAWING.
10. THE MECHANICAL CONTRACTOR SHALL CONFIRM ALL RADIATOR SIZES AND FINISHES WITH THE M&E CONSULTANT AND ARCHITECT PRIOR TO ORDERING.
11. THE RADIATOR POSITIONS SHOWN ON THIS DRAWING SHOW THE DESIGN INTENT. FINAL POSITIONS SHALL BE AGREED WITH THE CLIENT.
12. CONTRACTOR TO INCLUDE FOR CO-ORDINATING HIS WORK WITH ALL OTHER TRADES IN PARTICULAR WITH THE ELECTRICAL CONTRACTOR TO ENSURE POWER SUPPLIES FOR THE HEATERS ARE PROVIDED IN THE CORRECT POSITIONS.
13. EQUIPMENT SHALL BE POSITIONED TO ENSURE MANUFACTURERS MAINTENANCE ACCESS REQUIREMENTS ARE PROVIDED.
14. THE CONTRACTOR SHALL ALLOW FOR SCHEDULING AND PROGRAMMING OF ALL THE ELECTRIC RADIATORS. SCHEDULES, TEMPS ETC. ARE TO BE CONFIRMED WITH THE CLIENT.


HEATING LEGEND

- Electric Panel Heater
- Electric Towel Rail
- EPH XX
Electric Panel Heater Reference
- ETR XX
Electric Towel Rail Reference

28/11/2024	Revised Based on Updated Arch Model	P03	MS/UR
28/06/2024	Revised to Suit Design Team Comments	P02	UR
14/06/2024	Issued for Tender	P01	UR

Date	Description	Rev.	By
------	-------------	------	----

Revision Description



Manchester Office
2 Commercial Street
Castlefield
Manchester
M15 4RQ
T: 0161 832 2030
E: hk.manchester@hulley.co.uk

hulley & kirkwood

...Making Buildings Work

Project:
Piccadilly Warehouse, Bloom Street

Drawing Title:
HEATING LAYOUT LEVEL 00

ISO 19650 Drawing Number:
24006-HAK-BS-00-DR-M-56001

Project	Originator	Functional Breakdown	Special Breakdown	Form	Discipline	ServiceNumber
---------	------------	----------------------	-------------------	------	------------	---------------

Scale: As indicated **Creation Date:** 10/06/2024
Revision: P03 **Rev Date:** 28/11/2024

Drawn By: S.Miah **Checked By:** A.Moore
Approved By: P.Metcalf

Arch Rev: 24006-HFR-BS-ZZ-M3-A-9801_P3
Struct Rev: N/A

Issue Status:
TENDER