

Supply Grille Schedule								
	Project :	Picadilly Warehouse Bloom Street Manchester	Project No :		51050	Schedule Ref :		24006-HAK-BS-XX-SH-M-57002
	Building:		Issue Date :			Purpose of Issue :		
	H&K Office:					Revision:		
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments
Lower Ground Floor								
SG3	Apt LG01 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55		
SG3	Apt LG01 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55		
SG4	Apt LG01 - Bedroom 1	Swegon	Kite F	Circular Diffuser	125	40		
SG1	Apt LG02 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt LG02 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25		
SG1	Apt LG03 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt LG03 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25		
SG1	Apt LG04 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt LG04 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25		
SG1	Apt LG05 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt LG05 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25		

Supply Grille Schedule												
	Project :	Picadilly Warehouse		Project No :		51050		Schedule Ref :	24006-HAK-BS-XX-SH-M-57002			
	Building:			Bloom Street		Issue Date :		27/11/2024		Purpose of Issue :	Tender	
	H&K Office:			Manchester						Revision:	P02	
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments				
Upper Ground Floor												
SG3	Apt UG01 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55						
SG3	Apt UG01 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55						
SG4	Apt LG01 - Bedroom 1	Swegon	Kite F	Circular Diffuser	125	40						
SG1	Apt UG02 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10						
SG1	Apt UG02 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10						
SG2	Apt UG02 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15						
SG1	Apt UG03 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10						
SG2	Apt UG03 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25						
SG1	Apt UG04 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10						
SG1	Apt UG04 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10						
SG2	Apt UG04 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15						
SG1	Apt UG05 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10						
SG2	Apt UG05 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25						

Supply Grille Schedule									
	Project :	Picadilly Warehouse	Project No : 51050		Schedule Ref : 24006-HAK-BS-XX-SH-M-57002		Purpose of Issue : Tender		
	Building:								Issue Date : 27/11/2024
	H&K Office:								
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments	
First Floor									
SG3	Apt 101 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55			
SG3	Apt 101 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55			
SG4	Apt 101 - Bedroom 1	Swegon	Kite F	Circular Diffuser	125	40			
SG1	Apt 102 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 102 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 102 - Bedroom 3	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 102 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15			
SG1	Apt 103 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 103 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 103 - Bedroom 3	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 103 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15			
SG1	Apt 104 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 104 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 104 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15			
SG1	Apt 105 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 105 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 105 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15			
SG1	Apt 106 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			

Supply Grille Schedule												
	Project :	Picadilly Warehouse		Project No :	51050		Schedule Ref :	24006-HAK-BS-XX-SH-M-57002				
	Building:			Bloom Street			Issue Date :			27/11/2024	Purpose of Issue :	Tender
	H&K Office:			Manchester							Revision:	P02
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments				
SG2	Apt 106 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25						
SG1	Apt 107 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10						
SG2	Apt 107 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25						

Supply Grille Schedule									
	Project :	Picadilly Warehouse			Project No :	51050	Schedule Ref :	24006-HAK-BS-XX-SH-M-57002	
	Building:				Bloom Street		Issue Date :		27/11/2024
	H&K Office:				Manchester				
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments	
Second Floor									
SG3	Apt 201 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55			
SG3	Apt 201 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55			
SG4	Apt 201 - Bedroom 1	Swegon	Kite F	Circular Diffuser	125	40			
SG1	Apt 202 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 202 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 202 - Bedroom 3	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 202 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15			
SG1	Apt 203 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 203 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 203 - Bedroom 3	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 203 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15			
SG1	Apt 204 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 204 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 204 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15			
SG1	Apt 205 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 205 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 105 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15			
SG1	Apt 206 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			

Supply Grille Schedule															
		Project :	Picadilly Warehouse		Project No :		51050		Schedule Ref :		24006-HAK-BS-XX-SH-M-57002				
		Building:			Bloom Street		Issue Date :		27/11/2024		Purpose of Issue :		Tender		
		H&K Office:			Manchester						Revision:		P02		
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments							
SG2	Apt 206 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25									
SG1	Apt 207 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10									
SG2	Apt 207 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25									

Supply Grille Schedule								
	Project :	Picadilly Warehouse	Project No : 51050		Schedule Ref : 24006-HAK-BS-XX-SH-M-57002		Purpose of Issue : Tender	
	Building:	Bloom Street	Issue Date : 27/11/2024		Revision: P02			
	H&K Office:	Manchester						
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments
Third Floor								
SG3	Apt 301 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55		
SG3	Apt 301 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55		
SG4	Apt 301 - Bedroom 1	Swegon	Kite F	Circular Diffuser	125	40		
SG1	Apt 302 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt 302 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25		
SG1	Apt 303 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt 303 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25		
SG1	Apt 304 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG1	Apt 304 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt 304 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15		
SG1	Apt 305 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG1	Apt 305 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt 305 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15		
SG1	Apt 306 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG1	Apt 306 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt 306 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15		
SG1	Apt 307 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt 307 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25		

Supply Grille Schedule												
	Project :		Picadilly Warehouse		Project No :		51050		Schedule Ref :		24006-HAK-BS-XX-SH-M-57002	
	Building:				Issue Date :				Purpose of Issue :			
	H&K Office:								Revision:			
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments				
SG1	Apt 308 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10						
SG2	Apt 308 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25						

Supply Grille Schedule									
	Project :	Picadilly Warehouse	Project No : 51050		Schedule Ref : 24006-HAK-BS-XX-SH-M-57002		Purpose of Issue : Tender		
	Building:								Issue Date : 27/11/2024
	H&K Office:								
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments	
Fourth Floor									
SG3	Apt 401 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55			
SG3	Apt 401 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55			
SG4	Apt 401 - Bedroom 1	Swegon	Kite F	Circular Diffuser	125	40			
SG1	Apt 402 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 402 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25			
SG1	Apt 403 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 403 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25			
SG1	Apt 404 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 404 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 404 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15			
SG1	Apt 405 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 405 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 405 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15			
SG1	Apt 406 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG1	Apt 406 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 406 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15			
SG1	Apt 407 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10			
SG2	Apt 407 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25			

Supply Grille Schedule															
		Project :	Picadilly Warehouse		Project No :		51050		Schedule Ref :		24006-HAK-BS-XX-SH-M-57002				
		Building:			Bloom Street		Issue Date :		27/11/2024		Purpose of Issue :		Tender		
		H&K Office:			Manchester						Revision:		P02		
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments							
SG1	Apt 408 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10									
SG2	Apt 408 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	25									

Supply Grille Schedule								
	Project :	Picadilly Warehouse	Project No : 51050		Schedule Ref : 24006-HAK-BS-XX-SH-M-57002		Purpose of Issue : Tender	
	Building:	Bloom Street	Issue Date : 27/11/2024		Revision: P02			
	H&K Office:	Manchester						
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments
Fifth Floor								
SG3	Apt 401 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55		
SG3	Apt 401 - Kitchen / Living	Swegon	Kite F	Circular Diffuser	160	55		
SG4	Apt 401 - Bedroom 1	Swegon	Kite F	Circular Diffuser	125	40		
SG1	Apt 502 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG1	Apt 502 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt 502 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15		
SG1	Apt 503 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG1	Apt 503 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt 503 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15		
SG1	Apt 504 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG1	Apt 504 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt 504 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15		
SG1	Apt 505 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG1	Apt 505 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt 505 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15		
SG1	Apt 506 - Bedroom 1	Gilberts	SX	Air Supply Valve	100	10		
SG1	Apt 506 - Bedroom 2	Gilberts	SX	Air Supply Valve	100	10		
SG2	Apt 506 - Kitchen / Living	Gilberts	SX	Air Supply Valve	125	15		

Supply Grille Schedule								
	Project :	Picadilly Warehouse		Project No :	51050		Schedule Ref :	24006-HAK-BS-XX-SH-M-57002
	Building:			Issue Date :			Purpose of Issue :	
	H&K Office:			Manchester			27/11/2024	
Ref	Location	Manufacturer	Model	Type	Size (mm)	Duty (l/s)	Pressure Loss (Pa)	Comments

Notes:

- 1. All colour finishes must be agreed with the client and architect prior to order. For tender purposes, the contractor shall allow for each grille to be provided in a non standard finish.
- 2. Contractor to allow for any ductwork transitions to terminal unit connections.