

Callum Inkster

From: Jon Sharp <Jon.Sharp@casey.co.uk>
Sent: 22 November 2024 15:34
To: Callum Inkster
Cc: 'Simon Brady'
Subject: [External Email] FW: Pre Development Enquiry for: Benchill The Enterprise Centre UU Reference Number : 03493256

ATTENTION: This is an External message to Michael Dyson Associates
Do not open attachments or click on links unless you recognise the sender and know the content is safe.

Callum,

Please see below from UU regarding the predevelopment advice.

Can you forward on to Planning for discharge.

Regards,
Jon



Improving Lives

Jon Sharp MCIOB
Contracts Manager

| |
M: 07764 600 903 | **E:** Jon.Sharp@casey.co.uk

 Chat with me on Teams

   

Casey Group is a company registered in England and Wales under number 4233269. Registered office: , United Kingdom.
Please note that The Casey Group Ltd may monitor email traffic and also the content of email for the purposes of security and staff training.

This message contains confidential information and is intended only for the intended recipients. If you are not an intended recipient you should not disseminate, distribute or copy this e-mail. Please notify the sender immediately by e-mail if you have received this e-mail by mistake and delete this e-mail from your system. E-mail transmission cannot be guaranteed to be secure or error-free as information could be intercepted, corrupted, lost, destroyed, arrive late or incomplete, or contain viruses. The sender therefore does not accept liability for any errors or omissions in the contents of this message, which arise as a result of e-mail transmission. If verification is required please request a hard-copy version immediately by e-mail if you have received this e-mail by mistake and delete this e-mail from your system.

From: seweradoptions@uuplc.co.uk <seweradoptions@uuplc.co.uk>
Sent: 22 November 2024 15:31
To: simon.brady@sutcliffe.co.uk
Cc: Jon Sharp <Jon.Sharp@casey.co.uk>
Subject: Pre Development Enquiry for: Benchill The Enterprise Centre UU Reference Number : 03493256

Good afternoon Simon,

I hope you are well.

I am happy to extend the below pre development response for a further 12 months.

If this email isn't sufficient please let me know and I will happily re issue the pre development advice.

Kind regards



Ashleigh Bellerby
Developer Engineer
Developer Services & Metering
Customer Services
T: 01925 429042
unitedutilities.com

If you feel I have given you a great service, I would greatly appreciate if you could take the time to give me some feedback <http://unitedutilities.thewowawards.co.uk/nominate>

----- Original Message -----

From: seweradoptions@uuplc.co.uk [seweradoptions@uuplc.co.uk]
Sent: 18/11/2024 10:20
To: simon.brady@sutcliffe.co.uk
Cc: jon.sharp@casey.co.uk
Subject: RE: Pre Development Enquiry for: Benchill The Enterprise Centre UU Reference Number : 03493256

Good morning Simon,

Thank you for your email.

I have asked Ashleigh to review and respond before the 2nd December.

Regards

Samantha
0345 026 8989 - Option 4

----- Original Message -----

From: Simon Brady [simon.brady@sutcliffe.co.uk]
Sent: 18/11/2024 10:09
To: seweradoptions@uuplc.co.uk
Cc: jon.sharp@casey.co.uk
Subject: RE: Pre Development Enquiry for: Benchill The Enterprise Centre UU Reference Number : 03493256

Hi Ashleigh,

Are you able to confirm the below advice?

We made the pre-development enquiry to support the design for the planning application, planning was granted based on the surface water strategy based on below advice. Unfortunately, 12-months elapsed between the initial enquiry and commencement on site (and discharge of conditions) so the LPA have flagged that the pre-development enquiry is more that 12-months old.

I would be grateful if you can confirm the below.

Regards

Simon Brady
Executive Associate

SUTCLIFFE

18-20 Harrington Street, Liverpool, L2 9QA

t: 0151 227 3155

dd: 0151 305 5438
e: simon.brady@sutcliffe.co.uk
w: www.sutcliffe.co.uk



Sutcliffe
Inspiring and influencing the built environment since 1985

Structural & Civil Engineering
Geotechnical & Environmental Investigations
Building Surveying
Pre Planning Services

Head Office:
18-20 Harrington Street, Liverpool, L2 9QA
Tel: 0151 227 3155

Manchester Office: 0161 817 5180
North Wales Office: 01978 664 071
London Office: 020 8016 4320



Cert: 1122





Sutcliffe Projects is a Limited Company registered in England and Wales No 4287238

From: seweradoptions@uuplc.co.uk <seweradoptions@uuplc.co.uk>
Sent: 01 February 2023 09:31
To: simon.brady@sutcliffe.co.uk
Subject: Pre Development Enquiry for: Benchill The Enterprise Centre UU Reference Number : 03493256

Good morning Simon,

Pre Development Enquiry for: Benchill The Enterprise Centre UU Reference Number : 03493256

We have carried out an assessment of your application which is based on the information provided. This pre-development advice on your drainage strategy will be valid for 12 months. Your drainage strategy will need to be reviewed by other competent authorities as part of the planning process, and we advise that you carry out the necessary site investigations to confirm the viability of your proposals.

If your investigations require access to our public sewer network, we ask that you contact our network engineers with a request for an access certificate via our main contact telephone number 0345 6723 723 or refer to the link below:

<https://www.unitedutilities.com/builders-developers/working-near-our-assets/>

Foul Water

Foul flow from this site will be allowed to drain into the public foul water/combined sewer system.

Our preferred point of discharge would be to the 225mm diameter public combined sewer within Rothley Avenue located to the North of your proposed development at an unrestricted rate.

If you are able to identify an alternative, more suitable point of discharge, we request that you contact us at your earliest convenience so that we can assess suitability.

In accordance with our infrastructure plans we may ask you to change your point of connection. Therefore please contact us when you are ready to formalise your drainage proposals, we would suggest before you submit for Full Planning.

Surface Water

All surface water flow from the proposed development should drain in-line with the drainage hierarchy, as outlined in Paragraph 80, (Reference ID: 7-080-20150323), of the National Planning Practice Guidance. We also recommend you prioritise the use of multi-functional sustainable drainage systems for the management of surface water in accordance with national planning policy.

Generally, the aim should be to discharge surface run off as high up the following hierarchy of drainage options as reasonably practicable.

This is outlined as follows, in order of priority:

1. **into the ground (infiltration);**
2. **to a surface waterbody;**
3. **to a surface water sewer or highway drain;**
4. **to a combined sewer.**

For guidance, The [North West SuDS Pro-Forma](#) provides information on the appropriate evidence required at each stage of the hierarchy, to demonstrate how each level has been discounted.

The Lead Local Flood Authority has responsibility for all surface water drainage concerns and their input to your proposal is critical. You should also consider whether it is necessary to discuss your proposal with the Environment Agency, or Internal Drainage Board (if operating in your area).

The Local Planning Authority are the determining authority for any application for planning permission and the appropriate authority for determining cost viability of a proposed drainage scheme, such assessments are outside of the jurisdiction of United Utilities.

Infiltration

Surface water runoff generated from this development should discharge to the ground via infiltration system where feasible.

A detailed evidence based feasibility assessment must be carried out in line with Chapter 25 of the CIRIA SuDS Manual 2015 to determine whether infiltration is a suitable method of surface water disposal.

Particular attention must be paid to Ground Water Source Protection Zones to ensure that the risk of pollution to these valuable resources is not compromised. Details can be obtained from the government website:

<https://www.gov.uk/guidance/groundwater-source-protection-zones-spzs#find-groundwater-spzs>

If your site is in a Groundwater Source Protection Zone, you should have regard to the Environment Agency's approach to Groundwater Protection. Information on this is available via the link below:

<https://www.gov.uk/government/publications/groundwater-protection-position-statements>

Please note that such a location could have implications for the principle of your development and the need for additional mitigating measures to protect the groundwater environment and public water supply in the detailed design of your site.

Highway Drainage

If an evidence based assessment has been carried out and confirms that infiltration is not feasible, we recommend that you investigate the possibility of draining surface water to the highway drain where this ultimately discharges to a watercourse, by contacting the relevant Highway Authority.

Public Sewer

In accordance with the hierarchy of drainage options within the National Planning Practice Guidance, both discharge to ground via infiltration and discharge to a waterbody should be discounted prior to consideration of discharging surface water to the public sewer system. Evidence should be provided to demonstrate how these have been discounted, as outlined in the North West SuDS pro-forma.

Once evidence is provided as outlined above, United Utilities will consider a connection to the 225mm diameter public combined sewer within Rothley Avenue located North of the proposed site at a pass forward flow to be agreed by the Lead Local Flood Authority. United Utilities request that any agreed rate does not exceed 5l/s. This is in line with HR Wallingford soil type 5. I am happy to review the discharge rate once you have submitted evidence of existing flow rates.

As a Water Company, we have no obligation to accept highway drainage into our public sewer network. However, should your proposals include runoff from highways, we would request that consideration is given to SuDS components that deliver source control are incorporated within the design of the scheme to reduce the volume and frequency of discharges of these flows to the public sewer.

Levels

For low-lying sites, (where the ground level of the site or the level of a basement is below the ground level at the point where the drainage connects to the public sewer), care should be taken to ensure that the property is not at increased risk of flooding. If these circumstances exist, we recommend that you contact us to discuss further. It could affect the detailed design of your site and result in the need to incorporate appropriate mitigating measures in your drainage scheme.

Land drainage / Overland flows / track drainage

United Utilities have no obligation, and furthermore we do not accept land drainage, overland flows or track drainage into the pubic sewerage network under any circumstances

Existing Wastewater Assets Crossing the Site

We have reviewed our records and can confirm that there does not appear to be any charted public sewers located within the boundary of proposed development. However, due to the accuracy of the records and the public sewer transfer legislation in 2011, not all public sewers are shown on our records so we would ask that you proceed with caution and carry out your own site investigation works. If any uncharted sewers are identified while carrying out your works we would ask that you contact United Utilities at the earliest opportunity so that we can offer guidance and update our records.

Existing Water Assets Crossing the Site

It is the developer responsibility to identify utilities on-site. Where clean water assets are shown on our records, we recommend that you contact our Water Pre-Development Team, via the following email address: DeveloperServicesWater@uuplc.co.uk. Further information for this service can be found on our website via the link below:

<https://www.unitedutilities.com/builders-developers/larger-developments/pre-development/water-pre-dev/>

Connection Application

Although we may discuss and agree discharge points and rates in principle, please be aware that you will have to apply for a formal sewer connection. This is so that we can assess the method of construction, Health & Safety requirements and to ultimately inspect the connection when it is made. Details of the application process and the form itself can be obtained from our website by following the link below:

<https://www.unitedutilities.com/builders-developers/wastewater-services/sewer-connections/sewer-connection/>

We recommend that the detailed design should confirm the locations of all utilities in the area and ensure that any proposed drainage solution considers routing and clash checks where required.
If we can be of any further assistance please don't hesitate to contact us further.

Many thanks and kind regards,



Ashleigh Bellerby
Assistant Developer Engineer
Developer Services & Metering
Customer Services
T: 07826891650
[unitedutilities.com](https://www.unitedutilities.com)

If you have received a great service today why not tell us?
Visit: [unitedutilities.com/wow](https://www.unitedutilities.com/wow)

----- Original Message -----
From: seweradoptions@uuplc.co.uk [seweradoptions@uuplc.co.uk]
Sent: 19/01/2023 14:04
To: simon.brady@sutcliffe.co.uk
Subject:

Good Afternoon,

PRE DEVELOPMENT APPLICATION AT: Benchill The Enterprise Centre – UU Ref 03493256

Please accept this email as receipt of your application received on 18/01/2023 for the above development. This has now been logged on our system and the job reference is 03493256 we would ask that you quote this reference in all future correspondence.

I have reviewed your application (and attachments) and can confirm this is suitable to be passed to Ashleigh for technical assessment. You will receive their response within 8 working days.

Kind Regards,



Tonicha Wilde
Customer Advisor Advanced
Developer Services & Metering
Customer Services
Direct Tel: N/A
Tel: 0345 026 8989 (option 4)
unitedutilities.com

If you have received a great service today why not tell us?

Visit: [unitedutilities.com/wow](https://www.unitedutilities.com/wow)

Did you know we now have a live chat facility available to you Mon to Friday 8 -5pm. You just click on the orange live chat box on our webpage and one of our advisors will be ready to chat to you and help you with your enquiry <https://www.unitedutilities.com/builders-developers/> or you can email us at WastewaterDeveloperServices@uuplc.co.uk



The information contained in this e-mail is intended only for the individual to whom it is addressed. It may contain legally privileged or confidential information or otherwise be exempt from disclosure. If you have received this Message in error or there are any problems, please notify the sender immediately and delete the message from your computer. You must not use, disclose, copy or alter this message for any unauthorised purpose. Neither United Utilities Group PLC nor any of its subsidiaries will be liable for any direct, special, indirect or consequential damages as a result of any virus being passed on, or arising from the alteration of the contents of this message by a third party.

United Utilities Group PLC, Haweswater House, Lingley Mere
Business Park, Lingley Green Avenue, Great Sankey,

Warrington, WA5 3LP
Registered in England and Wales. Registered No 6559020

www.unitedutilities.com
www.unitedutilities.com/subsidiaries

