

FILENAME	ORIGINATOR	DESCRIPTION	REV	DATE REC'D
240222_138.02.101	M PINEY ASSOC	FIRST FLOOR	-	12.04.2024

1. ANY DUCT PASSING THROUGH A FIRE BARRIER SHALL BE FITTED WITH A FIRE DAMPER OR FIRE & SMOKE DAMPER, COMMENSURATE WITH THE REQUIREMENT OF FIRE STRATEGY.

1. ANY CDT PASSING THROUGH A FIRE BARRIER SHALL BE FITTED WITH A FIRE DAMPER OR FIRE & SMOKE DAMPER, COMENSURATE WITH THE REQUIREMENT OF FIRE STATES).
2. FINAL DUCTWORK COORDINATION ON SITE TO BE UNDERTAKEN BY THE INSTALLATION CONTRACTOR
3. ALL SUPPLY DUCTWORK AND DUCTWORK TO EXTERNAL SHALL BE INSULATED IN ACCORDANCE WITH THE DESIGNATION. EXISTING SHALL HAVE COP AND GWP OF LESS THAN 5.
4. ACCESS HATCHES SHALL BE PROVIDED TO ALLOW INSPECTION AND ACCESS FOR INTERNAL CLEANING AND ACCESS TO FIRE DAMPERS
5. ALL DUCTWORK SHALL BE CLEANED PRIOR TO COMMISSIONING IN ACCORDANCE WITH D1444 AND TR19/19.
6. DRAWING TO BE READ IN CONJUNCTION WITH FHP SPECIFICATION.
7. FOR PLANT SCHEDULES: PLEASE REFER TO DRAWING NUMBER 44759-A-500-A-X-003
8. CDT DISTRIBUTION ROUTES ARE TO BE CONFIRMED FROM THE STRUCTURAL ENGINEER'S FININGS.
9. FOUs TO BE CONNECTED WITH DAKIN DISCREET BUTION TYPE ROOM MOUNTED TEMPERATURE SENSOR TO BE COORDINATED WITH THE ARCHITECT'S REQUIREMENTS
10. FINAL LOCATION OF CONTROLS TO BE IN THE DISCREET OF THE ARCHITECT, NOT VISIBLE FROM ANY FLOOR AREAS.
11. 1ST FLOOR: WHEN SUPPLY AND EXTRACT VENTILATION IS REQUIRED, THE EXTRACT SHALL BE BY THE KITCHEN FURNITURE'S SPECIALIST.

CC01	12.07.24	CAD	CONSTRUCTION ISSUE
Rev	Date	Drm	Description

Client
WATCHES OF SWITZERLAND GROUP

Architect
JOHNSON PINNEY ARCHITECT

Project
AP WATCHES
KINGS STREET, MANCHESTER



London, Bexley, Birmingham, Glasgow, Leeds, Manchester, Waltham Abbey
0808 175 1000 drawings@fipess.com www.fipess.com

Drawing Title

MECHANICAL SERVICES
HEATING, COOLING & VENTILATION LAYOUT
FIRST FLOOR

Scale	1:50@A1	Drawn	AutoCAD/
Date	MAR '24	Checked	D.H

Status

CONSTRUCTION

Project number/Drawing number	Revision
44758-M-500-01-100	C01

