

TYPE 1 -NBS K10-110
FULL HEIGHT PARTITION
WALL FIRE RATED UPTO
FR30/30-
TWO LAYERS OF 12.5
WALLBOARD EACH SIDE OF
70MM C STUDS, NEW
SKIRTING TO MATCH
EXISTING PROFILE, GYPSUM
PLASTER SKIM AND
BREATHABLE EMULSION
PAINT AS M60/110

TYPE 2 -NBS K10-111
INDEPENDANT TANKED [DESIGN BY
OTHERS] WALL LINING WITH NBS
P10-217 110mm FOAMGLAS T3+
INSULATION FIXED TO WALL WITH
FOAMGLAS F ANCHOR
2NO. LAYERS OF 12.5 WALLBOARD
TO 70MM I STUDS, NEW SKIRTING
TO MATCH EXISTING PROFILE
GYPSUM PLASTER SKIM AND
BREATHABLE EMULSION PAINT AS
M60/110

TYPE 3 -NBS K10-112
INDEPENDANT WALL LINING
2NO. LAYERS OF 12.5 WALLBOARD
TO 50MM I STUDS, NEW SKIRTING
TO MATCH EXISTING PROFILE
GYPSUM PLASTER SKIM AND
BREATHABLE EMULSION PAINT AS
M60/110

TYPE 4 -NBS K10-113
OMITTED


TYPE 5 -NBS K10-114
SHAFTWALL, 2 x 12.5MM FIRELINE
WITH 19MM COREBOARD, PLASTER
SKIM AND PAINT, NEW PAINTED
SKIRTING

TYPE 6
OMITTED

B
B

Note:
Do Not Scale from this drawing.
Dimensions are to be checked on site.
If in doubt please ask.

KEY PLAN



GENERAL NOTES:

All construction shall be undertaken and completed in strict accordance with all drawings, specifications, statutory Building and Planning regulations, Health and Safety regulations, all relevant codes of practice requirements and manufacturers' recommendations and instructions.

Any discrepancies in constructional information should be reported immediately to the contract administrator prior to commencement of any work.

- For references and descriptions to work items, refer to separate Phase 1 NBS 'Architectural Restoration Specification and Phase 2 Conservation Specification'.
- All dimensions must be checked on site before proceeding. Dimensions of new work are to be adjusted to suit the existing where necessary. Do not assume that the existing structure or details are plumb, square or level. Any discrepancies to be brought to the Architects attention as soon as possible.
- Plan is based on survey information provided by MAG, corrected as far as reasonably possible to align with pointcloud survey data. All measurements to be checked on site.
- The waterproofing guarantee provided for the cavity drain membrane is for hydrostatic ground water pressures under normal site conditions and does not cover surface water flooding events.
- The 10 year waterproofing guarantee protects against water penetration to the treated area only, therefore does not cover water penetration through the floor area.
- Waterproofing works to specialist suppliers design. Waterproofing information is DESIGN INTENT ONLY- refer to specialist designer for further details.
- The following drawings are to be read in conjunction:
MAG-BUT-08-B2-DR-A-00-1001 - Alterations plan
MAG-BUT-08-B2-DR-A-05-0001 - 5 - Internal elevations
MAG-BUT-08-B2-DR-A-00-6001 - Section details
MAG-BUT-08-B2-DR-A-06-6002 - GA Section
MAG-BUT-08-B2-DR-A-22-0001 - Wall Types Plan
MAG-BUT-08-B2-DR-A-22-0002 - Wall Lining Details
MAG-BUT-08-B2-DR-A-23-0001 & 2 - Floor Repairs
MAG-BUT-08-B2-DR-A-23-0003 - Floor Details
MAG-BUT-08-B2-DR-A-23-0004 - Vent Details
MAG-BUT-08-B2-DR-A-31-0001 - Window proposals
MAG-BUT-08-B2-DR-A-32-7001 - Door elevations and schedule
MAG-BUT-08-B2-DR-A-32-7002 - Door details
MAG-BUT-08-B2-DR-A-35-4002 - Reflected Ceiling Plan
MAG-BUT-08-B2-DR-A-35-4003 - Ceiling details
MAG-BUT-08-B2-DR-A-40-0001 - Finishes plan

To be read in conjunction with the associated structural and MEP documentation for Work Package 8

P06	29/11/24	HB	Stage 4 for acceptance - Revised Floor Design
CD1	20/06/24	HB	For Construction
P05	05/06/24	HB	Stage 4 for acceptance
P04	17/05/24	HB	Stage 4 for acceptance
P03	07/05/24	HB	Stage 4 for acceptance
P02	19/04/24	HB	Stage 4 for acceptance
P01	28/03/24	CH	First Issue

Rev Date Intis Details

© The moral rights of the author are hereby asserted.
This drawing and design is the sole property of Buttress Ltd and must not be reproduced without permission.
Buttress Ltd is Registered in England and Wales: 336373



Buttress

Manchester Leeds

41 Bengal Street
Manchester
M4 6AF
0161 236 3303
www.buttress.net

Clockwise, Yorkshire House
Greek Street, Leeds
LS1 5SH
0113 539 7965

Certified

Corporation

Project Title Manchester Art Gallery
Client Manchester City Council
Location Mosley St, Manchester M2 3JL

Drawing ref Wall Types Plan

Date 29/11/2024 16:48:18 **Scale** As indicated

Checker **Size** A1

Job No: 9604 **Status** Preliminary

Project	Origin	Volume	Level	Type	Role	Number	Rev
---------	--------	--------	-------	------	------	--------	-----

MAG-BUT-08-B2-DR-A-22-0001-P06

1

Basement Partition and Tanking Plan

1 : 50