

[illegible]

2. ALL WIRE BASKET IS DEEMED TO BE 54mm RETURN ZINC STEEL TYPE UNLESS OTHERWISE DETAILED.

CONTAINMENT LAYOUT TO BE REVIEWED AND POSSIBLY REVISED FOLLOWING RECEIPT OF FIRE ALARM, SECURITY, P/Vs, ACCESS CONTROL DESIGN INFORMATION AND DRAWINGS BY THE SPECIALIST.

2. HORIZONTAL CABLING RUNS OF MORE THAN 35m NO SEPARATION IS REQUIRED FOR THE FINAL 15m.

NEW LANDLORDS DISTRIBUTION BOARD DB-12/LL/R2
NEW 2 x 300mm CABLE BASKET FROM BASEMENT COMMS CABINET LOCATION FOR NEW TENANT FIBRE BACKBONE AND STRUCTURED WIRING INSTALLATION

12.C1 NORTH LIFT CORE

150mm LOW LEVEL PERIMETER TRUNKING

2 NO. NEW TENANT'S DISTRIBUTION BOARDS - DB-12/T2/R2 & DB-12/T3/R2 RESPECTIVELY.

EXISTING 800A TENANTS RISING BUSBAR AND MAIN ISOLATOR UNIT. 2NO. NEW 125A TAP-OFF UNITS.

100mm TENANT'S TRAY RISE TO FLOOR ABOVE FOR CONDENSOR UNIT SUPPLY CABLES ON ROOF

12.01 WORKSPACE

TREET

REV	DATE	AMENDMENTS	BY	CKD
-----	------	------------	----	-----

Commercial Services Design Ltd
Unit 5
Woodside Court
Clayton Wood Rise
Leeds
LS16 6RF
Tel: 0113 3223190
Web: www.csdesign.uk.com

CLIENT
G&H BUILDING SERVICES

SUNLIGHT HOUSE
LITTLE QUAY STREET
MANCHESTER M3 3HP

**ELECTRICAL SERVICES CONTAINMENT
LAYOUT
LEVEL 12**

SCALE @ AC: 1:100	CSD REF: CSD 1298
DRAWN: MW	ENGINEER: OI
STARTED: JUNE 24	ISSUED: JULY 24
CHECKED: DB	APPROVED: BW

ARCHITECTURE IS BASED ON ANOMALY DESIGN ARCHITECTS
DRAWING NO. SLH-ANO-PO-12-DR-A-05122 (C01)
LEVEL 12 PLAN
RECEIVED 03.06.2024

This drawing is the property of Commercial Services Design Ltd. Copyright is reserved by them and is loaned on the condition that it is not copied either wholly or in part without consent in writing of Commercial Services Design Ltd. Plotted dimensions 1/16th preference over those noted. All dimensions 1/16th checked on site before commencement of any work. This drawing is to be used in conjunction with the specification and/or existing and/or other documents.