

Plan ref: 131318 (CDN/24/0756) condition 8

Lisa Jones <lisa.jones3@manchester.gov.uk>

Wed 11/09/2024 12:19

To: Lucy Harrison <lucy.harrison@manchester.gov.uk>

Hi Lucy,

The information submitted is insufficient to discharge the condition. The document submitted is a H&S document and not environmental. The CMP must address the hours of work for the site and the following:

- Measures to control noise and vibration;
- Dust suppression measures;
- Compound locations where relevant;
- Details of an emergency contact telephone number;
- A community consultation plan; and
- Sheeting of construction vehicles.

Ki

Kind regards

Lisa Jones
Environmental Protection Officer
Environmental Protection
Environmental Health
The Neighbourhoods Directorate
Manchester City Council

email: lisa.jones3@manchester.gov.uk

website: www.manchester.gov.uk

Tel: 0161 234 5004

Internal: 31372

We are now on Twitter, for latest news and updates follow us [@EnvHealthMcr](#)

This email and any files transmitted with it are confidential and intended solely for the use of the individual or entity to whom they are addressed.
If you have received this email in error, please notify the sender, or dpo@manchester.gov.uk, and then permanently delete the email, attachments and all copies.
The full text of the Council's email disclaimer is available at: www.manchester.gov.uk/emaildisclaimer.
Your personal data is very important to us. Please refer to our privacy notice at: www.manchester.gov.uk/privacy for further information.

This footnote also confirms that this email message has been swept for the presence of computer viruses.
