

Application details:	Application number: 140962/FO/2024 Proposal: Erection of two no. 2 bed two storey dwellings with rear dormers following demolition of existing dwelling including landscaping and car parking Location: 14 Wilton Road, Manchester, M8 4WQ.
-----------------------------	--

LLFA Comments 11/11/2024

The following Information has been considered:

Planning Portal uploads:	09/09/2024 - 23/10/2024
Further submission emails:	NA
Pre-Application Advice:	NA

Condition: Prior to the commencement of the development hereby approved, a surface water drainage layout for the development site shall be submitted for approval in writing by the City Council, as Local Planning Authority. This shall include the following:

- Evidence of drainage hierarchy adherence.
- Finalised surface water drainage layout including all components, levels and connectivity.
- Evidence of connection approval in principle.
- Maintenance and management plan.

The development shall be constructed and completed in accordance with the approved details prior to the first occupation/use of the development.

Reason: To prevent the increased risk of flooding, to improve and protect water quality and ensure future maintenance of the surface water drainage system pursuant to policy EN14 & EN17 of the Core Strategy.