



THIS DRAWING IS FOR INFORMATION ONLY DO NOT SCALE			
CDM REGULATIONS			
HAZARDS	DATE CHECKED	DATE UPDATED	RISK ASSESSMENT DATE
<p><u>VENTILATION NOTES:</u></p> <p>1. THIS DRAWING IS CONFIDENTIAL AND MAY NOT BE USED, COPIED OR DISCLOSED TO ANYONE WITHOUT PERMISSION OF CSD LTD</p> <p>2. DRAWINGS TO BE READ IN CONJUNCTION WITH THE TECHNICAL SPECIFICATION</p> <p>3. DO NOT SCALE FROM THIS DRAWING</p> <p>4. ALL DIMS ARE $\pm 10\text{mm}$ UNLESS INDICATED OTHERWISE</p> <p>5. SITE VERIFY ALL DIMENSIONS PRIOR TO CONSTRUCTION</p> <p>6. REPORT ALL DISCREPANCIES TO THE DRAWING ORIGINATOR IMMEDIATELY</p> <p>7. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT DOCUMENTS, DRAWINGS AND SCHEMATICS</p> <p>8. ALL LEVELS TO BE TAKEN FROM DATUM</p> <p>9. FIRE DAMPERS AND FIRE-RESISTIVE BARRIERS INSTALLED AS PER MANUFACTURERS RECOMMENDED INSTALLATION INSTRUCTIONS, INCLUDING FRAME WORK</p> <p>10. TURNING VANES TO BE INCLUDED IN ALL BENDS IN RECTANGULAR DUCTWORK</p> <p>11. DUCTWORK TO BE INSTALLED IN ACCORDANCE WITH THE GUIDELINES FOR CLASS C DUCTWORK SET OUT IN HW144 SPECIFICATION FOR STEEL METAL DUCTWORK</p> <p>12. ACUSTIC FLEXIBLE DUCTWORK AT T-JUNCTIONS CONNECTIONS TO OTHERS/ DIFFUSERS SHALL NOT EXCEED 500mm</p> <p>13. ACCESS & CLEANING DOORS TO BE FITTED IN DUCTWORK IN ACCORDANCE WITH HW144TR19</p> <p>14. DUCTWORK IN GALVANISED SHEET METAL UNLESS STATED OTHERWISE. INTERNAL SUPPLY DUCTWORK IN ACCORDANCE WITH HW144 CLASS A AIR LEAKAGE. INTERNAL EXTRACT DUCTWORK IN ACCORDANCE WITH HW144 CLASS A AIR LEAKAGE. EXTERNAL DUCTWORK TO CLASS A AIR LEAKAGE</p> <p>15. DUCTWORK PASSING THROUGH FIRE RATED STRUCTURE FORMING FIRE BARRIERS & COMPARTMENTS SHALL BE PROVIDED WITH FIRE DAMPERS SCALE TO THE RATING OF THE ELEMENT /COMPARTMENT. FIRE DAMPERS TO BE OF THE FOLLOWING CLASS TYPE WITH THE FOLLOWING CLASS OF THE AIR STREAM TO PROVIDE MAXIMUM FIRE AREA IN THE AIRWAY</p> <p>16. ALL GULFLEX PENETRATORS TO BE INSTALLED BY DUCTWORK SPECIALIST INCLUDING AIRLOCKS, JUNCTIONS</p>			

**FOR COMMENT
& APPROVAL**

**FOR COMMENT
& APPROVAL**



1298-CSD-XX-07-DR-M-5708 P02

ARCHITECTURE IS BASED ON ANOMALY DESIGN
ARCHITECTS DRAWING NO. SLH-ANO-PO-07-DR-A-0510
(001) LEVEL 07 PLAN
RECEIVED 05.06.2024