



1. VENTILATION NOTES:
2. THIS DRAWING IS CONFIDENTIAL AND MAY NOT BE USED, COPIED OR DISCLOSED TO ANYONE WITHOUT PERMISSION OF CS&S.
3. DRAWINGS TO BE READ IN CONJUNCTION WITH THE TECHNICAL SPECIFICATION
4. DO NOT SCALE FROM THIS DRAWING.
5. ALL DIMS ARE UNLESS OTHERWISE INDICATED OTHERWISE.
6. SITE VERIFY ALL DIMENSIONS PRIOR TO CONSTRUCTION.
7. REPORT ALL DISCREPANCIES TO THE DRAWING ORIGINATOR IMMEDIATELY.
8. THIS DRAWING IS TO BE READ IN CONJUNCTION WITH ALL RELEVANT DOCUMENTS, DRAWINGS AND SCHEMATICS
9. ALL LEVELS TO BE TAKEN FROM DATUM
10. FIRE BREAKS AND FIRE BREAKMATS INSTALLED AS PER MANUFACTURERS RECOMMENDED INSTALLATION
11. TURNING VANES TO BE EXCLUDED N/A BENDS IN RECTANGULAR DUCTWORK.
12. DUCTWORK TO BE INSTALLED IN ACCORDANCE WITH THE GUIDELINES FOR CLASS C DUCTWORK SET OUT IN DM144 SPECIFICATION FOR SHEET METAL DUCTWORK.
13. ACQUISITVE LEAKAGE SHALL AT FINAL CONNECTIONS TO GRILLES / DIFFUSERS SHALL NOT EXCEED 50MM.
14. ACCESS & CLEANING DOORS TO BE FITTED IN DUCTWORK IN ACCORDANCE WITH DM144TR19
15. DUCTWORK IN GALVANIZED SHEET METAL UNLESS STATED OTHERWISE. SUPPLY DUCTWORK IN ACCORDANCE WITH DM144 CLASS A AIR LEAKAGE. INTERNAL, EXTRACT DUCTWORK IN ACCORDANCE WITH DM144 CLASS A AIR LEAKAGE. EXTERNAL DUCTWORK TO CLASS A AIR LEAKAGE.
16. DUCTWORK PASSING THROUGH FIRE RATED STRUCTURE TO BE PROVIDED WITH FIRE DAMPERS CLASS A TO THE RATING OF THE ELEMENT / COMPARTMENT. FIRE DAMPERS TO BE OF THE LEAKAGE TYPE. EXTERNAL DUCTWORK TO BE OF THE AIR STREAM TO PROVIDE MAXIMUM FLOW AREA IN THE AIRWAY.
17. ALL GALVANIZED PLENUM BODIES TO BE INSTALLED BY DUCTWORK SUB-CONTRACTOR (INCLUDING ACQUISITIVE LEAKING)

P02	29.06.24	BOH TOILET VENTILATION TERMINATES TO EXTERNAL RISER	DB	SH
P01	25.06.24	ISSUED FOR COMMENT & APPROVAL	DB	SH
REV	DATE	AMENDMENTS	BY	CKD

**FOR COMMENT
& APPROVAL**

Commercial Services Design Ltd
Unit 5
Woodside Court
Clayton Wood Rise
Leeds
LS18 8RF
Tel: 0113 3223190
Web: www.csdesign.uk.com



CLIENT
G&H BUILDING SERVICES

PROJECT
SUNLIGHT HOUSE
LITTLE QUAY STREET
MANCHESTER M3 3HP

MECHANICAL SERVICES
VENTILATION LAYOUT
LEVEL 02

SCALE (S/A): 1:50	CSD REF: CSD 1298
DRAWN: MW	ENGINEER: DB
STARTED: JUNE 24	ISSUED: AUGUST 24
CHECKED: DB	APPROVED: BW
DRAWING NO: 1298-CSD-XX-02-DR-M-5703	
REV: P02	

ARCHITECTURE IS BASED ON ANOMALY DESIGN
ARCHITECTS DRAWING NO. SLH-ANO-PO-02-DR-A-0510
(001) LEVEL 02 PLAN
RECEIVED 05.06.2024

Project-Origination-Volume-Level-Type-Discipline-Drawing Number