138368/FO/2023 – DISCHARGING LISTED BUILDING CONDITIONS 3) AND 4)(a)

The Whitworth, Oxford Road, Manchester, M15 6ER

This statement is to discharge listed building conditions 3) and 4)(a) for the works to install a lifting hoist at The Whitworth, Oxford Road, Manchester, M15 6ER. Application number 138368/LO/2023.

Please see below comments:

138368/LO/2023 - DISCHARGING LISTED BUILDING CONDITIONS 3) and 4)(a)

3) The fixing method for the two motors is non-intrusive, nothing will be fixed into the roof structure. A nylon strap will be looped over each side of the timber roof truss and the motors will be clamped onto the strap on both sides of the roof.

Please refer to WML report.

4)(a) Please refer to the enclosed drawings, 031AA-8504-A103, 031AA-8504-A105, 031AA-8504-A106, 031AA-8504-A107.