LPCB®

www.redbooklive.com

Certificate of Product Approval

Certificate Number: 1117b Issue: 01

The Parkside Group Limited

Unit 5
The Willow Centre
17 Willow Lane
Mitcham
Surrey
CR4 4NX

is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

Products

Comar 7PI Commercial Door (Security Option)
hinged security doorset

Standard

BS EN 1627:2011
Pedestrian doorsets, windows, curtain walling, grilles and shutters - Burglar resistance - Requirements and classification

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for LPCB	Richard Flint Verifier	12 November 2013 Date of Issue	12 November 2013 Date of First Issue

This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR tag or contact us.

LPCB is part of BRE Global Ltd, Garston, Watford, WD25 9XX
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: enquiries@breglobal.com

© BRE Global Ltd, 2013

LPCB®

Appendix to Certificate No: 1117b

Issue: 01

The Parkside Group Limited

Hinged Security Doorset

Product Name	Type	Minimum Structural Opening Height (m)	Maximum Structural Opening Height (m)	Minimum Structural Opening Width (m)	Maximum Structural Opening Width (m)	EN 1627 Resistance Class[1]	LPCB Ref. No.
'Comar 7PI Commercial Door' (Security Option)	Single leaf bidirectional glazed aluminium doorset with anti-finger trap hinge and two deadlocks on the leading edge[2]	1.8	2.37	0.64	1.25	3	1117b/01

Compatible Locking Systems

Lock Positions	Manufacturer	Model	Type	Compatible Operating Devices		Compatible Cylinders
				External Face	Internal Face	
Upper and lower locks on leading edge	Adams Rite	Sentinel 6 hooked deadlock (Part 2600-300) and Sentinel 6 escutcheon (AH-2627-90-SLR)	Hook lock with security escutcheon	Key	Internal key	A, B, C or D

Compatible Cylinders

Cylinder Reference	Manufacturer	Model	Type
A	Adams Rite	CL1 – ED45/40-SC	Europrofile double cylinder (key:key)
B	Adams Rite	CL1 – ET45/40-SC	Europrofile double cylinder (key:thumbturn)
C	Avocet	ABS DC2AB 4540	Europrofile double cylinder (key:key)
D	Avocet	ABS DC2AB 4540 T	Europrofile double cylinder (key:thumbturn)

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for LPCB	Richard Flint Verifier	12 November 2013 Date of Issue	12 November 2013 Date of First Issue

This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR Tag or contact us.

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: Enquiries@breglobal.com

© BRE Global Ltd, 2013

LPCB®

Appendix to Certificate No: 1117b

Issue: 01

The Parkside Group Limited

Glazing

Manufacturer	Model
Essex Safety Glass	ESG Secure LPS 112/17

Other Hardware

Type	Manufacturer	Model	Description
Closer/pivot hinge	Axim	TC-8800-E	Concealed transom closer.
Escutcheon kit	Adams Rite	Sentinel 6	Cylinder escutcheon. This was formed from the following components: • Steel external escutcheon. • Steel back plate. • Steel internal plate. • M5 stainless steel machine screws.
Keep	Adams Rite	Sentinel	Strike plate assembly.
Pull handles	Comar	-	Extruded aluminium pull handle.

Notes:

1. The doorset achieves EN 1627 Resistance Class 3 in the optimum locked condition, i.e. when both locks are engaged. The EN 1627 resistance class achieved when only one lock is engaged was not determined because that is not a requirement of EN 1627.
2. The scope of approval only covers doorsets incorporating a mid-rail.
3. The quality of work conducted by those fabricating and installing the doorset can affect the products' ability to offer resistance to forced entry commensurate with that of the Resistance Class attributed to the doorset. It is therefore recommended that the doorset is sourced from fabricators that hold LPCB approval for the fabrication of this doorset.

This certificate and appendix is maintained and held in force through regular surveillance activities

Signed for LPCB	Richard Flint Verifier	12 November 2013 Date of Issue	12 November 2013 Date of First Issue

This certificate and appendix remain the property of BRE Global Ltd and is issued subject to terms and conditions (for details visit www.redbooklive.com/terms).

To check the validity of this certificate and appendix please visit www.redbooklive.com/check, scan the QR Tag or contact us.

LPCB is part of BRE Global Ltd., Garston, Watford WD25 9XX.
T: +44 (0)1923 664100 F: +44 (0)1923 664603 E: Enquiries@breglobal.com

© BRE Global Ltd, 2013