

RAMPS AND STEPS

- To be formed from timbers in accordance with structural engineer details and to be suitable and treated for external use.
- Landings ramps and steps to be finished with Slipgrip or equivalent non slip finish with contrasting nosings to steps and between landings and ramps. Sheeting to be screw fixed in accordance with manufacturers details and ensure no bubbling of sheeting/deflection between joints.
- All mitred joints to handrails and balustrades to be sanded down to remove sharp corners.
- Landing to be provided clear of door swing to allow minimum 1800mm dia turning circle.
- All landings, ramps and steps to have an unobstructed width of 1800mm.
- Steps to have a rise of 150mm with a tread depth of 280mm.
- Handrails to be fitted at 900mm above the level of the ramp and stair nosings and 1000mm above landings and to extend 450mm beyond the top and bottom of ramps and steps. Handrails to be fitted on 'L' brackets (brackets must be cast insitu and NOT welded).

