

Fire Detection and Alarm System Commissioning Certificate

FT/FAC *****

Requirement for BS:5839:1 2017

Details of the Installation for the Fire Alarm System which the Certificate of Servicing is being issued			
Client	Mr Abdul Tohid	Installation	Mr Abdul Tohid
Address	117 Oxbarn Avenue Wolverhampton	Address	12 South Grove Manchester
Postcode	WV37HQ	Postcode	M13 0AU

Details of the Installation	The system is: ☒ New ☐ An Addition ☐ An Alteration			System category
				L1

Extent of the system covered by this certificate

The whole building

Extent of Liability

Pass	All equipment operates correctly	Pass	Installation work is, as far as can reasonably be ascertained, of an acceptable standard
Pass	The entire system has been inspected and tested in accordance with the recommendations of Clause 39.2c of BS 5839-1: 2017	Pass	The documentation described in Clause 40 of BS 5839-1: 2017 has been provided to the user
Pass	Taking into account the guidance contained in Section 3 of BS 5839-1: 2017, I/we have not identified any obvious potential for an unacceptable rate of false alarms	The system performs as required by the specifications prepared by: Lukasz szachulowicz a copy of which I/we have been given	

The following work should be completed before/after (delete as applicable) the system becomes operational:

N/A

The following potential causes of false alarms should be considered at the time of the next visit

N/A

Before the system become operational, it should be soak tested in accordance with the recommendations of Clause 35.2.6 of BS 5839-1: 2017 for a period of:

N/A

Certification of Commissioning

I/We being the competent person(s) responsible (as indicated by my/our signatures below) for the commissioning of the fire detection and fire alarm system, particulars of which are set out above, certify that the said work for which I/we have been responsible complies to the best of my / our knowledge and belief with the recommendations of Clause 39 of BS 5839 -1: 2017, except for the variations, if any, stated in this certificate.

Variations from the recommendations of Clause 39 of BS 5839-1: 2017 (see BS 5839 -1: 2017, Clause 7):

N/A

For the COMMISSIONING of the system: The extent of liability of the signatory / signatories is limited to the work described above

Company:	Smart Solutions Electronics LTD	Name:	Lucas Szachulowicz
Branch No.	61679	Signature:	
Address:	72 Ardenfield Denton	Position:	Commision Engineer
Scheme No.	NAPIT	Date:	24/09/2023

Design Specification and Related Reference Documents

Design specification ref no.	Date issued	Electrical installation certificate no.	Date issued
N/A	24/09/2023	5973000001145	24/09/2023
Design drawings ref nos.		Design certificate no.	
N/A	24/09/2023	N/A	24/09/2023
'As Fitted' drawing nos.		Other	
N/A	24/09/2023	N/A	24/09/2023

Unless supplied by others, the 'As fitted' drawings have been supplied to the person responsible for commissioning the system (see Clause 36.2m of BS 5839 -1: 2017)