



MCFC North Expansion

North Stand

Metrolink External Cable Schedule

Document No:

NSE-MEE-NS-XX-LS-E-008007

RIBA Stage 4

Revision:

P03

MCFC North Expansion

Metrolink External Cable Schedule

Issue and Revision Record

Rev/ Issue	Date	Description	Revision Details	Prepared	Checked
P01	06/07/2023	RIBA Stage 4	S3 – For Review and Comment	AF	JM
P02	07/08/2023	RIBA Stage 4	S3 – For Review and Comment	AF	JM
P03	09/08/2023	RIBA Stage 4	S3 – For Review Comment	AF	JM

This document has been prepared for the titled project or named part thereof and should not be relied upon or used for any other project without an independent check being carried out as to its suitability and prior written authority of M-E Engineers Limited being obtained. This document, which may include extracts from or refer to British Standards, is the sole copyright of M-E Engineers Limited. It shall not be reproduced in whole or in part without written permission of M-E Engineers Limited. M-E Engineers Limited accepts no responsibility or liability for the consequences of this document being used for a purpose other than the purposes for which it was commissioned. Any person using or relying on the document for such other purpose agrees, and shall by such use or reliance be taken to confirm his agreement to indemnify M-E Engineers Limited for all loss of damage resulting therefrom. M-E Engineers Limited accepts no responsibility or liability for this document to any party other than the person by whom it was commissioned.

MCFC North Expansion

North Stand Metrolink External Cable Schedule



External LV Cable Schedule:

Breaker Ref	Cable Ref	Destination	Protection device type	Protection Size	Motorised	No of Cores	Preliminary Cable CSA mm2	Cable Type	CPC Separate Cable Size mm2
TBC	FP/DB/01/1L1	KINGFISHER FLOOD LIGHTING	RCBO	10A	N	1x1x3c	2.5	Multicore 90°C thermosetting armoured *RUN TO 70°C Cu Table 4D4	2.5