



1. THIS DRAWING SHALL BE READ IN CONJUNCTION WITH ALL OTHER RELEVANT ARCHITECTURAL, ELECTRICAL AND MECHANICAL DRAWINGS, SPECIFICATIONS, SCHEDULES AND DRAWINGS, SPECIFICATIONS, SCHEDULES AND PROJECT SPECIFIC DOCUMENTS.

2. ALL PLANT AND EQUIPMENT SHALL BE INSTALLED TO MANUFACTURER'S RECOMMENDATIONS, ALLOWING FULL ACCESS FOR COMMISSIONING, MAINTENANCE AND REPAIR.

3. ALL DIMENSIONS IN mm UNLESS OTHERWISE STATED.

4. WORK TO FIGURED DIMENSIONS ONLY - DO NOT SCALE FROM THIS DRAWING.

5. SECONDARY ROUTES ARE AS FOLLOWS:

DATA & SECURITY FINAL CIRCUIT IN GALVANIZED CONDUIT.

POWER & LIGHTING CIRCUIT IN GALVANIZED CONDUIT.

FIRE ALARM CIRCUIT IN GALVANIZED CONDUIT.

6. DIFFERENT TYPES OF CABLES ON THE COMBINED CABLE BASKET TO BE SEGREGATED VIA EARTHED DIVIDERS.

7. BUILDERSWORK TO BE SEALED WHERE REQUIRED USING PROPER FIRE STOPPING SEALANT, BY OTHERS.

8. ALL CABLES TO BE CONTAINED IN A BASKET, COMPLETE WITH ALL NECESSARY MANUFACTURED COMPONENTS, TO ENSURE CONTINUITY THROUGHOUT THE RUN AND TO BE SECURED AT EACH AND EVERY CABLE.

9. ALL EXTERNAL POWER AND LIGHTING CABLES TO BE SWA AND CONTAINED WITHIN CABLE TRAY. ALL EXTERNAL CABLEING TO BE UV PROTECTED.

10. ALL CONTAINMENT TO BE INSTALLED IN THE CEILING DOWN WHERE POSSIBLE.

Rev	Description	Drawn	Date
P01	Stage 4a Issue	DH	27/03/23
P02	Stage 4a Issue Update	SS	19/05/23
C01	Contract Issue	RH	03/10/23
C02	Contract Issue	SN	17/10/23
C03	Contract Issue	SS	20/10/23
C04	Contract Issue	CN	15/11/23

Registered in England No. 1067341

Client:

BAM Construction Ltd

Project:

Plot 9a First Street

Scale:	1:50 @ AU	Checked:	EP
Drawing Number:			Revision:
MN2A-BAF-ZZ-B1-DR-E-709901			C04
S4	Drawing Status: ISSUED FOR STAGE APPROVAL		
This drawing is copyright and may not be reproduced either in part or full without written permission from Briggs & Weller Group Ltd.			
		 bsi BSI Member Design & Construction Contract Delivery PAS 1992-2	

DO NOT SCALE OFF THIS DRAWING