Building Services

Direct Tel: 0161 839 8392
Direct Email: nuala.maguire@watermangroup.com

Our Ref: BSD 14184
Doc Ref: NMGNPH-WAT-ZZ-XX-LT-ME-0002

Date: 16th August 2024


Waterman Building Services
6th Floor Trinity Court
16 John Dalton Street
Manchester
M2 6HY

RE: North View, Adult Mental Health Unit, North Manchester General Hospital – Extraction of fumes, vapours and odours Planning Condition 19

In relation to the Planning Ventilation Statement NMGNPH-RAM-VV-XX-RP-M-5701 Version 2 prepared by Ramboll on the 25th September 2020, we confirm that generally the recommendations outlined in the report have been incorporated into the scheme to the best of our knowledge.

The report references the incorporation of UV filtration within the kitchen canopy however this has been omitted through the detailed design due to the low risk of odour pollution.

Signature:



Name: **Nuala Maguire**

On behalf of

Company: **Waterman Building Services**