MANCHESTER
CITY COUNCIL

Planning

Steven McCoombe
Telephone: 0161 234 4607
steven.mccoombe@manchester.gov.uk

P O Box 532 Town Hall
Manchester M60 2LA

Mr Darren Pomfret
Manchester Building Design Ltd
8 Gas Street
Hyde
SK14 8JD

Date: 28 May 2024

Dear Sir or Madam,

Class MA, Part 3, Schedule 2 of the Town & Country Planning (General Permitted Development) (England) Order 2015 (as amended)
Application No.: 139834/P3MA/2024
Description: Prior Approval for conversion of office units on the first and second floors to 7 No. self contained apartments
Location: 103 - 105 Cheetham Hill Road, Manchester, M8 8PY

The City Council is satisfied that the development would have no material, harmful impact as a result of contamination, flooding or noise, and satisfactory arrangements have been made with regard to the management of domestic waste and the provision of natural light to all habitable rooms. The proposal therefore complies with the requirements of policies SP1, EN14, EN18, EN19 and DM1 of the Manchester Core Strategy, saved policy DC26 of the Unitary Development Plan for the City of Manchester and Places for Everyone Joint Development Plan, pursuant to Schedule 2, Part 3, Class MA of the Town and Country Planning (General Permitted Development) Order 2015 (as amended). Approval is hereby granted in accordance with drawings referenced 83/23/04/B and 83/23/01/B received by the City Council as Local Planning Authority on 14 May 2024 and drawing referenced 83/23/04/D, received by the City Council as Local Planning Authority on 21 May 2024.

2) The development hereby approved shall only be implemented in accordance with the waste management arrangements shown on drawing referenced 83/23/04/B received by the City Council as Local Planning Authority on 9 May 2024. No bins shall be stored on the forecourt, adopted footway or outside the agreed storage area, other than on the day of collection.

Reason - In the interests of amenity and public health, pursuant to policies DM1 and SP1 of the Manchester Core Strategy.
3) a) Notwithstanding details submitted, prior to the flats hereby approved being occupied, a scheme for acoustically insulating the proposed residential accommodation against noise from Cheetham Hill Road and surrounding commercial uses, shall be submitted to and approved in writing by the City Council as Local planning authority. The potential for overheating shall also be assessed and the noise insulation scheme should take this into account. The approved noise insulation and ventilation scheme shall be completed before any of the approved flats are occupied.

b) Prior to first occupation of the residential units, a verification report shall be required to validate that the work undertaken throughout the development conforms to the recommendations and requirements in the approved acoustic consultant's report. The report shall also undertake post completion testing to confirm that the internal noise criteria have been met. Any instances of non-conformity with the recommendations in the report shall be detailed along with any measures required to ensure compliance with the internal noise
criteria.

Reason - In order to safeguard the amenity of existing and future occupiers of nearby residential accommodation, pursuant to saved policy DC26 of the Unitary Development Plan for the City of Manchester and policies SP1, H1 and DM1 of the Manchester Core Strategy.

Informatives

Building Regulations 2010

Please note that this document does not grant any permission under Building Regulations. If you require further information regarding compliance with Building Regulations, please contact Building Control on 0161 234 4490 or by email to building.control@manchester.gov.uk.

Street Naming & Numbering Requirements

Manchester City Council is responsible for allocating street naming and numbering within Manchester for new developments or property conversions. Individuals or businesses are not permitted to allocate their own property numbers, building or street names.

If your development includes the creation of new dwellings (either new build or conversion of existing buildings), creation of new commercial properties or the subdivision of existing properties you must ensure that you request new or changes to addresses through us so they can be officially allocated and registered in accordance with the Public Health Act 1925 Sections 17-19 & Greater Manchester Act 1981 Section 22.

Failure to do this may result in difficulties for the developer/occupier when requiring services such as connections to utilities, phone lines and postal services and may delay your development.

You can apply online at the following address:
http://www.manchester.gov.uk/info/100011/roads_parking_and_transport/1988/naming_and_numbering_of_houses_buildings_streets_and_roads/2

City Council records highlight that the underground River Irwell Tributary is located within close proximity to the site (approximately 60 m to the south of the site), while our records are frequently updated to ensure the highest level of accuracy, the records cannot guarantee 100% accuracy for all culverted assets. Therefore, we would request that the applicant informs the onsite contractor to remain observant and to take the appropriate safety precautions during excavation works. If any major unknown drainage assets are found beneath the site, then further investigation works should take place to identify the asset and MCC Lead Local Flood Authority (LLFA) should be contacted immediately. Any alterations to an ordinary watercourse will require consent from MCC LLFA under Land Drainage Act 1991.
following

Yours faithfully,



Julie Roscoe
Director of Planning, Building Control & Licensing