

Date: 12th August 2024

J Greenwood (Builders) Ltd
Unit B9
Greengate Industrial Estate
Greenside Way
Chadderton
M24 1SW

For the attention of Mr Guy Quigley

Dear Guy

RE: 63-65 Upper Chorlton Rd, Whalley Range PVC Window Replacement

Further to the queries raised by the planners regarding the thickness of the profile on the PVC window sample provided, we would like to respond as follows.

Using the REHAU pvc window system, there is only one size of casement sash (open out) available. This is 75mm wide. This is to ensure that the windows meets the U-Value requirements and also so that there is enough room for the 44mm thick triple glazed unit that we need on this project.

The sample provided has 52mm outer frame and 75mm T sash.

See section drawings below showing sight lines with 52mm outer frame.

Most other PVCu window systems have similar sight lines. There may be a few millimetres difference between say the Rehau system, VEKA system and Eurocell system for example.


Let us know if you need any further information.

Yours faithfully


Steve Bottomley

Steve Bottomley
Contracts Director

OUTER FRAMES



Casement Slim Outer Frame 52mm (6 Chamber)
 White Profile Art. No. 546845



Casement T Sash 75mm (5 chamber)
 White Profile Art. No. 546855
 Laminated Profile Art. No. 586855
 Reinforcement 30 x 23



Windows
& Doors Ltd.



0161 785 4663




sales@dandmwindowsanddoors.co.uk



www.dandmwindowsanddoors.co.uk



Office 7, Floor 3, Earl Business Centre,
Dowry Street, Oldham. OL8 2PF



52mm Outer Frame with T
sash and 150mm Sill