

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

Block Reference	Lodged	Issued on Date	30/05/2024
Block Name	Lodged		
Assessor Details	Mr. Steven Johnson, Steven Johnson, Tel: 0795607219, steven.johnson@twccconsulting.com		Assessor ID Z708-0001
Client			

Block Compliance Report - DER

Block Reference: Lodged		Block Name: Lodged			
Property-Assessment Reference	Multiplier	Floor Area (m ²)	DER (kgCO ₂ /m ²)	TER (kgCO ₂ /m ²)	% DER/TER
01.001-001	1	64.67	26.18	25.20	-3.88 %
01.002-001	1	45.32	23.45	26.07	10.05 %
01.003-001	1	65.73	21.46	22.95	6.49 %
01.004-001	1	33.64	28.58	35.13	18.65 %
01.005-001	1	66.76	22.10	23.84	7.31 %
01.006-001	1	66.76	23.32	24.03	2.96 %
01.007-001	1	59.31	23.71	24.65	3.81 %
01.008-001	1	46.79	23.39	25.98	9.97 %
01.009-001	1	67.02	27.10	26.43	-2.53 %
01.010-001	1	57.93	27.64	26.37	-4.80 %
01.011-001	1	46.79	22.70	24.61	7.76 %
01.012-001	1	59.31	22.58	22.95	1.63 %
01.013-001	1	46.65	23.59	24.64	4.27 %
01.014-001	1	66.83	21.81	23.22	6.07 %
01.015-001	1	62.63	21.63	22.54	4.05 %
01.016-001	1	85.6	19.36	21.28	9.01 %
01.017-001	1	64.72	24.53	24.02	-2.14 %
02.001-001	1	64.67	22.88	22.87	-0.05 %
02.002-001	1	45.32	21.07	23.44	10.12 %
02.003-001	1	65.73	20.08	21.28	5.65 %
02.004-001	1	33.64	25.48	30.81	17.29 %
02.005-001	1	71.12	22.63	23.99	5.67 %
02.006-001	1	66.85	18.97	21.07	9.96 %
02.007-001	1	66.76	20.55	21.62	4.94 %
02.008-001	1	59.31	20.75	22.20	6.53 %
02.009-001	1	46.79	21.60	23.52	8.15 %
02.010-001	1	67.02	23.92	24.14	0.93 %
02.011-001	1	57.93	24.12	23.64	-2.01 %
02.012-001	1	46.79	21.11	22.17	4.79 %
02.013-001	1	59.31	20.31	20.53	1.08 %
02.014-001	1	46.65	21.06	22.26	5.39 %
02.015-001	1	34.44	32.00	36.83	13.11 %
02.016-001	1	63.77	25.71	25.11	-2.38 %
02.017-001	1	65.3	18.70	19.77	5.39 %
02.018-001	1	62.83	19.06	20.12	5.27 %
02.019-001	1	85.6	19.78	21.23	6.83 %
02.020-001	1	64.72	25.21	24.02	-4.96 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

03.001-001	1	64.67	22.83	22.87	0.17 %
03.002-001	1	45.32	20.95	23.44	10.63 %
03.003-001	1	65.73	19.88	21.28	6.59 %
03.004-001	1	33.64	25.33	30.81	17.78 %
03.005-001	1	71.12	20.19	21.41	5.68 %
03.006-001	1	66.85	18.77	21.07	10.91 %
03.007-001	1	66.76	19.64	21.62	9.15 %
03.008-001	1	59.31	20.80	22.20	6.30 %
03.009-001	1	46.79	21.44	23.52	8.83 %
03.010-001	1	67.02	24.62	24.14	-1.97 %
03.011-001	1	57.93	24.26	23.64	-2.60 %
03.012-001	1	46.79	21.12	22.17	4.74 %
03.013-001	1	59.31	19.63	20.53	4.39 %
03.014-001	1	46.65	20.90	22.26	6.11 %
03.015-001	1	34.44	28.71	33.70	14.82 %
03.016-001	1	63.77	23.16	22.53	-2.78 %
03.017-001	1	65.3	18.63	19.77	5.74 %
03.018-001	1	62.83	18.67	20.12	7.21 %
03.019-001	1	85.6	19.13	21.23	9.90 %
03.020-001	1	64.72	25.35	24.02	-5.54 %
04.001-001	1	64.67	23.10	22.87	-1.01 %
04.002-001	1	45.32	20.66	23.44	11.87 %
04.003-001	1	65.73	20.13	21.28	5.41 %
04.004-001	1	33.64	26.10	30.81	15.28 %
04.005-001	1	71.12	21.31	21.41	0.45 %
04.006-001	1	66.85	19.54	21.07	7.26 %
04.007-001	1	66.76	21.00	21.62	2.86 %
04.008-001	1	59.31	21.43	22.20	3.47 %
04.009-001	1	46.79	21.26	23.52	9.59 %
04.010-001	1	67.02	24.07	24.14	0.31 %
04.011-001	1	57.93	23.84	23.64	-0.83 %
04.012-001	1	46.79	20.55	22.17	7.31 %
04.013-001	1	59.31	19.63	20.53	4.39 %
04.014-001	1	46.65	21.03	22.26	5.53 %
04.015-001	1	34.44	28.71	33.70	14.82 %
04.016-001	1	63.77	23.35	22.53	-3.62 %
04.017-001	1	65.3	18.85	19.77	4.63 %
04.018-001	1	62.83	19.22	20.12	4.48 %
04.019-001	1	85.6	19.52	21.23	8.06 %
04.020-001	1	64.72	25.07	24.02	-4.38 %
05.001-001	1	64.67	23.10	22.87	-1.01 %
05.002-001	1	45.32	20.73	23.44	11.57 %
05.003-001	1	65.73	20.21	21.28	5.04 %
05.004-001	1	33.64	26.10	30.81	15.28 %
05.005-001	1	71.12	21.24	21.41	0.78 %
05.006-001	1	66.85	19.68	21.07	6.59 %
05.007-001	1	66.76	20.99	21.62	2.90 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

05.008-001	1	59.31	21.33	22.20	3.92 %
05.009-001	1	46.79	21.33	23.52	9.29 %
05.010-001	1	67.02	24.12	24.14	0.10 %
05.011-001	1	57.93	24.03	23.64	-1.63 %
05.012-001	1	46.79	21.03	22.17	5.15 %
05.013-001	1	59.31	20.06	20.53	2.30 %
05.014-001	1	46.65	21.30	22.26	4.31 %
05.015-001	1	34.44	28.81	33.70	14.52 %
05.016-001	1	63.77	23.39	22.53	-3.80 %
05.017-001	1	65.3	19.14	19.77	3.16 %
05.018-001	1	62.83	19.28	20.12	4.18 %
05.019-001	1	85.6	19.60	21.23	7.68 %
05.020-001	1	64.72	25.18	24.02	-4.84 %
06.001-001	1	64.67	23.61	22.87	-3.24 %
06.002-001	1	45.32	21.15	23.44	9.78 %
06.003-001	1	65.73	20.16	21.28	5.27 %
06.004-001	1	33.64	26.21	30.81	14.92 %
06.005-001	1	71.12	21.02	21.41	1.81 %
06.006-001	1	66.85	19.73	21.07	6.36 %
06.007-001	1	66.76	20.96	21.62	3.04 %
06.008-001	1	59.31	21.35	22.20	3.83 %
06.009-001	1	46.79	26.45	27.52	3.88 %
06.010-001	1	67.02	31.39	29.22	-7.42 %
06.011-001	1	57.93	31.97	28.77	-11.12 %
06.012-001	1	46.79	26.14	25.82	-1.23 %
06.013-001	1	59.31	20.30	20.53	1.13 %
06.014-001	1	46.65	21.51	22.26	3.37 %
06.015-001	1	34.44	29.09	33.70	13.69 %
06.016-001	1	63.77	23.35	22.53	-3.62 %
06.017-001	1	65.3	19.36	19.77	2.05 %
06.018-001	1	62.83	19.33	20.12	3.93 %
06.019-001	1	85.6	19.46	21.23	8.34 %
06.020-001	1	64.72	25.10	24.02	-4.50 %
07.001-001	1	64.67	23.05	22.87	-0.80 %
07.002-001	1	45.32	21.10	23.44	9.99 %
07.003-001	1	65.73	20.19	21.28	5.13 %
07.004-001	1	33.64	25.96	30.81	15.73 %
07.005-001	1	71.12	20.92	21.41	2.27 %
07.006-001	1	66.85	19.92	21.07	5.45 %
07.007-001	1	66.76	21.04	21.62	2.67 %
07.008-001	1	59.31	25.81	25.05	-3.02 %
07.009-001	1	59.31	24.61	23.38	-5.24 %
07.010-001	1	46.65	21.27	22.26	4.45 %
07.011-001	1	34.44	29.28	33.70	13.12 %
07.012-001	1	63.77	23.24	22.53	-3.13 %
07.013-001	1	65.3	18.91	19.77	4.33 %
07.014-001	1	62.83	19.22	20.12	4.48 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

07.015-001	1	85.6	19.59	21.23	7.73 %
07.016-001	1	64.72	25.18	24.02	-4.84 %
08.001-001	1	64.67	23.11	22.87	-1.06 %
08.002-001	1	45.32	21.20	23.44	9.56 %
08.003-001	1	65.73	20.25	21.28	4.85 %
08.004-001	1	33.64	25.96	30.81	15.73 %
08.005-001	1	71.12	21.20	21.41	0.97 %
08.006-001	1	66.85	19.87	21.07	5.69 %
08.007-001	1	66.76	20.93	21.62	3.18 %
08.008-001	1	66.55	24.66	23.96	-2.91 %
08.009-001	1	59.31	24.32	23.38	-4.00 %
08.010-001	1	46.65	21.51	22.26	3.37 %
08.011-001	1	34.44	29.55	33.70	12.32 %
08.012-001	1	63.77	23.83	22.53	-5.75 %
08.013-001	1	65.3	19.29	19.77	2.41 %
08.014-001	1	62.83	19.27	20.12	4.23 %
08.015-001	1	85.6	19.51	21.23	8.11 %
08.016-001	1	64.72	25.43	24.02	-5.88 %
09.001-001	1	64.67	23.80	22.87	-4.07 %
09.002-001	1	45.32	21.20	23.44	9.56 %
09.003-001	1	65.73	19.87	21.28	6.63 %
09.004-001	1	33.64	25.74	30.81	16.45 %
09.005-001	1	71.12	21.35	21.41	0.27 %
09.006-001	1	66.85	19.27	21.07	8.54 %
09.007-001	1	66.76	20.72	21.62	4.15 %
09.008-001	1	66.55	23.83	23.96	0.55 %
09.009-001	1	59.31	24.70	23.38	-5.63 %
09.010-001	1	46.65	21.39	22.26	3.91 %
09.011-001	1	34.44	29.19	33.70	13.39 %
09.012-001	1	63.77	22.89	22.53	-1.58 %
09.013-001	1	65.3	18.65	19.77	5.64 %
09.014-001	1	62.83	19.01	20.12	5.52 %
09.015-001	1	85.6	19.29	21.23	9.14 %
09.016-001	1	64.72	25.00	24.02	-4.09 %
10.001-001	1	64.67	22.75	22.87	0.52 %
10.002-001	1	45.32	21.20	23.44	9.56 %
10.003-001	1	65.73	19.69	21.28	7.48 %
10.004-001	1	33.64	25.88	30.81	15.99 %
10.005-001	1	71.12	20.83	21.41	2.69 %
10.006-001	1	66.85	18.92	21.07	10.20 %
10.007-001	1	66.76	20.42	21.62	5.54 %
10.008-001	1	66.55	24.09	23.96	-0.53 %
10.009-001	1	59.31	24.09	23.38	-3.02 %
10.010-001	1	46.65	21.34	22.26	4.13 %
10.011-001	1	34.44	29.50	33.70	12.47 %
10.012-001	1	63.77	23.14	22.53	-2.69 %
10.013-001	1	65.3	18.87	19.77	4.53 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

10.014-001	1	46.67	21.26	22.31	4.72 %
10.015-001	1	52.74	19.84	21.06	5.79 %
10.016-001	1	46.73	20.88	22.20	5.95 %
10.017-001	1	64.72	24.47	24.02	-1.88 %
11.001-001	1	64.67	22.70	22.87	0.74 %
11.002-001	1	45.32	21.23	23.44	9.43 %
11.003-001	1	65.73	19.91	21.28	6.45 %
11.004-001	1	33.64	25.75	30.81	16.41 %
11.005-001	1	71.12	20.83	21.41	2.69 %
11.006-001	1	66.85	19.47	21.07	7.59 %
11.007-001	1	66.76	20.93	21.62	3.18 %
11.008-001	1	66.55	23.94	23.96	0.09 %
11.009-001	1	59.31	24.88	23.38	-6.40 %
11.010-001	1	46.65	21.52	22.26	3.33 %
11.011-001	1	34.44	29.55	33.70	12.32 %
11.012-001	1	63.77	23.54	22.53	-4.47 %
11.013-001	1	65.3	19.15	19.77	3.11 %
11.014-001	1	46.67	21.31	22.31	4.50 %
11.015-001	1	52.74	19.67	21.06	6.60 %
11.016-001	1	46.73	21.03	22.20	5.27 %
11.017-001	1	64.72	25.11	24.02	-4.54 %
12.001-001	1	64.67	22.98	22.87	-0.49 %
12.002-001	1	45.32	21.18	23.44	9.65 %
12.003-001	1	65.73	19.57	21.28	8.04 %
12.004-001	1	33.64	25.95	30.81	15.77 %
12.005-001	1	71.12	20.96	21.41	2.09 %
12.006-001	1	66.85	19.09	21.07	9.39 %
12.007-001	1	66.76	20.68	21.62	4.34 %
12.008-001	1	66.55	24.34	23.96	-1.58 %
12.009-001	1	59.31	24.16	23.38	-3.32 %
12.010-001	1	46.65	21.49	22.26	3.46 %
12.011-001	1	34.44	29.56	33.70	12.29 %
12.012-001	1	63.77	23.02	22.53	-2.16 %
12.013-001	1	65.3	19.10	19.77	3.37 %
12.014-001	1	46.67	21.18	22.31	5.08 %
12.015-001	1	52.74	19.53	21.06	7.26 %
12.016-001	1	46.73	20.76	22.20	6.49 %
12.017-001	1	64.72	24.72	24.02	-2.92 %
13.001-001	1	64.67	31.14	28.26	-10.20 %
13.002-001	1	45.32	25.88	27.47	5.79 %
13.003-001	1	65.73	19.29	21.28	9.36 %
13.004-001	1	33.64	25.49	30.81	17.26 %
13.005-001	1	71.12	20.15	21.41	5.87 %
13.006-001	1	66.85	18.51	21.07	12.15 %
13.007-001	1	66.76	20.08	21.62	7.11 %
13.008-001	1	66.55	23.87	23.96	0.38 %
13.009-001	1	59.31	23.90	23.38	-2.20 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

13.010-001	1	46.65	21.04	22.26	5.48 %
13.011-001	1	34.44	29.19	33.70	13.39 %
13.012-001	1	63.77	22.71	22.53	-0.78 %
13.013-001	1	65.3	18.50	19.77	6.40 %
13.014-001	1	46.67	21.48	22.31	3.74 %
13.015-001	1	52.74	20.13	21.06	4.41 %
13.016-001	1	46.73	25.63	25.87	0.92 %
14.001-001	1	67.16	21.85	22.94	4.74 %
14.002-001	1	33.64	25.78	30.81	16.32 %
14.003-001	1	71.12	20.63	21.41	3.63 %
14.004-001	1	66.85	19.13	21.07	9.20 %
14.005-001	1	66.76	20.31	21.62	6.05 %
14.006-001	1	66.55	23.37	23.96	2.47 %
14.007-001	1	59.31	23.29	23.38	0.40 %
14.008-001	1	46.65	21.09	22.26	5.26 %
14.009-001	1	34.44	29.02	33.70	13.90 %
14.010-001	1	63.77	23.63	22.53	-4.86 %
14.011-001	1	65.3	19.05	19.77	3.62 %
14.012-001	1	46.67	21.40	22.31	4.10 %
14.013-001	1	52.74	23.92	23.38	-2.29 %
15.001-001	1	67.16	22.53	22.94	1.77 %
15.002-001	1	33.64	25.76	30.81	16.38 %
15.003-001	1	71.12	21.26	21.41	0.69 %
15.004-001	1	66.85	19.92	21.07	5.45 %
15.005-001	1	66.76	20.95	21.62	3.09 %
15.006-001	1	66.55	23.94	23.96	0.09 %
15.007-001	1	59.31	24.35	23.38	-4.13 %
15.008-001	1	46.65	21.48	22.26	3.51 %
15.009-001	1	34.44	29.50	33.70	12.47 %
15.010-001	1	63.77	23.86	22.53	-5.89 %
15.011-001	1	65.3	18.96	19.77	4.08 %
15.012-001	1	46.67	21.43	22.31	3.96 %
15.013-001	1	58.81	24.01	22.89	-4.91 %
16.001-001	1	67.16	22.11	22.94	3.61 %
16.002-001	1	33.64	25.61	30.81	16.87 %
16.003-001	1	71.12	20.42	21.41	4.61 %
16.004-001	1	66.85	19.15	21.07	9.11 %
16.005-001	1	66.76	21.22	21.62	1.84 %
16.006-001	1	66.55	23.62	23.96	1.43 %
16.007-001	1	59.31	24.31	23.38	-3.96 %
16.008-001	1	46.65	21.42	22.26	3.78 %
16.009-001	1	34.44	29.09	33.70	13.69 %
16.010-001	1	63.77	22.98	22.53	-1.98 %
16.011-001	1	65.3	18.77	19.77	5.04 %
16.012-001	1	46.67	21.50	22.31	3.65 %
16.013-001	1	58.81	23.97	22.89	-4.74 %
17.001-001	1	67.16	22.01	22.94	4.04 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

17.002-001	1	33.64	25.96	30.81	15.73 %
17.003-001	1	71.12	20.54	21.41	4.05 %
17.004-001	1	66.85	18.84	21.07	10.58 %
17.005-001	1	66.76	20.48	21.62	5.26 %
17.006-001	1	66.55	23.24	23.96	3.01 %
17.007-001	1	59.31	24.13	23.38	-3.19 %
17.008-001	1	46.65	21.49	22.26	3.46 %
17.009-001	1	34.44	29.04	33.70	13.84 %
17.010-001	1	63.77	22.73	22.53	-0.87 %
17.011-001	1	65.3	18.68	19.77	5.49 %
17.012-001	1	46.67	21.27	22.31	4.68 %
17.013-001	1	58.81	23.78	22.89	-3.91 %
18.001-001	1	67.16	21.89	22.94	4.56 %
18.002-001	1	33.64	25.92	30.81	15.86 %
18.003-001	1	71.12	20.95	21.41	2.13 %
18.004-001	1	66.85	18.98	21.07	9.92 %
18.005-001	1	66.76	20.32	21.62	6.00 %
18.006-001	1	66.55	23.85	23.96	0.47 %
18.007-001	1	59.31	24.27	23.38	-3.79 %
18.008-001	1	46.65	21.46	22.26	3.60 %
18.009-001	1	34.44	29.49	33.70	12.50 %
18.010-001	1	63.77	23.28	22.53	-3.31 %
18.011-001	1	65.3	18.62	19.77	5.80 %
18.012-001	1	46.67	21.49	22.31	3.69 %
18.013-001	1	58.81	24.12	22.89	-5.39 %
19.001-001	1	67.16	22.96	22.94	-0.10 %
19.002-001	1	33.64	25.89	30.81	15.96 %
19.003-001	1	71.12	20.84	21.41	2.65 %
19.004-001	1	66.85	19.04	21.07	9.63 %
19.005-001	1	66.76	20.47	21.62	5.31 %
19.006-001	1	66.55	23.66	23.96	1.26 %
19.007-001	1	59.31	24.80	23.38	-6.05 %
19.008-001	1	46.65	21.46	22.26	3.60 %
19.009-001	1	34.44	29.01	33.70	13.93 %
19.010-001	1	63.77	23.79	22.53	-5.57 %
19.011-001	1	65.3	19.29	19.77	2.41 %
19.012-001	1	46.67	21.56	22.31	3.38 %
19.013-001	1	58.81	24.42	22.89	-6.70 %
20.001-001	1	67.16	21.74	22.94	5.22 %
20.002-001	1	33.64	25.94	30.81	15.80 %
20.003-001	1	71.12	29.59	27.20	-8.80 %
20.004-001	1	66.85	26.84	26.09	-2.87 %
20.005-001	1	66.76	28.56	26.54	-7.62 %
20.006-001	1	66.55	32.43	29.83	-8.70 %
20.007-001	1	59.31	28.99	26.09	-11.11 %
20.008-001	1	46.65	28.82	26.72	-7.85 %
20.009-001	1	34.44	29.53	33.70	12.38 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

20.010-001	1	63.77	23.73	22.53	-5.31 %
20.011-001	1	65.3	19.20	19.77	2.86 %
20.012-001	1	46.67	21.55	22.31	3.42 %
20.013-001	1	58.81	24.24	22.89	-5.92 %
21.001-001	1	67.16	22.05	22.94	3.87 %
21.002-001	1	42.1	25.89	27.30	5.15 %
21.003-001	1	50.98	23.94	25.22	5.06 %
21.004-001	1	63.77	23.77	22.53	-5.49 %
21.005-001	1	65.3	19.23	19.77	2.71 %
21.006-001	1	46.67	21.55	22.31	3.42 %
21.007-001	1	58.81	24.48	22.89	-6.97 %
22.001-001	1	67.16	21.77	22.94	5.09 %
22.002-001	1	42.1	25.14	27.30	7.90 %
22.003-001	1	50.98	24.22	25.36	4.50 %
22.004-001	1	63.77	23.73	22.53	-5.31 %
22.005-001	1	65.3	18.62	19.77	5.80 %
22.006-001	1	46.67	21.52	22.31	3.56 %
22.007-001	1	58.81	24.00	22.89	-4.87 %
23.001-001	1	67.16	21.77	22.94	5.09 %
23.002-001	1	42.1	25.07	27.30	8.16 %
23.003-001	1	50.98	24.16	25.36	4.74 %
23.004-001	1	63.77	22.87	22.53	-1.49 %
23.005-001	1	65.3	18.67	19.77	5.54 %
23.006-001	1	46.67	21.57	22.31	3.33 %
23.007-001	1	58.81	23.74	22.89	-3.73 %
24.001-001	1	67.16	31.42	28.78	-9.17 %
24.002-001	1	42.1	34.21	32.42	-5.52 %
24.003-001	1	50.98	34.51	32.28	-6.91 %
24.004-001	1	63.77	32.52	28.16	-15.47 %
24.005-001	1	65.3	27.08	24.47	-10.68 %
24.006-001	1	46.67	29.62	27.04	-9.56 %
24.007-001	1	58.81	32.93	28.68	-14.80 %
13.017*-001	1	64.72	31.79	28.97	-9.73 %
Totals:	352	20407.93	8,048.43	8,372.82	
Average DER = 22.55 kgCO ₂ /m ²		% DER/TER	PASS		
Average TER = 23.26 kgCO ₂ /m ²		3.05 %			

Block Compliance Report - DFEE

Block Reference: Lodged		Block Name: Lodged			
Property-Assessment Reference	Multiplier	Floor Area (m ²)	DFEE (kWh/m ² /yr)	TFEE (kWh/m ² /yr)	% DFEE/TFEE
01.001-001	1	64.67	37.11	42.66	13.00 %
01.002-001	1	45.32	26.65	33.85	21.26 %
01.003-001	1	65.73	28.21	34.23	17.58 %
01.004-001	1	33.64	31.77	42.86	25.86 %
01.005-001	1	66.76	29.66	38.01	21.95 %
01.006-001	1	66.76	31.98	38.87	17.72 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

01.007-001	1	59.31	30.82	37.60	18.02 %
01.008-001	1	46.79	28.56	35.62	19.83 %
01.009-001	1	67.02	39.50	47.90	17.54 %
01.010-001	1	57.93	38.26	43.93	12.90 %
01.011-001	1	46.79	26.51	30.72	13.68 %
01.012-001	1	59.31	28.24	31.66	10.81 %
01.013-001	1	46.65	27.68	31.16	11.18 %
01.014-001	1	66.83	27.98	34.64	19.23 %
01.015-001	1	62.63	27.74	31.62	12.27 %
01.016-001	1	85.6	27.28	33.34	18.19 %
01.017-001	1	64.72	34.40	38.63	10.97 %
02.001-001	1	64.67	31.71	35.27	10.10 %
02.002-001	1	45.32	21.25	24.88	14.58 %
02.003-001	1	65.73	25.37	29.02	12.59 %
02.004-001	1	33.64	26.27	30.41	13.60 %
02.005-001	1	71.12	33.82	40.21	15.88 %
02.006-001	1	66.85	24.26	28.27	14.20 %
02.007-001	1	66.76	27.41	31.22	12.22 %
02.008-001	1	59.31	26.00	29.77	12.65 %
02.009-001	1	46.79	24.05	27.48	12.47 %
02.010-001	1	67.02	35.07	40.67	13.78 %
02.011-001	1	57.93	32.68	35.06	6.79 %
02.012-001	1	46.79	21.87	21.25	-2.92 %
02.013-001	1	59.31	23.53	23.71	0.73 %
02.014-001	1	46.65	22.69	21.90	-3.63 %
02.015-001	1	34.44	40.04	49.96	19.86 %
02.016-001	1	63.77	36.92	42.39	12.91 %
02.017-001	1	65.3	21.99	22.99	4.39 %
02.018-001	1	62.83	21.71	22.85	5.01 %
02.019-001	1	85.6	27.68	33.37	17.04 %
02.020-001	1	64.72	35.21	38.93	9.55 %
03.001-001	1	64.67	31.68	35.27	10.17 %
03.002-001	1	45.32	21.16	24.88	14.96 %
03.003-001	1	65.73	25.27	29.02	12.92 %
03.004-001	1	33.64	26.15	30.41	13.98 %
03.005-001	1	71.12	28.55	31.57	9.56 %
03.006-001	1	66.85	24.17	28.27	14.52 %
03.007-001	1	66.76	27.04	31.22	13.41 %
03.008-001	1	59.31	26.03	29.77	12.57 %
03.009-001	1	46.79	23.94	27.48	12.87 %
03.010-001	1	67.02	35.37	40.67	13.03 %
03.011-001	1	57.93	32.75	35.06	6.59 %
03.012-001	1	46.79	21.88	21.25	-2.95 %
03.013-001	1	59.31	23.15	23.71	2.36 %
03.014-001	1	46.65	22.58	21.90	-3.11 %
03.015-001	1	34.44	34.27	41.03	16.48 %
03.016-001	1	63.77	31.58	33.76	6.45 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

03.017-001	1	65.3	21.95	22.99	4.56 %
03.018-001	1	62.83	21.48	22.85	5.99 %
03.019-001	1	85.6	27.36	33.37	18.00 %
03.020-001	1	64.72	35.28	38.93	9.36 %
04.001-001	1	64.67	31.81	35.27	9.81 %
04.002-001	1	45.32	20.92	24.88	15.90 %
04.003-001	1	65.73	25.39	29.02	12.50 %
04.004-001	1	33.64	26.76	30.41	12.00 %
04.005-001	1	71.12	29.14	31.57	7.68 %
04.006-001	1	66.85	24.54	28.27	13.20 %
04.007-001	1	66.76	27.62	31.22	11.55 %
04.008-001	1	59.31	26.36	29.77	11.45 %
04.009-001	1	46.79	23.82	27.48	13.30 %
04.010-001	1	67.02	35.13	40.67	13.63 %
04.011-001	1	57.93	32.55	35.06	7.17 %
04.012-001	1	46.79	21.45	21.25	-0.95 %
04.013-001	1	59.31	23.14	23.71	2.38 %
04.014-001	1	46.65	22.67	21.90	-3.53 %
04.015-001	1	34.44	34.27	41.03	16.48 %
04.016-001	1	63.77	31.68	33.76	6.17 %
04.017-001	1	65.3	22.07	22.99	4.03 %
04.018-001	1	62.83	21.80	22.85	4.60 %
04.019-001	1	85.6	27.55	33.37	17.44 %
04.020-001	1	64.72	35.14	38.93	9.73 %
05.001-001	1	64.67	31.81	35.27	9.81 %
05.002-001	1	45.32	20.98	24.88	15.69 %
05.003-001	1	65.73	25.44	29.02	12.36 %
05.004-001	1	33.64	26.76	30.41	12.00 %
05.005-001	1	71.12	29.10	31.57	7.81 %
05.006-001	1	66.85	24.61	28.27	12.95 %
05.007-001	1	66.76	27.61	31.22	11.57 %
05.008-001	1	59.31	26.30	29.77	11.63 %
05.009-001	1	46.79	23.87	27.48	13.13 %
05.010-001	1	67.02	35.15	40.67	13.58 %
05.011-001	1	57.93	32.64	35.06	6.91 %
05.012-001	1	46.79	21.81	21.25	-2.64 %
05.013-001	1	59.31	23.39	23.71	1.35 %
05.014-001	1	46.65	22.86	21.90	-4.40 %
05.015-001	1	34.44	34.34	41.03	16.31 %
05.016-001	1	63.77	31.70	33.76	6.11 %
05.017-001	1	65.3	22.24	22.99	3.30 %
05.018-001	1	62.83	21.84	22.85	4.43 %
05.019-001	1	85.6	27.59	33.37	17.31 %
05.020-001	1	64.72	35.19	38.93	9.59 %
06.001-001	1	64.67	32.07	35.27	9.07 %
06.002-001	1	45.32	21.32	24.88	14.29 %
06.003-001	1	65.73	25.41	29.02	12.45 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

06.004-001	1	33.64	26.85	30.41	11.70 %
06.005-001	1	71.12	28.98	31.57	8.19 %
06.006-001	1	66.85	24.64	28.27	12.86 %
06.007-001	1	66.76	27.60	31.22	11.61 %
06.008-001	1	59.31	26.32	29.77	11.60 %
06.009-001	1	46.79	35.07	41.08	14.63 %
06.010-001	1	67.02	48.88	57.45	14.92 %
06.011-001	1	57.93	47.15	52.17	9.63 %
06.012-001	1	46.79	32.90	35.18	6.48 %
06.013-001	1	59.31	23.52	23.71	0.78 %
06.014-001	1	46.65	23.01	21.90	-5.08 %
06.015-001	1	34.44	34.54	41.03	15.82 %
06.016-001	1	63.77	31.68	33.76	6.17 %
06.017-001	1	65.3	22.36	22.99	2.75 %
06.018-001	1	62.83	21.87	22.85	4.32 %
06.019-001	1	85.6	27.52	33.37	17.52 %
06.020-001	1	64.72	35.15	38.93	9.69 %
07.001-001	1	64.67	31.79	35.27	9.87 %
07.002-001	1	45.32	21.28	24.88	14.47 %
07.003-001	1	65.73	25.42	29.02	12.40 %
07.004-001	1	33.64	26.23	30.41	13.72 %
07.005-001	1	71.12	28.79	31.57	8.80 %
07.006-001	1	66.85	24.74	28.27	12.51 %
07.007-001	1	66.76	27.64	31.22	11.49 %
07.008-001	1	59.31	35.30	40.59	13.04 %
07.009-001	1	59.31	32.98	34.88	5.45 %
07.010-001	1	46.65	22.83	21.90	-4.29 %
07.011-001	1	34.44	34.67	41.03	15.49 %
07.012-001	1	63.77	31.62	33.76	6.34 %
07.013-001	1	65.3	22.10	22.99	3.89 %
07.014-001	1	62.83	21.80	22.85	4.60 %
07.015-001	1	85.6	27.59	33.37	17.33 %
07.016-001	1	64.72	35.19	38.93	9.59 %
08.001-001	1	64.67	31.81	35.27	9.80 %
08.002-001	1	45.32	21.36	24.88	14.13 %
08.003-001	1	65.73	25.46	29.02	12.29 %
08.004-001	1	33.64	26.23	30.41	13.72 %
08.005-001	1	71.12	28.95	31.57	8.29 %
08.006-001	1	66.85	24.71	28.27	12.60 %
08.007-001	1	66.76	27.59	31.22	11.64 %
08.008-001	1	66.55	34.34	39.52	13.10 %
08.009-001	1	59.31	32.83	34.88	5.89 %
08.010-001	1	46.65	23.01	21.90	-5.08 %
08.011-001	1	34.44	34.87	41.03	15.01 %
08.012-001	1	63.77	31.93	33.76	5.41 %
08.013-001	1	65.3	22.32	22.99	2.93 %
08.014-001	1	62.83	21.83	22.85	4.47 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

08.015-001	1	85.6	27.54	33.37	17.46 %
08.016-001	1	64.72	35.32	38.93	9.26 %
09.001-001	1	64.67	32.17	35.27	8.78 %
09.002-001	1	45.32	21.36	24.88	14.13 %
09.003-001	1	65.73	25.27	29.02	12.94 %
09.004-001	1	33.64	26.05	30.41	14.32 %
09.005-001	1	71.12	29.04	31.57	8.01 %
09.006-001	1	66.85	24.40	28.27	13.69 %
09.007-001	1	66.76	27.49	31.22	11.97 %
09.008-001	1	66.55	33.94	39.52	14.13 %
09.009-001	1	59.31	33.03	34.88	5.31 %
09.010-001	1	46.65	22.92	21.90	-4.69 %
09.011-001	1	34.44	34.61	41.03	15.66 %
09.012-001	1	63.77	31.45	33.76	6.84 %
09.013-001	1	65.3	21.96	22.99	4.50 %
09.014-001	1	62.83	21.68	22.85	5.13 %
09.015-001	1	85.6	27.44	33.37	17.77 %
09.016-001	1	64.72	35.11	38.93	9.82 %
10.001-001	1	64.67	31.65	35.27	10.27 %
10.002-001	1	45.32	21.36	24.88	14.13 %
10.003-001	1	65.73	25.18	29.02	13.24 %
10.004-001	1	33.64	26.17	30.41	13.95 %
10.005-001	1	71.12	28.74	31.57	8.94 %
10.006-001	1	66.85	24.23	28.27	14.28 %
10.007-001	1	66.76	27.35	31.22	12.40 %
10.008-001	1	66.55	34.06	39.52	13.83 %
10.009-001	1	59.31	32.71	34.88	6.23 %
10.010-001	1	46.65	22.89	21.90	-4.53 %
10.011-001	1	34.44	34.84	41.03	15.09 %
10.012-001	1	63.77	31.57	33.76	6.48 %
10.013-001	1	65.3	22.08	22.99	3.97 %
10.014-001	1	46.67	22.96	22.11	-3.84 %
10.015-001	1	52.74	21.89	21.43	-2.13 %
10.016-001	1	46.73	21.73	21.31	-1.98 %
10.017-001	1	64.72	34.86	38.93	10.45 %
11.001-001	1	64.67	31.63	35.27	10.33 %
11.002-001	1	45.32	21.39	24.88	14.03 %
11.003-001	1	65.73	25.29	29.02	12.87 %
11.004-001	1	33.64	26.06	30.41	14.29 %
11.005-001	1	71.12	28.74	31.57	8.94 %
11.006-001	1	66.85	24.50	28.27	13.34 %
11.007-001	1	66.76	27.59	31.22	11.64 %
11.008-001	1	66.55	33.98	39.52	14.01 %
11.009-001	1	59.31	33.13	34.88	5.02 %
11.010-001	1	46.65	23.01	21.90	-5.11 %
11.011-001	1	34.44	34.87	41.03	15.01 %
11.012-001	1	63.77	31.77	33.76	5.88 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

11.013-001	1	65.3	22.24	22.99	3.28 %
11.014-001	1	46.67	22.98	22.11	-3.97 %
11.015-001	1	52.74	21.77	21.43	-1.59 %
11.016-001	1	46.73	21.85	21.31	-2.54 %
11.017-001	1	64.72	35.16	38.93	9.68 %
12.001-001	1	64.67	31.75	35.27	9.97 %
12.002-001	1	45.32	21.35	24.88	14.19 %
12.003-001	1	65.73	25.12	29.02	13.45 %
12.004-001	1	33.64	26.23	30.41	13.75 %
12.005-001	1	71.12	28.81	31.57	8.72 %
12.006-001	1	66.85	24.31	28.27	14.00 %
12.007-001	1	66.76	27.47	31.22	12.03 %
12.008-001	1	66.55	34.18	39.52	13.53 %
12.009-001	1	59.31	32.74	34.88	6.13 %
12.010-001	1	46.65	23.00	21.90	-5.03 %
12.011-001	1	34.44	34.88	41.03	14.99 %
12.012-001	1	63.77	31.51	33.76	6.66 %
12.013-001	1	65.3	22.21	22.99	3.41 %
12.014-001	1	46.67	22.89	22.11	-3.55 %
12.015-001	1	52.74	21.68	21.43	-1.16 %
12.016-001	1	46.73	21.64	21.31	-1.57 %
12.017-001	1	64.72	34.97	38.93	10.16 %
13.001-001	1	64.67	47.98	53.25	9.89 %
13.002-001	1	45.32	32.53	38.79	16.15 %
13.003-001	1	65.73	25.00	29.02	13.87 %
13.004-001	1	33.64	25.85	30.41	14.99 %
13.005-001	1	71.12	28.39	31.57	10.07 %
13.006-001	1	66.85	24.05	28.27	14.94 %
13.007-001	1	66.76	27.21	31.22	12.86 %
13.008-001	1	66.55	33.95	39.52	14.09 %
13.009-001	1	59.31	32.62	34.88	6.49 %
13.010-001	1	46.65	22.67	21.90	-3.56 %
13.011-001	1	34.44	34.61	41.03	15.66 %
13.012-001	1	63.77	31.37	33.76	7.08 %
13.013-001	1	65.3	21.88	22.99	4.86 %
13.014-001	1	46.67	23.11	22.11	-4.53 %
13.015-001	1	52.74	22.09	21.43	-3.07 %
13.016-001	1	46.73	32.68	35.28	7.38 %
14.001-001	1	67.16	30.70	35.73	14.07 %
14.002-001	1	33.64	26.08	30.41	14.22 %
14.003-001	1	71.12	28.64	31.57	9.28 %
14.004-001	1	66.85	24.34	28.27	13.92 %
14.005-001	1	66.76	27.30	31.22	12.55 %
14.006-001	1	66.55	33.73	39.52	14.65 %
14.007-001	1	59.31	32.34	34.88	7.30 %
14.008-001	1	46.65	22.71	21.90	-3.71 %
14.009-001	1	34.44	34.49	41.03	15.95 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

14.010-001	1	63.77	31.83	33.76	5.73 %
14.011-001	1	65.3	22.18	22.99	3.54 %
14.012-001	1	46.67	23.05	22.11	-4.26 %
14.013-001	1	52.74	31.33	32.37	3.21 %
15.001-001	1	67.16	31.01	35.73	13.22 %
15.002-001	1	33.64	26.07	30.41	14.27 %
15.003-001	1	71.12	28.98	31.57	8.18 %
15.004-001	1	66.85	24.74	28.27	12.51 %
15.005-001	1	66.76	27.59	31.22	11.63 %
15.006-001	1	66.55	33.98	39.52	14.01 %
15.007-001	1	59.31	32.84	34.88	5.84 %
15.008-001	1	46.65	22.99	21.90	-5.00 %
15.009-001	1	34.44	34.84	41.03	15.09 %
15.010-001	1	63.77	31.95	33.76	5.37 %
15.011-001	1	65.3	22.13	22.99	3.77 %
15.012-001	1	46.67	23.07	22.11	-4.37 %
15.013-001	1	58.81	32.14	32.94	2.42 %
16.001-001	1	67.16	30.81	35.73	13.76 %
16.002-001	1	33.64	25.94	30.41	14.68 %
16.003-001	1	71.12	28.53	31.57	9.63 %
16.004-001	1	66.85	24.34	28.27	13.89 %
16.005-001	1	66.76	27.73	31.22	11.19 %
16.006-001	1	66.55	33.84	39.52	14.37 %
16.007-001	1	59.31	32.82	34.88	5.90 %
16.008-001	1	46.65	22.94	21.90	-4.78 %
16.009-001	1	34.44	34.54	41.03	15.82 %
16.010-001	1	63.77	31.50	33.76	6.70 %
16.011-001	1	65.3	22.02	22.99	4.23 %
16.012-001	1	46.67	23.12	22.11	-4.59 %
16.013-001	1	58.81	32.12	32.94	2.49 %
17.001-001	1	67.16	30.77	35.73	13.88 %
17.002-001	1	33.64	26.23	30.41	13.72 %
17.003-001	1	71.12	28.59	31.57	9.43 %
17.004-001	1	66.85	24.20	28.27	14.42 %
17.005-001	1	66.76	27.38	31.22	12.32 %
17.006-001	1	66.55	33.68	39.52	14.78 %
17.007-001	1	59.31	32.73	34.88	6.16 %
17.008-001	1	46.65	23.00	21.90	-5.03 %
17.009-001	1	34.44	34.50	41.03	15.93 %
17.010-001	1	63.77	31.38	33.76	7.05 %
17.011-001	1	65.3	21.97	22.99	4.44 %
17.012-001	1	46.67	22.96	22.11	-3.86 %
17.013-001	1	58.81	32.02	32.94	2.78 %
18.001-001	1	67.16	30.72	35.73	14.03 %
18.002-001	1	33.64	26.20	30.41	13.85 %
18.003-001	1	71.12	28.81	31.57	8.74 %
18.004-001	1	66.85	24.26	28.27	14.19 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

18.005-001	1	66.76	27.31	31.22	12.54 %
18.006-001	1	66.55	33.94	39.52	14.12 %
18.007-001	1	59.31	32.80	34.88	5.97 %
18.008-001	1	46.65	22.97	21.90	-4.91 %
18.009-001	1	34.44	34.83	41.03	15.11 %
18.010-001	1	63.77	31.64	33.76	6.27 %
18.011-001	1	65.3	21.94	22.99	4.58 %
18.012-001	1	46.67	23.12	22.11	-4.56 %
18.013-001	1	58.81	32.20	32.94	2.25 %
19.001-001	1	67.16	31.22	35.73	12.63 %
19.002-001	1	33.64	26.17	30.41	13.92 %
19.003-001	1	71.12	28.75	31.57	8.92 %
19.004-001	1	66.85	24.29	28.27	14.08 %
19.005-001	1	66.76	27.37	31.22	12.33 %
19.006-001	1	66.55	33.86	39.52	14.33 %
19.007-001	1	59.31	33.08	34.88	5.15 %
19.008-001	1	46.65	22.97	21.90	-4.91 %
19.009-001	1	34.44	34.48	41.03	15.97 %
19.010-001	1	63.77	31.91	33.76	5.48 %
19.011-001	1	65.3	22.32	22.99	2.93 %
19.012-001	1	46.67	23.16	22.11	-4.78 %
19.013-001	1	58.81	32.36	32.94	1.75 %
20.001-001	1	67.16	30.66	35.73	14.20 %
20.002-001	1	33.64	26.22	30.41	13.77 %
20.003-001	1	71.12	46.30	50.90	9.04 %
20.004-001	1	66.85	40.30	45.12	10.69 %
20.005-001	1	66.76	43.15	47.62	9.40 %
20.006-001	1	66.55	50.99	58.98	13.54 %
20.007-001	1	59.31	42.25	43.93	3.80 %
20.008-001	1	46.65	38.50	38.67	0.44 %
20.009-001	1	34.44	34.86	41.03	15.05 %
20.010-001	1	63.77	31.88	33.76	5.57 %
20.011-001	1	65.3	22.27	22.99	3.15 %
20.012-001	1	46.67	23.16	22.11	-4.75 %
20.013-001	1	58.81	32.26	32.94	2.05 %
21.001-001	1	67.16	30.79	35.73	13.83 %
21.002-001	1	42.1	31.80	37.68	15.61 %
21.003-001	1	50.98	31.14	37.40	16.75 %
21.004-001	1	63.77	31.90	33.76	5.52 %
21.005-001	1	65.3	22.29	22.99	3.08 %
21.006-001	1	46.67	23.16	22.11	-4.75 %
21.007-001	1	58.81	32.40	32.94	1.66 %
22.001-001	1	67.16	30.67	35.73	14.16 %
22.002-001	1	42.1	31.37	37.68	16.74 %
22.003-001	1	50.98	32.62	37.88	13.91 %
22.004-001	1	63.77	31.88	33.76	5.57 %
22.005-001	1	65.3	21.94	22.99	4.58 %

BLOCK COMPLIANCE

Calculation Type: New Build (As Built)

22.006-001	1	46.67	23.14	22.11	-4.67 %
22.007-001	1	58.81	32.14	32.94	2.43 %
23.001-001	1	67.16	30.67	35.73	14.16 %
23.002-001	1	42.1	31.34	37.68	16.83 %
23.003-001	1	50.98	32.58	37.88	13.99 %
23.004-001	1	63.77	31.44	33.76	6.86 %
23.005-001	1	65.3	21.97	22.99	4.46 %
23.006-001	1	46.67	23.17	22.11	-4.81 %
23.007-001	1	58.81	32.01	32.94	2.83 %
24.001-001	1	67.16	48.21	55.20	12.66 %
24.002-001	1	42.1	47.62	54.90	13.27 %
24.003-001	1	50.98	52.52	60.72	13.49 %
24.004-001	1	63.77	48.97	52.57	6.85 %
24.005-001	1	65.3	38.63	39.08	1.13 %
24.006-001	1	46.67	39.90	39.74	-0.41 %
24.007-001	1	58.81	49.94	52.34	4.60 %
13.017*-001	1	64.72	48.62	55.55	12.47 %
Totals:	352	20407.93	10,189.40	11,294.09	
Average DFEE = 29.06 kWh/m ² /yr		% DFEE/TFEE	PASS		
Average TFEE = 32.22 kWh/m ² /yr		9.81 %			